PWSID	PWSName	FacilityID	FacilityName	FacilityWat	SamplePointI	SamplePoi	CollectionDate	SampleID	Contaminant	MethodID	AnalyticalR	AnalyticalResultValue	MRL	Unit of Me	State
MD0010008	City of Cumberland	1	Evitts Creek Filter Plant	SW	WTP POE	EP	7/24/2013	K1307524-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0010008	City of Cumberland	1	Evitts Creek Filter Plant	SW	WTP POE	EP	7/24/2013	K1307524-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0010008	City of Cumberland	1	Evitts Creek Filter Plant	SW	WTP POE	EP	7/24/2013	K1307524-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0010008	City of Cumberland	1	Evitts Creek Filter Plant	SW	WTP POE	EP	7/24/2013	K1307524-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0010008	City of Cumberland	1	Evitts Creek Filter Plant	SW	WTP POE	EP	7/24/2013	K1307524-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0010008	City of Cumberland	1	Evitts Creek Filter Plant	SW	WTP POE	EP	7/24/2013	K1307524-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0010008	City of Cumberland	1	Evitts Creek Filter Plant	SW	WTP POE	EP	10/17/2013	K1311419-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0010008	City of Cumberland	1	Evitts Creek Filter Plant	SW	WTP POE	EP	10/17/2013	K1311419-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0010008	City of Cumberland	1	Evitts Creek Filter Plant	SW	WTP POE	EP	10/17/2013	K1311419-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0010008	City of Cumberland	1	Evitts Creek Filter Plant	SW	WTP POE	EP	10/17/2013	K1311419-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0010008	City of Cumberland	1	Evitts Creek Filter Plant	SW	WTP POE	EP	10/17/2013	K1311419-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0010008	City of Cumberland	1	Evitts Creek Filter Plant	SW	WTP POE	EP	10/17/2013	K1311419-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0010008	City of Cumberland	1	Evitts Creek Filter Plant	SW	WTP POE	EP	1/6/2014	K1400294-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0010008	City of Cumberland	1	Evitts Creek Filter Plant	SW	WTP POE	EP	1/6/2014	K1400294-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0010008	City of Cumberland	1	Evitts Creek Filter Plant	SW	WTP POE	EP	1/6/2014	K1400294-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0010008	City of Cumberland	1	Evitts Creek Filter Plant	SW	WTP POE	EP	1/6/2014	K1400294-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0010008	City of Cumberland	1	Evitts Creek Filter Plant	SW	WTP POE	EP	1/6/2014	K1400294-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0010008	City of Cumberland	1	Evitts Creek Filter Plant	SW	WTP POE	EP	1/6/2014	K1400294-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0010008	City of Cumberland	1	Evitts Creek Filter Plant	SW	WTP POE	EP	4/8/2014	K1403619-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0010008	City of Cumberland	1	Evitts Creek Filter Plant	SW	WTP POE	EP	4/8/2014	K1403619-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0010008	City of Cumberland	1	Evitts Creek Filter Plant	SW	WTP POE	EP	4/8/2014	K1403619-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0010008	City of Cumberland	1	Evitts Creek Filter Plant	SW	WTP POE	EP	4/8/2014	K1403619-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0010008	City of Cumberland	1	Evitts Creek Filter Plant	SW	WTP POE	EP	4/8/2014	K1403619-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0010008	City of Cumberland	1	Evitts Creek Filter Plant	SW	WTP POE	EP	4/8/2014	K1403619-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0010011	City of Frostburg	1	Frostburg Filter Plant	SW	WTP POE	EP	12/15/2014	835802-13028	PFHxS	EPA 537	<		0.03	ppb	MD
MD0010011	City of Frostburg	1	Frostburg Filter Plant	SW	WTP POE	EP	12/15/2014	835802-13028	PFNA	EPA 537	<		0.02	ppb	MD
MD0010011	City of Frostburg	1	Frostburg Filter Plant	SW	WTP POE	EP	12/15/2014	835802-13028	PFHpA	EPA 537	<		0.01	ppb	MD
MD0010011	City of Frostburg	1	Frostburg Filter Plant	SW	WTP POE	EP	12/15/2014	835802-13028	PFOA	EPA 537	<		0.02	ppb	MD
MD0010011	City of Frostburg	1	Frostburg Filter Plant	SW	WTP POE	EP	12/15/2014	835802-13028	PFOS	EPA 537	<		0.04	ppb	MD
MD0010011	City of Frostburg	1	Frostburg Filter Plant	SW	WTP POE	EP	12/15/2014	835802-13028	PFBS	EPA 537	<		0.09	ppb	MD
MD0010011	City of Frostburg	1	Frostburg Filter Plant	SW	WTP POE	EP	3/10/2015	847543-13589	PFNA	EPA 537	<		0.02	ppb	MD
MD0010011	City of Frostburg	1	Frostburg Filter Plant	SW	WTP POE	EP	3/10/2015	847543-13589	PFHpA	EPA 537	<		0.01	ppb	MD
MD0010011	City of Frostburg	1	Frostburg Filter Plant	SW	WTP POE	EP	3/10/2015	847543-13589	PFBS	EPA 537	<		0.09	ppb	MD
MD0010011	City of Frostburg	1	Frostburg Filter Plant	SW	WTP POE	EP	3/10/2015	847543-13589	PFHxS	EPA 537	<		0.03	ppb	MD
MD0010011	City of Frostburg	1	Frostburg Filter Plant	SW	WTP POE	EP	3/10/2015	847543-13589	PFOS	EPA 537	<		0.04	ppb	MD
MD0010011	City of Frostburg	1	Frostburg Filter Plant	SW	WTP POE	EP	3/10/2015	847543-13589	PFOA	EPA 537	<		0.02	ppb	MD
MD0010011	City of Frostburg	1	Frostburg Filter Plant	SW	WTP POE	EP	6/2/2015	863247-14230	PFHxS	EPA 537	<		0.03	ppb	MD
MD0010011	City of Frostburg	1	Frostburg Filter Plant	SW	WTP POE	EP	6/2/2015	863247-14230	PFHpA	EPA 537	<		0.01	ppb	MD
MD0010011	City of Frostburg	1	Frostburg Filter Plant	SW	WTP POE	EP	6/2/2015	863247-14230	PFNA	EPA 537	<		0.02	ppb	MD
MD0010011	City of Frostburg	1	Frostburg Filter Plant	SW	WTP POE	EP	6/2/2015	863247-14230	PFBS	EPA 537	<		0.09	ppb	MD
MD0010011	City of Frostburg	1	Frostburg Filter Plant	SW	WTP POE	EP	6/2/2015	863247-14230	PFOA	EPA 537	<		0.02	ppb	MD
MD0010011	City of Frostburg	1	Frostburg Filter Plant	SW	WTP POE	EP	6/2/2015	863247-14230	PFOS	EPA 537	<		0.04	ppb	MD
MD0010011	City of Frostburg	1	Frostburg Filter Plant	SW	WTP POE	EP	9/14/2015	882880-14986	PFOA	EPA 537	<		0.02	ppb	MD
MD0010011	City of Frostburg	1	Frostburg Filter Plant	SW	WTP POE	EP	9/14/2015	882880-14986	PFOS	EPA 537	<		0.04	ppb	MD
MD0010011	City of Frostburg	1	Frostburg Filter Plant	SW	WTP POE	EP	9/14/2015	882880-14986	PFNA	EPA 537	<		0.02	ppb	MD
MD0010011	City of Frostburg	1	Frostburg Filter Plant	SW	WTP POE	EP	9/14/2015	882880-14986	PFHxS	EPA 537	<		0.03	ppb	MD
MD0010011	City of Frostburg	1	Frostburg Filter Plant	SW	WTP POE	EP	9/14/2015	882880-14986	PFHpA	EPA 537	<		0.01	ppb	MD
MD0010011	City of Frostburg	1	Frostburg Filter Plant	SW	WTP POE	EP	9/14/2015	882880-14986	PFBS	EPA 537	<		0.09	ppb	MD
MD0010018	Midland - Lonaconing	1	Charlestown Filter Plant	SW	Charlestown	EP	5/11/2015	111250R	PFBS	EPA 537	<		0.09	ppb	MD
MD0010018	Midland - Lonaconing	1	Charlestown Filter Plant	SW	Charlestown	EP	5/11/2015	111250R	PFHpA	EPA 537	<		0.01	ppb	MD
MD0010018	Midland - Lonaconing	1	Charlestown Filter Plant	SW	Charlestown	EP	5/11/2015	111250R	PFHxS	EPA 537	<		0.03	ppb	MD
MD0010018	Midland - Lonaconing	1	Charlestown Filter Plant	SW	Charlestown	EP	5/11/2015	111250R	PFNA	EPA 537	<		0.02	ppb	MD
MD0010018	Midland - Lonaconing	1	Charlestown Filter Plant	SW	Charlestown	EP	5/11/2015	111250R	PFOS	EPA 537	<		0.04	ppb	MD
MD0010018	Midland - Lonaconing	1	Charlestown Filter Plant	SW	Charlestown	EP	5/11/2015	111250R	PFOA	EPA 537	<		0.02	ppb	MD
MD0010018	Midland - Lonaconing	2	Koontz Filter Plant	SW	Koontz WTP I	EP	3/5/2014	105919P	PFBS	EPA 537	<		0.09	ppb	MD
MD0010018	Midland - Lonaconing	2	Koontz Filter Plant	SW	Koontz WTP I	EP	3/5/2014	105919P	PFHpA	EPA 537	<		0.01	ppb	MD
MD0010018	Midland - Lonaconing	2	Koontz Filter Plant	SW	Koontz WTP I	EP	3/5/2014	105919P	PFHxS	EPA 537	<		0.03	ppb	MD
MD0010018	Midland - Lonaconing	2	Koontz Filter Plant	SW	Koontz WTP I	EP	3/5/2014	105919P	PFNA	EPA 537	<		0.02	ppb	MD
MD0010018	Midland - Lonaconing	2	Koontz Filter Plant	SW	Koontz WTP I	EP	3/5/2014	105919P	PFOS	EPA 537	<		0.04	ppb	MD
MD0010018	Midland - Lonaconing	2	Koontz Filter Plant	SW	Koontz WTP I	EP	3/5/2014	105919P	PFOA	EPA 537	<		0.02	ppb	MD
MD0010018	Midland - Lonaconing	2	Koontz Filter Plant	SW	Koontz WTP I	EP	6/2/2014	107599P	PFBS	EPA 537	<		0.09	ppb	MD
MD0010018	Midland - Lonaconing	2	Koontz Filter Plant	SW	Koontz WTP I	EP	6/2/2014	107599P	PFHpA	EPA 537	<		0.01	ppb	MD
MD0010018	Midland - Lonaconing	2	Koontz Filter Plant	SW	Koontz WTP I	EP	6/2/2014	107599P	PFHxS	EPA 537	<		0.03	ppb	MD
MD0010018	Midland - Lonaconing	2	Koontz Filter Plant	SW	Koontz WTP I	EP	6/2/2014	107599P	PFNA	EPA 537	<		0.02	ppb	MD
MD0010018	Midland - Lonaconing	2	Koontz Filter Plant	SW	Koontz WTP I	EP	6/2/2014	107599P	PFOS	EPA 537	<		0.04	ppb	MD
MD0010018	Midland - Lonaconing	2	Koontz Filter Plant	SW	Koontz WTP I	EP	6/2/2014	107599P	PFOA	EPA 537	<		0.02	ppb	MD
MD0010018	Midland - Lonaconing	2	Koontz Filter Plant	SW	Koontz WTP I	EP	9/9/2014	109065P	PFBS	EPA 537	<		0.09	ppb	MD
MD0010018	Midland - Lonaconing	2	Koontz Filter Plant	SW	Koontz WTP I	EP	9/9/2014	109065P	PFHpA	EPA 537	<		0.01	ppb	MD
MD0010018	Midland - Lonaconing	2	Koontz Filter Plant	SW	Koontz WTP I	EP	9/9/2014	109065P	PFHxS	EPA 537	<		0.03	ppb	MD
MD0010018	Midland - Lonaconing	2	Koontz Filter Plant	SW	Koontz WTP I	EP	9/9/2014	109065P	PFNA	EPA 537	<		0.02	ppb	MD
MD0010018	Midland - Lonaconing	2	Koontz Filter Plant	SW	Koontz WTP I	EP	9/9/2014	109065P	PFOS	EPA 537	<		0.04	ppb	MD
MD0010018	Midland - Lonaconing	2	Koontz Filter Plant	SW	Koontz WTP I	EP	9/9/2014	109065P	PFOA	EPA 537	<		0.02	ppb	MD
MD0010018	Midland - Lonaconing	2	Koontz Filter Plant	SW	Koontz WTP I	EP	12/3/2014	110718P	PFBS	EPA 537	<		0.09	ppb	MD
MD0010018	Midland - Lonaconing	2	Koontz Filter Plant	SW	Koontz WTP I	EP	12/3/2014	110718P	PFHpA	EPA 537	<		0.01	ppb	MD
MD0010018	Midland - Lonaconing	2	Koontz Filter Plant	SW	Koontz WTP I	EP	12/3/2014	110718P	PFHxS	EPA 537	<		0.03	ppb	MD

MD0010018	Midland - Lonaconing	2	Koontz Filter Plant	SW	Koontz WTP I	EP	12/3/2014	110718P	PFNA	EPA 537	<		0.02	ppb	MD
MD0010018	Midland - Lonaconing	2	Koontz Filter Plant	SW	Koontz WTP I	EP	12/3/2014	110718P	PFOS	EPA 537	<		0.04	ppb	MD
MD0010018	Midland - Lonaconing	2	Koontz Filter Plant	SW	Koontz WTP I	EP	12/3/2014	110718P	PFOA	EPA 537	<		0.02	ppb	MD
MD0010018	Midland - Lonaconing	3	Gilmore Midland Filter Plant	SW	Gilmore WTP	EP	3/4/2014	105920P	PFBS	EPA 537	<		0.09	ppb	MD
MD0010018	Midland - Lonaconing	3	Gilmore Midland Filter Plant	SW	Gilmore WTP	EP	3/4/2014	105920P	PFHpA	EPA 537	<		0.01	ppb	MD
MD0010018	Midland - Lonaconing	3	Gilmore Midland Filter Plant	SW	Gilmore WTP	EP	3/4/2014	105920P	PFHxS	EPA 537	<		0.03	ppb	MD
MD0010018	Midland - Lonaconing	3	Gilmore Midland Filter Plant	SW	Gilmore WTP	EP	3/4/2014	105920P	PFNA	EPA 537	<		0.02	ppb	MD
MD0010018	Midland - Lonaconing	3	Gilmore Midland Filter Plant	SW	Gilmore WTP	EP	3/4/2014	105920P	PFOS	EPA 537	<		0.04	ppb	MD
MD0010018	Midland - Lonaconing	3	Gilmore Midland Filter Plant	SW	Gilmore WTP	EP	3/4/2014	105920P	PFOA	EPA 537	<		0.02	ppb	MD
MD0010018	Midland - Lonaconing	3	Gilmore Midland Filter Plant	SW	Gilmore WTP	EP	6/2/2014	107600P	PFBS	EPA 537	<		0.09	ppb	MD
MD0010018	Midland - Lonaconing	3	Gilmore Midland Filter Plant	SW	Gilmore WTP	EP	6/2/2014	107600P	PFHpA	EPA 537	<		0.01	ppb	MD
MD0010018	Midland - Lonaconing	3	Gilmore Midland Filter Plant	SW	Gilmore WTP	EP	6/2/2014	107600P	PFHxS	EPA 537	<		0.03	ppb	MD
MD0010018	Midland - Lonaconing	3	Gilmore Midland Filter Plant	SW	Gilmore WTP	EP	6/2/2014	107600P	PFNA	EPA 537	<		0.02	ppb	MD
MD0010018	Midland - Lonaconing	3	Gilmore Midland Filter Plant	SW	Gilmore WTP	EP	6/2/2014	107600P	PFOS	EPA 537	<		0.04	ppb	MD
MD0010018	Midland - Lonaconing	3	Gilmore Midland Filter Plant	SW	Gilmore WTP	EP	6/2/2014	107600P	PFOA	EPA 537	<		0.02	ppb	MD
MD0010018	Midland - Lonaconing	3	Gilmore Midland Filter Plant	SW	Gilmore WTP	EP	9/9/2014	109066P	PFBS	EPA 537	<		0.09	ppb	MD
MD0010018	Midland - Lonaconing	3	Gilmore Midland Filter Plant	SW	Gilmore WTP	EP	9/9/2014	109066P	PFHpA	EPA 537	<		0.01	ppb	MD
MD0010018	Midland - Lonaconing	3	Gilmore Midland Filter Plant	SW	Gilmore WTP	EP	9/9/2014	109066P	PFHxS	EPA 537	<		0.03	ppb	MD
MD0010018	Midland - Lonaconing	3	Gilmore Midland Filter Plant	SW	Gilmore WTP	EP	9/9/2014	109066P	PFNA	EPA 537	<		0.02	ppb	MD
MD0010018	Midland - Lonaconing	3	Gilmore Midland Filter Plant	SW	Gilmore WTP	EP	9/9/2014	109066P	PFOS	EPA 537	<		0.04	ppb	MD
MD0010018	Midland - Lonaconing	3	Gilmore Midland Filter Plant	SW	Gilmore WTP	EP	9/9/2014	109066P	PFOA	EPA 537	<		0.02	ppb	MD
MD0010018	Midland - Lonaconing	3	Gilmore Midland Filter Plant	SW	Gilmore WTP	EP	12/3/2014	110719P	PFBS	EPA 537	<		0.09	ppb	MD
MD0010018	Midland - Lonaconing	3	Gilmore Midland Filter Plant	SW	Gilmore WTP	EP	12/3/2014	110719P	PFHpA	EPA 537	<		0.01	ppb	MD
MD0010018	Midland - Lonaconing	3	Gilmore Midland Filter Plant	SW	Gilmore WTP	EP	12/3/2014	110719P	PFHxS	EPA 537	<		0.03	ppb	MD
MD0010018	Midland - Lonaconing	3	Gilmore Midland Filter Plant	SW	Gilmore WTP	EP	12/3/2014	110719P	PFNA	EPA 537	<		0.02	ppb	MD
MD0010018	Midland - Lonaconing	3	Gilmore Midland Filter Plant	SW	Gilmore WTP	EP	12/3/2014	110719P	PFOS	EPA 537	<		0.04	ppb	MD
MD0010018	Midland - Lonaconing	3	Gilmore Midland Filter Plant	SW	Gilmore WTP	EP	12/3/2014	110719P	PFOA	EPA 537	<		0.02	ppb	MD
MD0020001	City of Annapolis	1	Annapolis Filter Plant	GW	WTP POE	EP	10/14/2013	752521-10038	PFOA	EPA 537	<		0.02	ppb	MD
MD0020001	City of Annapolis	1	Annapolis Filter Plant	GW	WTP POE	EP	10/14/2013	752521-10038	PFBS	EPA 537	<		0.09	ppb	MD
MD0020001	City of Annapolis	1	Annapolis Filter Plant	GW	WTP POE	EP	10/14/2013	752521-10038	PFHpA	EPA 537	<		0.01	ppb	MD
MD0020001	City of Annapolis	1	Annapolis Filter Plant	GW	WTP POE	EP	10/14/2013	752521-10038	PFOS	EPA 537	<		0.04	ppb	MD
MD0020001	City of Annapolis	1	Annapolis Filter Plant	GW	WTP POE	EP	10/14/2013	752521-10038	PFNA	EPA 537	<		0.02	ppb	MD
MD0020001	City of Annapolis	1	Annapolis Filter Plant	GW	WTP POE	EP	10/14/2013	752521-10038	PFHxS	EPA 537	<		0.03	ppb	MD
MD0020001	City of Annapolis	1	Annapolis Filter Plant	GW	WTP POE	EP	4/14/2014	780375-11205	PFNA	EPA 537	<		0.02	ppb	MD
MD0020001	City of Annapolis	1	Annapolis Filter Plant	GW	WTP POE	EP	4/14/2014	780375-11205	PFHxS	EPA 537	<		0.03	ppb	MD
MD0020001	City of Annapolis	1	Annapolis Filter Plant	GW	WTP POE	EP	4/14/2014	780375-11205	PFOS	EPA 537	<		0.04	ppb	MD
MD0020001	City of Annapolis	1	Annapolis Filter Plant	GW	WTP POE	EP	4/14/2014	780375-11205	PFHpA	EPA 537	<		0.01	ppb	MD
MD0020001	City of Annapolis	1	Annapolis Filter Plant	GW	WTP POE	EP	4/14/2014	780375-11205	PFBS	EPA 537	<		0.09	ppb	MD
MD0020001	City of Annapolis	1	Annapolis Filter Plant	GW	WTP POE	EP	4/14/2014	780375-11205	PFOA	EPA 537	<		0.02	ppb	MD
MD0020004	Broad Creek	2	Broad Creek WTP II	GW	WTP POE	EP	8/28/2013	1308A02-001F	PFBS	EPA 537	<		0.09	ppb	MD
MD0020004	Broad Creek	2	Broad Creek WTP II	GW	WTP POE	EP	8/28/2013	1308A02-001F	PFNA	EPA 537	<		0.02	ppb	MD
MD0020004	Broad Creek	2	Broad Creek WTP II	GW	WTP POE	EP	8/28/2013	1308A02-001F	PFOS	EPA 537	<		0.04	ppb	MD
MD0020004	Broad Creek	2	Broad Creek WTP II	GW	WTP POE	EP	8/28/2013	1308A02-001F	PFHpA	EPA 537	<		0.01	ppb	MD
MD0020004	Broad Creek	2	Broad Creek WTP II	GW	WTP POE	EP	8/28/2013	1308A02-001F	PFHxS	EPA 537	<		0.03	ppb	MD
MD0020004	Broad Creek	2	Broad Creek WTP II	GW	WTP POE	EP	8/28/2013	1308A02-001F	PFOA	EPA 537	<		0.02	ppb	MD
MD0020004	Broad Creek	2	Broad Creek WTP II	GW	WTP POE	EP	2/26/2014	1402961-001F	PFOA	EPA 537	<		0.02	ppb	MD
MD0020004	Broad Creek	2	Broad Creek WTP II	GW	WTP POE	EP	2/26/2014	1402961-001F	PFOS	EPA 537	<		0.04	ppb	MD
MD0020004	Broad Creek	2	Broad Creek WTP II	GW	WTP POE	EP	2/26/2014	1402961-001F	PFNA	EPA 537	<		0.02	ppb	MD
MD0020004	Broad Creek	2	Broad Creek WTP II	GW	WTP POE	EP	2/26/2014	1402961-001F	PFHpA	EPA 537	<		0.01	ppb	MD
MD0020004	Broad Creek	2	Broad Creek WTP II	GW	WTP POE	EP	2/26/2014	1402961-001F	PFHxS	EPA 537	<		0.03	ppb	MD
MD0020004	Broad Creek	2	Broad Creek WTP II	GW	WTP POE	EP	2/26/2014	1402961-001F	PFBS	EPA 537	<		0.09	ppb	MD
MD0020008	Crofton-Odenton	4	Crofton Meadows WTP II	GW	WTP POE	EP	2/25/2013	1302722-001F	PFBS	EPA 537	<		0.09	ppb	MD
MD0020008	Crofton-Odenton	4	Crofton Meadows WTP II	GW	WTP POE	EP	2/25/2013	1302722-001F	PFHpA	EPA 537	<		0.01	ppb	MD
MD0020008	Crofton-Odenton	4	Crofton Meadows WTP II	GW	WTP POE	EP	2/25/2013	1302722-001F	PFHxS	EPA 537	<		0.03	ppb	MD
MD0020008	Crofton-Odenton	4	Crofton Meadows WTP II	GW	WTP POE	EP	2/25/2013	1302722-001F	PFNA	EPA 537	<		0.02	ppb	MD
MD0020008	Crofton-Odenton	4	Crofton Meadows WTP II	GW	WTP POE	EP	2/25/2013	1302722-001F	PFOS	EPA 537	<		0.04	ppb	MD
MD0020008	Crofton-Odenton	4	Crofton Meadows WTP II	GW	WTP POE	EP	2/25/2013	1302722-001F	PFOA	EPA 537	<		0.02	ppb	MD
MD0020008	Crofton-Odenton	4	Crofton Meadows WTP II	GW	WTP POE	EP	8/28/2013	1308999-001F	PFOA	EPA 537	<		0.02	ppb	MD
MD0020008	Crofton-Odenton	4	Crofton Meadows WTP II	GW	WTP POE	EP	8/28/2013	1308999-001F	PFOS	EPA 537	<		0.04	ppb	MD
MD0020008	Crofton-Odenton	4	Crofton Meadows WTP II	GW	WTP POE	EP	8/28/2013	1308999-001F	PFNA	EPA 537	<		0.02	ppb	MD
MD0020008	Crofton-Odenton	4	Crofton Meadows WTP II	GW	WTP POE	EP	8/28/2013	1308999-001F	PFBS	EPA 537	<		0.09	ppb	MD
MD0020008	Crofton-Odenton	4	Crofton Meadows WTP II	GW	WTP POE	EP	8/28/2013	1308999-001F	PFHpA	EPA 537	<		0.01	ppb	MD
MD0020008	Crofton-Odenton	4	Crofton Meadows WTP II	GW	WTP POE	EP	8/28/2013	1308999-001F	PFHxS	EPA 537	<		0.03	ppb	MD
MD0020012	Fort George G. Meade	1	Ft. Meade Filter Plant	GW	WTP POE	EP	12/3/2014	27718101	PFOA	EPA 537	<		0.02	ppb	MD
MD0020012	Fort George G. Meade	1	Ft. Meade Filter Plant	GW	WTP POE	EP	12/3/2014	27718101	PFHxS	EPA 537	<		0.03	ppb	MD
MD0020012	Fort George G. Meade	1	Ft. Meade Filter Plant	GW	WTP POE	EP	12/3/2014	27718101	PFHpA	EPA 537	<		0.01	ppb	MD
MD0020012	Fort George G. Meade	1	Ft. Meade Filter Plant	GW	WTP POE	EP	12/3/2014	27718101	PFBS	EPA 537	<		0.09	ppb	MD
MD0020012	Fort George G. Meade	1	Ft. Meade Filter Plant	GW	WTP POE	EP	12/3/2014	27718101	PFOS	EPA 537	<		0.04	ppb	MD
MD0020012	Fort George G. Meade	1	Ft. Meade Filter Plant	GW	WTP POE	EP	12/3/2014	27718101	PFNA	EPA 537	<		0.02	ppb	MD
MD0020012	Fort George G. Meade	1	Ft. Meade Filter Plant	GW	WTP POE	EP	6/3/2015	29085401	PFOS	EPA 537	<		0.04	ppb	MD
MD0020012	Fort George G. Meade	1	Ft. Meade Filter Plant	GW	WTP POE	EP	6/3/2015	29085401	PFBS	EPA 537	<		0.09	ppb	MD
MD0020012	Fort George G. Meade	1	Ft. Meade Filter Plant	GW	WTP POE	EP	6/3/2015	29085401	PFHpA	EPA 537	<		0.01	ppb	MD
MD0020012	Fort George G. Meade	1	Ft. Meade Filter Plant	GW	WTP POE	EP	6/3/2015	29085401	PFHxS	EPA 537	<		0.03	ppb	MD
MD0020012	Fort George G. Meade	1	Ft. Meade Filter Plant	GW	WTP POE	EP	6/3/2015	29085401	PFOA	EPA 537	<		0.02	ppb	MD
MD0020012	Fort George G. Meade	1	Ft. Meade Filter Plant	GW	WTP POE	EP	6/3/2015	29085401	PFNA	EPA 537	<		0.02	ppb	MD
MD0020017	Glen Burnie-Broadneck	2	Stevenson Road SCW	GW	WTP POE	EP	11/21/2013	1311816-001F	PFBS	EPA 537	<		0.09	ppb	MD

MD0020017	Glen Burnie-Broadneck	2	Stevenson Road SCW	GW	WTP POE	EP	11/21/2013	1311816-001F	PFHpA	EPA 537	<		0.01	ppb	MD
MD0020017	Glen Burnie-Broadneck	2	Stevenson Road SCW	GW	WTP POE	EP	11/21/2013	1311816-001F	PFHxS	EPA 537	<		0.03	ppb	MD
MD0020017	Glen Burnie-Broadneck	2	Stevenson Road SCW	GW	WTP POE	EP	11/21/2013	1311816-001F	PFNA	EPA 537	<		0.02	ppb	MD
MD0020017	Glen Burnie-Broadneck	2	Stevenson Road SCW	GW	WTP POE	EP	11/21/2013	1311816-001F	PFOA	EPA 537	<		0.02	ppb	MD
MD0020017	Glen Burnie-Broadneck	2	Stevenson Road SCW	GW	WTP POE	EP	11/21/2013	1311816-001F	PFOS	EPA 537	<		0.04	ppb	MD
MD0020017	Glen Burnie-Broadneck	2	Stevenson Road SCW	GW	WTP POE	EP	5/7/2014	1405278-001F	PFOA	EPA 537	<		0.02	ppb	MD
MD0020017	Glen Burnie-Broadneck	2	Stevenson Road SCW	GW	WTP POE	EP	5/7/2014	1405278-001F	PFNA	EPA 537	<		0.02	ppb	MD
MD0020017	Glen Burnie-Broadneck	2	Stevenson Road SCW	GW	WTP POE	EP	5/7/2014	1405278-001F	PFHpA	EPA 537	<		0.01	ppb	MD
MD0020017	Glen Burnie-Broadneck	2	Stevenson Road SCW	GW	WTP POE	EP	5/7/2014	1405278-001F	PFOS	EPA 537	<		0.04	ppb	MD
MD0020017	Glen Burnie-Broadneck	2	Stevenson Road SCW	GW	WTP POE	EP	5/7/2014	1405278-001F	PFHxS	EPA 537	<		0.03	ppb	MD
MD0020017	Glen Burnie-Broadneck	2	Stevenson Road SCW	GW	WTP POE	EP	5/7/2014	1405278-001F	PFBS	EPA 537	<		0.09	ppb	MD
MD0020017	Glen Burnie-Broadneck	10	Baltimore - Hammonds Lane WBS	SW	EPTDS from E	EP	11/21/2013	1311815-001F	PFNA	EPA 537	<		0.02	ppb	MD
MD0020017	Glen Burnie-Broadneck	10	Baltimore - Hammonds Lane WBS	SW	EPTDS from E	EP	11/21/2013	1311815-001F	PFOS	EPA 537	<		0.04	ppb	MD
MD0020017	Glen Burnie-Broadneck	10	Baltimore - Hammonds Lane WBS	SW	EPTDS from E	EP	11/21/2013	1311815-001F	PFOA	EPA 537	<		0.02	ppb	MD
MD0020017	Glen Burnie-Broadneck	10	Baltimore - Hammonds Lane WBS	SW	EPTDS from E	EP	11/21/2013	1311815-001F	PFBS	EPA 537	<		0.09	ppb	MD
MD0020017	Glen Burnie-Broadneck	10	Baltimore - Hammonds Lane WBS	SW	EPTDS from E	EP	11/21/2013	1311815-001F	PFHpA	EPA 537	<		0.01	ppb	MD
MD0020017	Glen Burnie-Broadneck	10	Baltimore - Hammonds Lane WBS	SW	EPTDS from E	EP	11/21/2013	1311815-001F	PFHxS	EPA 537	<		0.03	ppb	MD
MD0020017	Glen Burnie-Broadneck	10	Baltimore - Hammonds Lane WBS	SW	EPTDS from E	EP	2/19/2014	1402962-001F	PFBS	EPA 537	<		0.09	ppb	MD
MD0020017	Glen Burnie-Broadneck	10	Baltimore - Hammonds Lane WBS	SW	EPTDS from E	EP	2/19/2014	1402962-001F	PFHpA	EPA 537	<		0.01	ppb	MD
MD0020017	Glen Burnie-Broadneck	10	Baltimore - Hammonds Lane WBS	SW	EPTDS from E	EP	2/19/2014	1402962-001F	PFHxS	EPA 537	<		0.03	ppb	MD
MD0020017	Glen Burnie-Broadneck	10	Baltimore - Hammonds Lane WBS	SW	EPTDS from E	EP	2/19/2014	1402962-001F	PFNA	EPA 537	<		0.02	ppb	MD
MD0020017	Glen Burnie-Broadneck	10	Baltimore - Hammonds Lane WBS	SW	EPTDS from E	EP	2/19/2014	1402962-001F	PFOS	EPA 537	<		0.04	ppb	MD
MD0020017	Glen Burnie-Broadneck	10	Baltimore - Hammonds Lane WBS	SW	EPTDS from E	EP	2/19/2014	1402962-001F	PFOA	EPA 537	<		0.02	ppb	MD
MD0020017	Glen Burnie-Broadneck	10	Baltimore - Hammonds Lane WBS	SW	EPTDS from E	EP	5/7/2014	1405279-001F	PFBS	EPA 537	<		0.09	ppb	MD
MD0020017	Glen Burnie-Broadneck	10	Baltimore - Hammonds Lane WBS	SW	EPTDS from E	EP	5/7/2014	1405279-001F	PFHxS	EPA 537	<		0.03	ppb	MD
MD0020017	Glen Burnie-Broadneck	10	Baltimore - Hammonds Lane WBS	SW	EPTDS from E	EP	5/7/2014	1405279-001F	PFNA	EPA 537	<		0.02	ppb	MD
MD0020017	Glen Burnie-Broadneck	10	Baltimore - Hammonds Lane WBS	SW	EPTDS from E	EP	5/7/2014	1405279-001F	PFHpA	EPA 537	<		0.01	ppb	MD
MD0020017	Glen Burnie-Broadneck	10	Baltimore - Hammonds Lane WBS	SW	EPTDS from E	EP	5/7/2014	1405279-001F	PFOA	EPA 537	<		0.02	ppb	MD
MD0020017	Glen Burnie-Broadneck	10	Baltimore - Hammonds Lane WBS	SW	EPTDS from E	EP	5/7/2014	1405279-001F	PFOS	EPA 537	<		0.04	ppb	MD
MD0020017	Glen Burnie-Broadneck	10	Baltimore - Hammonds Lane WBS	SW	EPTDS from E	EP	8/6/2014	1408212-001F	PFBS	EPA 537	<		0.09	ppb	MD
MD0020017	Glen Burnie-Broadneck	10	Baltimore - Hammonds Lane WBS	SW	EPTDS from E	EP	8/6/2014	1408212-001F	PFOA	EPA 537	<		0.02	ppb	MD
MD0020017	Glen Burnie-Broadneck	10	Baltimore - Hammonds Lane WBS	SW	EPTDS from E	EP	8/6/2014	1408212-001F	PFHpA	EPA 537	<		0.01	ppb	MD
MD0020017	Glen Burnie-Broadneck	10	Baltimore - Hammonds Lane WBS	SW	EPTDS from E	EP	8/6/2014	1408212-001F	PFOS	EPA 537	<		0.04	ppb	MD
MD0020017	Glen Burnie-Broadneck	10	Baltimore - Hammonds Lane WBS	SW	EPTDS from E	EP	8/6/2014	1408212-001F	PFNA	EPA 537	<		0.02	ppb	MD
MD0020017	Glen Burnie-Broadneck	10	Baltimore - Hammonds Lane WBS	SW	EPTDS from E	EP	8/6/2014	1408212-001F	PFHxS	EPA 537	<		0.03	ppb	MD
MD0020017	Glen Burnie-Broadneck	11	Severndale WTP	GW	WTP POE	EP	11/21/2013	1311817-001F	PFBS	EPA 537	<		0.09	ppb	MD
MD0020017	Glen Burnie-Broadneck	11	Severndale WTP	GW	WTP POE	EP	11/21/2013	1311817-001F	PFHpA	EPA 537	<		0.01	ppb	MD
MD0020017	Glen Burnie-Broadneck	11	Severndale WTP	GW	WTP POE	EP	11/21/2013	1311817-001F	PFHxS	EPA 537	<		0.03	ppb	MD
MD0020017	Glen Burnie-Broadneck	11	Severndale WTP	GW	WTP POE	EP	11/21/2013	1311817-001F	PFNA	EPA 537	<		0.02	ppb	MD
MD0020017	Glen Burnie-Broadneck	11	Severndale WTP	GW	WTP POE	EP	11/21/2013	1311817-001F	PFOA	EPA 537	<		0.02	ppb	MD
MD0020017	Glen Burnie-Broadneck	11	Severndale WTP	GW	WTP POE	EP	11/21/2013	1311817-001F	PFOS	EPA 537	<		0.04	ppb	MD
MD0020017	Glen Burnie-Broadneck	11	Severndale WTP	GW	WTP POE	EP	5/7/2014	1405277-001F	PFHpA	EPA 537	<		0.01	ppb	MD
MD0020017	Glen Burnie-Broadneck	11	Severndale WTP	GW	WTP POE	EP	5/7/2014	1405277-001F	PFOA	EPA 537	<		0.02	ppb	MD
MD0020017	Glen Burnie-Broadneck	11	Severndale WTP	GW	WTP POE	EP	5/7/2014	1405277-001F	PFOS	EPA 537	<		0.04	ppb	MD
MD0020017	Glen Burnie-Broadneck	11	Severndale WTP	GW	WTP POE	EP	5/7/2014	1405277-001F	PFHxS	EPA 537	<		0.03	ppb	MD
MD0020017	Glen Burnie-Broadneck	11	Severndale WTP	GW	WTP POE	EP	5/7/2014	1405277-001F	PFBS	EPA 537	<		0.09	ppb	MD
MD0020017	Glen Burnie-Broadneck	11	Severndale WTP	GW	WTP POE	EP	5/7/2014	1405277-001F	PFNA	EPA 537	<		0.02	ppb	MD
MD0020017	Glen Burnie-Broadneck	16	Dorsey Road WTP	GW	WTP POE	EP	11/21/2013	1311813-001F	PFBS	EPA 537	<		0.09	ppb	MD
MD0020017	Glen Burnie-Broadneck	16	Dorsey Road WTP	GW	WTP POE	EP	11/21/2013	1311813-001F	PFHxS	EPA 537	<		0.03	ppb	MD
MD0020017	Glen Burnie-Broadneck	16	Dorsey Road WTP	GW	WTP POE	EP	11/21/2013	1311813-001F	PFNA	EPA 537	<		0.02	ppb	MD
MD0020017	Glen Burnie-Broadneck	16	Dorsey Road WTP	GW	WTP POE	EP	11/21/2013	1311813-001F	PFOS	EPA 537	<		0.04	ppb	MD
MD0020017	Glen Burnie-Broadneck	16	Dorsey Road WTP	GW	WTP POE	EP	11/21/2013	1311813-001F	PFHpA	EPA 537	<		0.01	ppb	MD
MD0020017	Glen Burnie-Broadneck	16	Dorsey Road WTP	GW	WTP POE	EP	11/21/2013	1311813-001F	PFOA	EPA 537	<		0.02	ppb	MD
MD0020017	Glen Burnie-Broadneck	16	Dorsey Road WTP	GW	WTP POE	EP	5/7/2014	1405280-001F	PFHpA	EPA 537	<		0.01	ppb	MD
MD0020017	Glen Burnie-Broadneck	16	Dorsey Road WTP	GW	WTP POE	EP	5/7/2014	1405280-001F	PFHxS	EPA 537	<		0.03	ppb	MD
MD0020017	Glen Burnie-Broadneck	16	Dorsey Road WTP	GW	WTP POE	EP	5/7/2014	1405280-001F	PFBS	EPA 537	<		0.09	ppb	MD
MD0020017	Glen Burnie-Broadneck	16	Dorsey Road WTP	GW	WTP POE	EP	5/7/2014	1405280-001F	PFOA	EPA 537	<		0.02	ppb	MD
MD0020017	Glen Burnie-Broadneck	16	Dorsey Road WTP	GW	WTP POE	EP	5/7/2014	1405280-001F	PFOS	EPA 537	<		0.04	ppb	MD
MD0020017	Glen Burnie-Broadneck	16	Dorsey Road WTP	GW	WTP POE	EP	5/7/2014	1405280-001F	PFNA	EPA 537	<		0.02	ppb	MD
MD0020017	Glen Burnie-Broadneck	17	Arnold WTP	GW	WTP POE	EP	11/21/2013	1311814-001F	PFOA	EPA 537	<		0.02	ppb	MD
MD0020017	Glen Burnie-Broadneck	17	Arnold WTP	GW	WTP POE	EP	11/21/2013	1311814-001F	PFHpA	EPA 537	<		0.01	ppb	MD
MD0020017	Glen Burnie-Broadneck	17	Arnold WTP	GW	WTP POE	EP	11/21/2013	1311814-001F	PFBS	EPA 537	<		0.09	ppb	MD
MD0020017	Glen Burnie-Broadneck	17	Arnold WTP	GW	WTP POE	EP	11/21/2013	1311814-001F	PFHxS	EPA 537	<		0.03	ppb	MD
MD0020017	Glen Burnie-Broadneck	17	Arnold WTP	GW	WTP POE	EP	11/21/2013	1311814-001F	PFNA	EPA 537	<		0.02	ppb	MD
MD0020017	Glen Burnie-Broadneck	17	Arnold WTP	GW	WTP POE	EP	11/21/2013	1311814-001F	PFOS	EPA 537	<		0.04	ppb	MD
MD0020017	Glen Burnie-Broadneck	17	Arnold WTP	GW	WTP POE	EP	5/7/2014	1405281-001F	PFBS	EPA 537	<		0.09	ppb	MD
MD0020017	Glen Burnie-Broadneck	17	Arnold WTP	GW	WTP POE	EP	5/7/2014	1405281-001F	PFHpA	EPA 537	<		0.01	ppb	MD
MD0020017	Glen Burnie-Broadneck	17	Arnold WTP	GW	WTP POE	EP	5/7/2014	1405281-001F	PFHxS	EPA 537	<		0.03	ppb	MD
MD0020017	Glen Burnie-Broadneck	17	Arnold WTP	GW	WTP POE	EP	5/7/2014	1405281-001F	PFNA	EPA 537	<		0.02	ppb	MD
MD0020017	Glen Burnie-Broadneck	17	Arnold WTP	GW	WTP POE	EP	5/7/2014	1405281-001F	PFOS	EPA 537	<		0.04	ppb	MD
MD0020017	Glen Burnie-Broadneck	17	Arnold WTP	GW	WTP POE	EP	5/7/2014	1405281-001F	PFOA	EPA 537	<		0.02	ppb	MD
MD0020042	US Naval Academy	1	USNA Filter Plant	GW	WTP POE	EP	5/19/2015	113233P	PFBS	EPA 537	<		0.09	ppb	MD
MD0020042	US Naval Academy	1	USNA Filter Plant	GW	WTP POE	EP	5/19/2015	113233P	PFHpA	EPA 537	<		0.01	ppb	MD
MD0020042	US Naval Academy	1	USNA Filter Plant	GW	WTP POE	EP	5/19/2015	113233P	PFHxS	EPA 537	<		0.03	ppb	MD
MD0020042	US Naval Academy	1	USNA Filter Plant	GW	WTP POE	EP	5/19/2015	113233P	PFNA	EPA 537	<		0.02	ppb	MD
MD0020042	US Naval Academy	1	USNA Filter Plant	GW	WTP POE	EP	5/19/2015	113233P	PFOS	EPA 537	<		0.04	ppb	MD

MD0020042	US Naval Academy	1	USNA Filter Plant	GW	WTP POE	EP	5/19/2015	113233P	PFOA	EPA 537	<		0.02	ppb	MD
MD0020042	US Naval Academy	1	USNA Filter Plant	GW	WTP POE	EP	11/16/2015	116024Q	PFBS	EPA 537	<		0.09	ppb	MD
MD0020042	US Naval Academy	1	USNA Filter Plant	GW	WTP POE	EP	11/16/2015	116024Q	PFHpA	EPA 537	<		0.01	ppb	MD
MD0020042	US Naval Academy	1	USNA Filter Plant	GW	WTP POE	EP	11/16/2015	116024Q	PFHxS	EPA 537	<		0.03	ppb	MD
MD0020042	US Naval Academy	1	USNA Filter Plant	GW	WTP POE	EP	11/16/2015	116024Q	PFNA	EPA 537	<		0.02	ppb	MD
MD0020042	US Naval Academy	1	USNA Filter Plant	GW	WTP POE	EP	11/16/2015	116024Q	PFOS	EPA 537	<		0.04	ppb	MD
MD0020042	US Naval Academy	1	USNA Filter Plant	GW	WTP POE	EP	11/16/2015	116024Q	PFOA	EPA 537	<		0.02	ppb	MD
MD0040018	Chesapeake Heights (Bayside Forest)	1	Chesapeake Heights-Hill	GW	WTP POE	EP	3/11/2013	100603P	PFBS	EPA 537	<		0.09	ppb	MD
MD0040018	Chesapeake Heights (Bayside Forest)	1	Chesapeake Heights-Hill	GW	WTP POE	EP	3/11/2013	100603P	PFHpA	EPA 537	<		0.01	ppb	MD
MD0040018	Chesapeake Heights (Bayside Forest)	1	Chesapeake Heights-Hill	GW	WTP POE	EP	3/11/2013	100603P	PFHxS	EPA 537	<		0.03	ppb	MD
MD0040018	Chesapeake Heights (Bayside Forest)	1	Chesapeake Heights-Hill	GW	WTP POE	EP	3/11/2013	100603P	PFNA	EPA 537	<		0.02	ppb	MD
MD0040018	Chesapeake Heights (Bayside Forest)	1	Chesapeake Heights-Hill	GW	WTP POE	EP	3/11/2013	100603P	PFOS	EPA 537	<		0.04	ppb	MD
MD0040018	Chesapeake Heights (Bayside Forest)	1	Chesapeake Heights-Hill	GW	WTP POE	EP	3/11/2013	100603P	PFOA	EPA 537	<		0.02	ppb	MD
MD0040018	Chesapeake Heights (Bayside Forest)	1	Chesapeake Heights-Hill	GW	WTP POE	EP	9/16/2013	102127P	PFBS	EPA 537	<		0.09	ppb	MD
MD0040018	Chesapeake Heights (Bayside Forest)	1	Chesapeake Heights-Hill	GW	WTP POE	EP	9/16/2013	102127P	PFHpA	EPA 537	<		0.01	ppb	MD
MD0040018	Chesapeake Heights (Bayside Forest)	1	Chesapeake Heights-Hill	GW	WTP POE	EP	9/16/2013	102127P	PFHxS	EPA 537	<		0.03	ppb	MD
MD0040018	Chesapeake Heights (Bayside Forest)	1	Chesapeake Heights-Hill	GW	WTP POE	EP	9/16/2013	102127P	PFNA	EPA 537	<		0.02	ppb	MD
MD0040018	Chesapeake Heights (Bayside Forest)	1	Chesapeake Heights-Hill	GW	WTP POE	EP	9/16/2013	102127P	PFOS	EPA 537	<		0.04	ppb	MD
MD0040018	Chesapeake Heights (Bayside Forest)	1	Chesapeake Heights-Hill	GW	WTP POE	EP	9/16/2013	102127P	PFOA	EPA 537	<		0.02	ppb	MD
MD0060002	Freedom District	1	Filter Plant - Liberty Reservoir	SW	WTP POE	EP	10/15/2014	K1411701-003	PFHpA	EPA 537	<		0.01	ppb	MD
MD0060002	Freedom District	1	Filter Plant - Liberty Reservoir	SW	WTP POE	EP	10/15/2014	K1411701-003	PFOS	EPA 537	<		0.04	ppb	MD
MD0060002	Freedom District	1	Filter Plant - Liberty Reservoir	SW	WTP POE	EP	10/15/2014	K1411701-003	PFNA	EPA 537	<		0.02	ppb	MD
MD0060002	Freedom District	1	Filter Plant - Liberty Reservoir	SW	WTP POE	EP	10/15/2014	K1411701-003	PFHxS	EPA 537	<		0.03	ppb	MD
MD0060002	Freedom District	1	Filter Plant - Liberty Reservoir	SW	WTP POE	EP	10/15/2014	K1411701-003	PFBS	EPA 537	<		0.09	ppb	MD
MD0060002	Freedom District	1	Filter Plant - Liberty Reservoir	SW	WTP POE	EP	10/15/2014	K1411701-003	PFOA	EPA 537	<		0.02	ppb	MD
MD0060002	Freedom District	1	Filter Plant - Liberty Reservoir	SW	WTP POE	EP	1/19/2015	K1500569-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0060002	Freedom District	1	Filter Plant - Liberty Reservoir	SW	WTP POE	EP	1/19/2015	K1500569-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0060002	Freedom District	1	Filter Plant - Liberty Reservoir	SW	WTP POE	EP	1/19/2015	K1500569-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0060002	Freedom District	1	Filter Plant - Liberty Reservoir	SW	WTP POE	EP	1/19/2015	K1500569-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0060002	Freedom District	1	Filter Plant - Liberty Reservoir	SW	WTP POE	EP	1/19/2015	K1500569-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0060002	Freedom District	1	Filter Plant - Liberty Reservoir	SW	WTP POE	EP	1/19/2015	K1500569-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0060002	Freedom District	1	Filter Plant - Liberty Reservoir	SW	WTP POE	EP	4/6/2015	K1503592-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0060002	Freedom District	1	Filter Plant - Liberty Reservoir	SW	WTP POE	EP	4/6/2015	K1503592-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0060002	Freedom District	1	Filter Plant - Liberty Reservoir	SW	WTP POE	EP	4/6/2015	K1503592-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0060002	Freedom District	1	Filter Plant - Liberty Reservoir	SW	WTP POE	EP	4/6/2015	K1503592-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0060002	Freedom District	1	Filter Plant - Liberty Reservoir	SW	WTP POE	EP	4/6/2015	K1503592-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0060002	Freedom District	1	Filter Plant - Liberty Reservoir	SW	WTP POE	EP	4/6/2015	K1503592-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0060002	Freedom District	1	Filter Plant - Liberty Reservoir	SW	WTP POE	EP	7/13/2015	K1507663-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0060002	Freedom District	1	Filter Plant - Liberty Reservoir	SW	WTP POE	EP	7/13/2015	K1507663-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0060002	Freedom District	1	Filter Plant - Liberty Reservoir	SW	WTP POE	EP	7/13/2015	K1507663-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0060002	Freedom District	1	Filter Plant - Liberty Reservoir	SW	WTP POE	EP	7/13/2015	K1507663-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0060002	Freedom District	1	Filter Plant - Liberty Reservoir	SW	WTP POE	EP	7/13/2015	K1507663-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0060002	Freedom District	1	Filter Plant - Liberty Reservoir	SW	WTP POE	EP	7/13/2015	K1507663-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0060002	Freedom District	2	Fairhaven WTP (Well 22B)	GW	WTP POE	EP	10/15/2014	K1411701-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0060002	Freedom District	2	Fairhaven WTP (Well 22B)	GW	WTP POE	EP	10/15/2014	K1411701-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0060002	Freedom District	2	Fairhaven WTP (Well 22B)	GW	WTP POE	EP	10/15/2014	K1411701-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0060002	Freedom District	2	Fairhaven WTP (Well 22B)	GW	WTP POE	EP	10/15/2014	K1411701-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0060002	Freedom District	2	Fairhaven WTP (Well 22B)	GW	WTP POE	EP	10/15/2014	K1411701-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0060002	Freedom District	2	Fairhaven WTP (Well 22B)	GW	WTP POE	EP	10/15/2014	K1411701-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0060002	Freedom District	2	Fairhaven WTP (Well 22B)	GW	WTP POE	EP	4/20/2015	K1504298-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0060002	Freedom District	2	Fairhaven WTP (Well 22B)	GW	WTP POE	EP	4/20/2015	K1504298-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0060002	Freedom District	2	Fairhaven WTP (Well 22B)	GW	WTP POE	EP	4/20/2015	K1504298-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0060002	Freedom District	2	Fairhaven WTP (Well 22B)	GW	WTP POE	EP	4/20/2015	K1504298-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0060002	Freedom District	2	Fairhaven WTP (Well 22B)	GW	WTP POE	EP	4/20/2015	K1504298-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0060002	Freedom District	2	Fairhaven WTP (Well 22B)	GW	WTP POE	EP	4/20/2015	K1504298-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0060015	City of Westminster	1	Cranberry WTP	SW	WTP POE	EP	11/14/2013	201311150239AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0060015	City of Westminster	1	Cranberry WTP	SW	WTP POE	EP	11/14/2013	201311150239AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0060015	City of Westminster	1	Cranberry WTP	SW	WTP POE	EP	11/14/2013	201311150239AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0060015	City of Westminster	1	Cranberry WTP	SW	WTP POE	EP	11/14/2013	201311150239AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0060015	City of Westminster	1	Cranberry WTP	SW	WTP POE	EP	11/14/2013	201311150239AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0060015	City of Westminster	1	Cranberry WTP	SW	WTP POE	EP	11/14/2013	201311150239AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0060015	City of Westminster	1	Cranberry WTP	SW	WTP POE	EP	2/11/2014	201402120481AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0060015	City of Westminster	1	Cranberry WTP	SW	WTP POE	EP	2/11/2014	201402120481AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0060015	City of Westminster	1	Cranberry WTP	SW	WTP POE	EP	2/11/2014	201402120481AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0060015	City of Westminster	1	Cranberry WTP	SW	WTP POE	EP	2/11/2014	201402120481AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0060015	City of Westminster	1	Cranberry WTP	SW	WTP POE	EP	2/11/2014	201402120481AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0060015	City of Westminster	1	Cranberry WTP	SW	WTP POE	EP	2/11/2014	201402120481AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0060015	City of Westminster	1	Cranberry WTP	SW	WTP POE	EP	5/13/2014	201405150091AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0060015	City of Westminster	1	Cranberry WTP	SW	WTP POE	EP	5/13/2014	201405150091AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0060015	City of Westminster	1	Cranberry WTP	SW	WTP POE	EP	5/13/2014	201405150091AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0060015	City of Westminster	1	Cranberry WTP	SW	WTP POE	EP	5/13/2014	201405150091AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0060015	City of Westminster	1	Cranberry WTP	SW	WTP POE	EP	5/13/2014	201405150091AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0060015	City of Westminster	1	Cranberry WTP	SW	WTP POE	EP	5/13/2014	201405150091AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0060015	City of Westminster	1	Cranberry WTP	SW	WTP POE	EP	8/7/2014	201408080182AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0060015	City of Westminster	1	Cranberry WTP	SW	WTP POE	EP	8/7/2014	201408080182AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0060015	City of Westminster	1	Cranberry WTP	SW	WTP POE	EP	8/7/2014	201408080182AM	PFNA	EPA 537	<		0.02	ppb	MD

MD0060015	City of Westminster	1	Cranberry WTP	SW	WTP POE	EP	8/7/2014	201408080182AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0060015	City of Westminster	1	Cranberry WTP	SW	WTP POE	EP	8/7/2014	201408080182AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0060015	City of Westminster	1	Cranberry WTP	SW	WTP POE	EP	8/7/2014	201408080182AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0060015	City of Westminster	3	Airport Well 4 WTP	GW	WTP POE	EP	11/14/2013	201311150376AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0060015	City of Westminster	3	Airport Well 4 WTP	GW	WTP POE	EP	11/14/2013	201311150376AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0060015	City of Westminster	3	Airport Well 4 WTP	GW	WTP POE	EP	11/14/2013	201311150376AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0060015	City of Westminster	3	Airport Well 4 WTP	GW	WTP POE	EP	11/14/2013	201311150376AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0060015	City of Westminster	3	Airport Well 4 WTP	GW	WTP POE	EP	11/14/2013	201311150376AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0060015	City of Westminster	3	Airport Well 4 WTP	GW	WTP POE	EP	11/14/2013	201311150376AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0060015	City of Westminster	3	Airport Well 4 WTP	GW	WTP POE	EP	5/13/2014	201405140726AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0060015	City of Westminster	3	Airport Well 4 WTP	GW	WTP POE	EP	5/13/2014	201405140726AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0060015	City of Westminster	3	Airport Well 4 WTP	GW	WTP POE	EP	5/13/2014	201405140726AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0060015	City of Westminster	3	Airport Well 4 WTP	GW	WTP POE	EP	5/13/2014	201405140726AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0060015	City of Westminster	3	Airport Well 4 WTP	GW	WTP POE	EP	5/13/2014	201405140726AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0060015	City of Westminster	3	Airport Well 4 WTP	GW	WTP POE	EP	5/13/2014	201405140726AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0060015	City of Westminster	5	Kriders Church Well 5 WTP	GU	WTP POE	EP	11/14/2013	201311150225AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0060015	City of Westminster	5	Kriders Church Well 5 WTP	GU	WTP POE	EP	11/14/2013	201311150225AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0060015	City of Westminster	5	Kriders Church Well 5 WTP	GU	WTP POE	EP	11/14/2013	201311150225AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0060015	City of Westminster	5	Kriders Church Well 5 WTP	GU	WTP POE	EP	11/14/2013	201311150225AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0060015	City of Westminster	5	Kriders Church Well 5 WTP	GU	WTP POE	EP	11/14/2013	201311150225AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0060015	City of Westminster	5	Kriders Church Well 5 WTP	GU	WTP POE	EP	11/14/2013	201311150225AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0060015	City of Westminster	5	Kriders Church Well 5 WTP	GU	WTP POE	EP	2/11/2014	201402120479AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0060015	City of Westminster	5	Kriders Church Well 5 WTP	GU	WTP POE	EP	2/11/2014	201402120479AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0060015	City of Westminster	5	Kriders Church Well 5 WTP	GU	WTP POE	EP	2/11/2014	201402120479AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0060015	City of Westminster	5	Kriders Church Well 5 WTP	GU	WTP POE	EP	2/11/2014	201402120479AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0060015	City of Westminster	5	Kriders Church Well 5 WTP	GU	WTP POE	EP	2/11/2014	201402120479AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0060015	City of Westminster	5	Kriders Church Well 5 WTP	GU	WTP POE	EP	2/11/2014	201402120479AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0060015	City of Westminster	5	Kriders Church Well 5 WTP	GU	WTP POE	EP	5/13/2014	201405150093AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0060015	City of Westminster	5	Kriders Church Well 5 WTP	GU	WTP POE	EP	5/13/2014	201405150093AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0060015	City of Westminster	5	Kriders Church Well 5 WTP	GU	WTP POE	EP	5/13/2014	201405150093AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0060015	City of Westminster	5	Kriders Church Well 5 WTP	GU	WTP POE	EP	5/13/2014	201405150093AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0060015	City of Westminster	5	Kriders Church Well 5 WTP	GU	WTP POE	EP	5/13/2014	201405150093AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0060015	City of Westminster	5	Kriders Church Well 5 WTP	GU	WTP POE	EP	5/13/2014	201405150093AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0060015	City of Westminster	5	Kriders Church Well 5 WTP	GU	WTP POE	EP	8/7/2014	201408080184AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0060015	City of Westminster	5	Kriders Church Well 5 WTP	GU	WTP POE	EP	8/7/2014	201408080184AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0060015	City of Westminster	5	Kriders Church Well 5 WTP	GU	WTP POE	EP	8/7/2014	201408080184AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0060015	City of Westminster	5	Kriders Church Well 5 WTP	GU	WTP POE	EP	8/7/2014	201408080184AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0060015	City of Westminster	5	Kriders Church Well 5 WTP	GU	WTP POE	EP	8/7/2014	201408080184AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0060015	City of Westminster	5	Kriders Church Well 5 WTP	GU	WTP POE	EP	8/7/2014	201408080184AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0070011	Town of Elkton	1	Big Elk Creek Filter Plant	SW	WTP POE	EP	7/29/2013	A990798	PFHpA	EPA 537	<		0.01	ppb	MD
MD0070011	Town of Elkton	1	Big Elk Creek Filter Plant	SW	WTP POE	EP	7/29/2013	A990798	PFBS	EPA 537	<		0.09	ppb	MD
MD0070011	Town of Elkton	1	Big Elk Creek Filter Plant	SW	WTP POE	EP	7/29/2013	A990798	PFHxS	EPA 537	<		0.03	ppb	MD
MD0070011	Town of Elkton	1	Big Elk Creek Filter Plant	SW	WTP POE	EP	7/29/2013	A990798	PFNA	EPA 537	<		0.02	ppb	MD
MD0070011	Town of Elkton	1	Big Elk Creek Filter Plant	SW	WTP POE	EP	7/29/2013	A990798	PFOA	EPA 537	<		0.02	ppb	MD
MD0070011	Town of Elkton	1	Big Elk Creek Filter Plant	SW	WTP POE	EP	7/29/2013	A990798	PFOS	EPA 537	<		0.04	ppb	MD
MD0070011	Town of Elkton	1	Big Elk Creek Filter Plant	SW	WTP POE	EP	9/25/2013	K1310501-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0070011	Town of Elkton	1	Big Elk Creek Filter Plant	SW	WTP POE	EP	9/25/2013	K1310501-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0070011	Town of Elkton	1	Big Elk Creek Filter Plant	SW	WTP POE	EP	9/25/2013	K1310501-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0070011	Town of Elkton	1	Big Elk Creek Filter Plant	SW	WTP POE	EP	9/25/2013	K1310501-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0070011	Town of Elkton	1	Big Elk Creek Filter Plant	SW	WTP POE	EP	9/25/2013	K1310501-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0070011	Town of Elkton	1	Big Elk Creek Filter Plant	SW	WTP POE	EP	9/25/2013	K1310501-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0070011	Town of Elkton	1	Big Elk Creek Filter Plant	SW	WTP POE	EP	12/19/2013	K1313955-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0070011	Town of Elkton	1	Big Elk Creek Filter Plant	SW	WTP POE	EP	12/19/2013	K1313955-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0070011	Town of Elkton	1	Big Elk Creek Filter Plant	SW	WTP POE	EP	12/19/2013	K1313955-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0070011	Town of Elkton	1	Big Elk Creek Filter Plant	SW	WTP POE	EP	12/19/2013	K1313955-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0070011	Town of Elkton	1	Big Elk Creek Filter Plant	SW	WTP POE	EP	12/19/2013	K1313955-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0070011	Town of Elkton	1	Big Elk Creek Filter Plant	SW	WTP POE	EP	12/19/2013	K1313955-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0070011	Town of Elkton	1	Big Elk Creek Filter Plant	SW	WTP POE	EP	3/24/2014	K1403154-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0070011	Town of Elkton	1	Big Elk Creek Filter Plant	SW	WTP POE	EP	3/24/2014	K1403154-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0070011	Town of Elkton	1	Big Elk Creek Filter Plant	SW	WTP POE	EP	3/24/2014	K1403154-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0070011	Town of Elkton	1	Big Elk Creek Filter Plant	SW	WTP POE	EP	3/24/2014	K1403154-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0070011	Town of Elkton	1	Big Elk Creek Filter Plant	SW	WTP POE	EP	3/24/2014	K1403154-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0070011	Town of Elkton	1	Big Elk Creek Filter Plant	SW	WTP POE	EP	3/24/2014	K1403154-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0070011	Town of Elkton	2	Well 3 WTP	GW	WTP POE	EP	7/15/2013	A989792	PFHpA	EPA 537	<		0.01	ppb	MD
MD0070011	Town of Elkton	2	Well 3 WTP	GW	WTP POE	EP	7/15/2013	A989792	PFHxS	EPA 537	<		0.03	ppb	MD
MD0070011	Town of Elkton	2	Well 3 WTP	GW	WTP POE	EP	7/15/2013	A989792	PFBS	EPA 537	<		0.09	ppb	MD
MD0070011	Town of Elkton	2	Well 3 WTP	GW	WTP POE	EP	7/15/2013	A989792	PFOA	EPA 537	<		0.02	ppb	MD
MD0070011	Town of Elkton	2	Well 3 WTP	GW	WTP POE	EP	7/15/2013	A989792	PFNA	EPA 537	<		0.02	ppb	MD
MD0070011	Town of Elkton	2	Well 3 WTP	GW	WTP POE	EP	7/15/2013	A989792	PFOS	EPA 537	<		0.04	ppb	MD
MD0070011	Town of Elkton	2	Well 3 WTP	GW	WTP POE	EP	12/19/2013	K1313960-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0070011	Town of Elkton	2	Well 3 WTP	GW	WTP POE	EP	12/19/2013	K1313960-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0070011	Town of Elkton	2	Well 3 WTP	GW	WTP POE	EP	12/19/2013	K1313960-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0070011	Town of Elkton	2	Well 3 WTP	GW	WTP POE	EP	12/19/2013	K1313960-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0070011	Town of Elkton	2	Well 3 WTP	GW	WTP POE	EP	12/19/2013	K1313960-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0070011	Town of Elkton	2	Well 3 WTP	GW	WTP POE	EP	12/19/2013	K1313960-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0070011	Town of Elkton	3	Well 1	GW	WTP POE	EP	7/15/2013	A989790	PFBS	EPA 537	<		0.09	ppb	MD

MD0070011	Town of Elkton	3	Well 1	GW	WTP POE	EP	7/15/2013	A989790	PFOS	EPA 537	<		0.04	ppb	MD
MD0070011	Town of Elkton	3	Well 1	GW	WTP POE	EP	7/15/2013	A989790	PFOA	EPA 537	<		0.02	ppb	MD
MD0070011	Town of Elkton	3	Well 1	GW	WTP POE	EP	7/15/2013	A989790	PFHpA	EPA 537	<		0.01	ppb	MD
MD0070011	Town of Elkton	3	Well 1	GW	WTP POE	EP	7/15/2013	A989790	PFHxS	EPA 537	<		0.03	ppb	MD
MD0070011	Town of Elkton	3	Well 1	GW	WTP POE	EP	7/15/2013	A989790	PFNA	EPA 537	<		0.02	ppb	MD
MD0070011	Town of Elkton	3	Well 1	GW	WTP POE	EP	12/19/2013	K1313959-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0070011	Town of Elkton	3	Well 1	GW	WTP POE	EP	12/19/2013	K1313959-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0070011	Town of Elkton	3	Well 1	GW	WTP POE	EP	12/19/2013	K1313959-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0070011	Town of Elkton	3	Well 1	GW	WTP POE	EP	12/19/2013	K1313959-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0070011	Town of Elkton	3	Well 1	GW	WTP POE	EP	12/19/2013	K1313959-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0070011	Town of Elkton	3	Well 1	GW	WTP POE	EP	12/19/2013	K1313959-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0080049	Waldorf	3	White Oak WTP	GW	WTP POE	EP	2/25/2013	1302713-001C	PFOS	EPA 537	<		0.04	ppb	MD
MD0080049	Waldorf	3	White Oak WTP	GW	WTP POE	EP	2/25/2013	1302713-001C	PFBS	EPA 537	<		0.09	ppb	MD
MD0080049	Waldorf	3	White Oak WTP	GW	WTP POE	EP	2/25/2013	1302713-001C	PFHxS	EPA 537	<		0.03	ppb	MD
MD0080049	Waldorf	3	White Oak WTP	GW	WTP POE	EP	2/25/2013	1302713-001C	PFOA	EPA 537	<		0.02	ppb	MD
MD0080049	Waldorf	3	White Oak WTP	GW	WTP POE	EP	2/25/2013	1302713-001C	PFHpA	EPA 537	<		0.01	ppb	MD
MD0080049	Waldorf	3	White Oak WTP	GW	WTP POE	EP	2/25/2013	1302713-001C	PFNA	EPA 537	<		0.02	ppb	MD
MD0080049	Waldorf	3	White Oak WTP	GW	WTP POE	EP	7/9/2013	1307258-001E	PFHxS	EPA 537	<		0.03	ppb	MD
MD0080049	Waldorf	3	White Oak WTP	GW	WTP POE	EP	7/9/2013	1307258-001E	PFNA	EPA 537	<		0.02	ppb	MD
MD0080049	Waldorf	3	White Oak WTP	GW	WTP POE	EP	7/9/2013	1307258-001E	PFBS	EPA 537	<		0.09	ppb	MD
MD0080049	Waldorf	3	White Oak WTP	GW	WTP POE	EP	7/9/2013	1307258-001E	PFOS	EPA 537	<		0.04	ppb	MD
MD0080049	Waldorf	3	White Oak WTP	GW	WTP POE	EP	7/9/2013	1307258-001E	PFOA	EPA 537	<		0.02	ppb	MD
MD0080049	Waldorf	3	White Oak WTP	GW	WTP POE	EP	7/9/2013	1307258-001E	PFHpA	EPA 537	<		0.01	ppb	MD
MD0080049	Waldorf	13	WSSC Booster (16" Main)	SW	EPTDS from V	EP	2/25/2013	1302721-001A	PFHpA	EPA 537	<		0.01	ppb	MD
MD0080049	Waldorf	13	WSSC Booster (16" Main)	SW	EPTDS from V	EP	2/25/2013	1302721-001A	PFNA	EPA 537	<		0.02	ppb	MD
MD0080049	Waldorf	13	WSSC Booster (16" Main)	SW	EPTDS from V	EP	2/25/2013	1302721-001A	PFOS	EPA 537	<		0.04	ppb	MD
MD0080049	Waldorf	13	WSSC Booster (16" Main)	SW	EPTDS from V	EP	2/25/2013	1302721-001A	PFBS	EPA 537	<		0.09	ppb	MD
MD0080049	Waldorf	13	WSSC Booster (16" Main)	SW	EPTDS from V	EP	2/25/2013	1302721-001A	PFHxS	EPA 537	<		0.03	ppb	MD
MD0080049	Waldorf	13	WSSC Booster (16" Main)	SW	EPTDS from V	EP	2/25/2013	1302721-001A	PFOA	EPA 537	<		0.02	ppb	MD
MD0080049	Waldorf	13	WSSC Booster (16" Main)	SW	EPTDS from V	EP	4/15/2013	1304494-001E	PFBS	EPA 537	<		0.09	ppb	MD
MD0080049	Waldorf	13	WSSC Booster (16" Main)	SW	EPTDS from V	EP	4/15/2013	1304494-001E	PFHpA	EPA 537	<		0.01	ppb	MD
MD0080049	Waldorf	13	WSSC Booster (16" Main)	SW	EPTDS from V	EP	4/15/2013	1304494-001E	PFNA	EPA 537	<		0.02	ppb	MD
MD0080049	Waldorf	13	WSSC Booster (16" Main)	SW	EPTDS from V	EP	4/15/2013	1304494-001E	PFOS	EPA 537	<		0.04	ppb	MD
MD0080049	Waldorf	13	WSSC Booster (16" Main)	SW	EPTDS from V	EP	4/15/2013	1304494-001E	PFHxS	EPA 537	<		0.03	ppb	MD
MD0080049	Waldorf	13	WSSC Booster (16" Main)	SW	EPTDS from V	EP	4/15/2013	1304494-001E	PFOA	EPA 537	<		0.02	ppb	MD
MD0080049	Waldorf	13	WSSC Booster (16" Main)	SW	EPTDS from V	EP	8/5/2013	1308227-001E	PFBS	EPA 537	<		0.09	ppb	MD
MD0080049	Waldorf	13	WSSC Booster (16" Main)	SW	EPTDS from V	EP	8/5/2013	1308227-001E	PFHpA	EPA 537	<		0.01	ppb	MD
MD0080049	Waldorf	13	WSSC Booster (16" Main)	SW	EPTDS from V	EP	8/5/2013	1308227-001E	PFNA	EPA 537	<		0.02	ppb	MD
MD0080049	Waldorf	13	WSSC Booster (16" Main)	SW	EPTDS from V	EP	8/5/2013	1308227-001E	PFOA	EPA 537	<		0.02	ppb	MD
MD0080049	Waldorf	13	WSSC Booster (16" Main)	SW	EPTDS from V	EP	8/5/2013	1308227-001E	PFHxS	EPA 537	<		0.03	ppb	MD
MD0080049	Waldorf	13	WSSC Booster (16" Main)	SW	EPTDS from V	EP	8/5/2013	1308227-001E	PFOS	EPA 537	<		0.04	ppb	MD
MD0080049	Waldorf	13	WSSC Booster (16" Main)	SW	EPTDS from V	EP	10/31/2013	1310A30-001E	PFHxS	EPA 537	<		0.03	ppb	MD
MD0080049	Waldorf	13	WSSC Booster (16" Main)	SW	EPTDS from V	EP	10/31/2013	1310A30-001E	PFNA	EPA 537	<		0.02	ppb	MD
MD0080049	Waldorf	13	WSSC Booster (16" Main)	SW	EPTDS from V	EP	10/31/2013	1310A30-001E	PFOS	EPA 537	<		0.04	ppb	MD
MD0080049	Waldorf	13	WSSC Booster (16" Main)	SW	EPTDS from V	EP	10/31/2013	1310A30-001E	PFOA	EPA 537	<		0.02	ppb	MD
MD0080049	Waldorf	13	WSSC Booster (16" Main)	SW	EPTDS from V	EP	10/31/2013	1310A30-001E	PFBS	EPA 537	<		0.09	ppb	MD
MD0080049	Waldorf	13	WSSC Booster (16" Main)	SW	EPTDS from V	EP	10/31/2013	1310A30-001E	PFHpA	EPA 537	<		0.01	ppb	MD
MD0090002	Cambridge	1	Stone Boundary WTP	GW	WTP POE	EP	1/27/2014	35124103001AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0090002	Cambridge	1	Stone Boundary WTP	GW	WTP POE	EP	1/27/2014	35124103001AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0090002	Cambridge	1	Stone Boundary WTP	GW	WTP POE	EP	1/27/2014	35124103001AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0090002	Cambridge	1	Stone Boundary WTP	GW	WTP POE	EP	1/27/2014	35124103001AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0090002	Cambridge	1	Stone Boundary WTP	GW	WTP POE	EP	1/27/2014	35124103001AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0090002	Cambridge	1	Stone Boundary WTP	GW	WTP POE	EP	1/27/2014	35124103001AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0090002	Cambridge	1	Stone Boundary WTP	GW	WTP POE	EP	7/8/2014	35145286001AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0090002	Cambridge	1	Stone Boundary WTP	GW	WTP POE	EP	7/8/2014	35145286001AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0090002	Cambridge	1	Stone Boundary WTP	GW	WTP POE	EP	7/8/2014	35145286001AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0090002	Cambridge	1	Stone Boundary WTP	GW	WTP POE	EP	7/8/2014	35145286001AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0090002	Cambridge	1	Stone Boundary WTP	GW	WTP POE	EP	7/8/2014	35145286001AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0090002	Cambridge	1	Stone Boundary WTP	GW	WTP POE	EP	7/8/2014	35145286001AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0100015	City of Frederick	1	Monocacy Filter Plant	SW	WTP POE	EP	3/18/2015	K1503020-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0100015	City of Frederick	1	Monocacy Filter Plant	SW	WTP POE	EP	3/18/2015	K1503020-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0100015	City of Frederick	1	Monocacy Filter Plant	SW	WTP POE	EP	3/18/2015	K1503020-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0100015	City of Frederick	1	Monocacy Filter Plant	SW	WTP POE	EP	3/18/2015	K1503020-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0100015	City of Frederick	1	Monocacy Filter Plant	SW	WTP POE	EP	3/18/2015	K1503020-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0100015	City of Frederick	1	Monocacy Filter Plant	SW	WTP POE	EP	3/18/2015	K1503020-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0100015	City of Frederick	1	Monocacy Filter Plant	SW	WTP POE	EP	6/10/2015	K1506494-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0100015	City of Frederick	1	Monocacy Filter Plant	SW	WTP POE	EP	6/10/2015	K1506494-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0100015	City of Frederick	1	Monocacy Filter Plant	SW	WTP POE	EP	6/10/2015	K1506494-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0100015	City of Frederick	1	Monocacy Filter Plant	SW	WTP POE	EP	6/10/2015	K1506494-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0100015	City of Frederick	1	Monocacy Filter Plant	SW	WTP POE	EP	6/10/2015	K1506494-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0100015	City of Frederick	1	Monocacy Filter Plant	SW	WTP POE	EP	6/10/2015	K1506494-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0100015	City of Frederick	1	Monocacy Filter Plant	SW	WTP POE	EP	9/2/2015	K1509924-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0100015	City of Frederick	1	Monocacy Filter Plant	SW	WTP POE	EP	9/2/2015	K1509924-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0100015	City of Frederick	1	Monocacy Filter Plant	SW	WTP POE	EP	9/2/2015	K1509924-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0100015	City of Frederick	1	Monocacy Filter Plant	SW	WTP POE	EP	9/2/2015	K1509924-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0100015	City of Frederick	1	Monocacy Filter Plant	SW	WTP POE	EP	9/2/2015	K1509924-001	PFHpA	EPA 537	<		0.01	ppb	MD

MD0100015	City of Frederick	1	Monocacy Filter Plant	SW	WTP POE	EP	9/2/2015	K1509924-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0100015	City of Frederick	1	Monocacy Filter Plant	SW	WTP POE	EP	12/9/2015	K1514272-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0100015	City of Frederick	1	Monocacy Filter Plant	SW	WTP POE	EP	12/9/2015	K1514272-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0100015	City of Frederick	1	Monocacy Filter Plant	SW	WTP POE	EP	12/9/2015	K1514272-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0100015	City of Frederick	1	Monocacy Filter Plant	SW	WTP POE	EP	12/9/2015	K1514272-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0100015	City of Frederick	1	Monocacy Filter Plant	SW	WTP POE	EP	12/9/2015	K1514272-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0100015	City of Frederick	1	Monocacy Filter Plant	SW	WTP POE	EP	12/9/2015	K1514272-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0100015	City of Frederick	2	Linganore Creek Filter Plant	SW	WTP POE	EP	3/18/2015	K1503021-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0100015	City of Frederick	2	Linganore Creek Filter Plant	SW	WTP POE	EP	3/18/2015	K1503021-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0100015	City of Frederick	2	Linganore Creek Filter Plant	SW	WTP POE	EP	3/18/2015	K1503021-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0100015	City of Frederick	2	Linganore Creek Filter Plant	SW	WTP POE	EP	3/18/2015	K1503021-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0100015	City of Frederick	2	Linganore Creek Filter Plant	SW	WTP POE	EP	3/18/2015	K1503021-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0100015	City of Frederick	2	Linganore Creek Filter Plant	SW	WTP POE	EP	3/18/2015	K1503021-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0100015	City of Frederick	2	Linganore Creek Filter Plant	SW	WTP POE	EP	6/10/2015	K1506482-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0100015	City of Frederick	2	Linganore Creek Filter Plant	SW	WTP POE	EP	6/10/2015	K1506482-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0100015	City of Frederick	2	Linganore Creek Filter Plant	SW	WTP POE	EP	6/10/2015	K1506482-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0100015	City of Frederick	2	Linganore Creek Filter Plant	SW	WTP POE	EP	6/10/2015	K1506482-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0100015	City of Frederick	2	Linganore Creek Filter Plant	SW	WTP POE	EP	6/10/2015	K1506482-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0100015	City of Frederick	2	Linganore Creek Filter Plant	SW	WTP POE	EP	6/10/2015	K1506482-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0100015	City of Frederick	2	Linganore Creek Filter Plant	SW	WTP POE	EP	9/2/2015	K1509923-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0100015	City of Frederick	2	Linganore Creek Filter Plant	SW	WTP POE	EP	9/2/2015	K1509923-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0100015	City of Frederick	2	Linganore Creek Filter Plant	SW	WTP POE	EP	9/2/2015	K1509923-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0100015	City of Frederick	2	Linganore Creek Filter Plant	SW	WTP POE	EP	9/2/2015	K1509923-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0100015	City of Frederick	2	Linganore Creek Filter Plant	SW	WTP POE	EP	9/2/2015	K1509923-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0100015	City of Frederick	2	Linganore Creek Filter Plant	SW	WTP POE	EP	9/2/2015	K1509923-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0100015	City of Frederick	2	Linganore Creek Filter Plant	SW	WTP POE	EP	12/9/2015	K1514289-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0100015	City of Frederick	2	Linganore Creek Filter Plant	SW	WTP POE	EP	12/9/2015	K1514289-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0100015	City of Frederick	2	Linganore Creek Filter Plant	SW	WTP POE	EP	12/9/2015	K1514289-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0100015	City of Frederick	2	Linganore Creek Filter Plant	SW	WTP POE	EP	12/9/2015	K1514289-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0100015	City of Frederick	2	Linganore Creek Filter Plant	SW	WTP POE	EP	12/9/2015	K1514289-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0100015	City of Frederick	2	Linganore Creek Filter Plant	SW	WTP POE	EP	12/9/2015	K1514289-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0100015	City of Frederick	3	Lester R. Dingle Filter Plant	SW	WTP POE	EP	3/18/2015	K1503017-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0100015	City of Frederick	3	Lester R. Dingle Filter Plant	SW	WTP POE	EP	3/18/2015	K1503017-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0100015	City of Frederick	3	Lester R. Dingle Filter Plant	SW	WTP POE	EP	3/18/2015	K1503017-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0100015	City of Frederick	3	Lester R. Dingle Filter Plant	SW	WTP POE	EP	3/18/2015	K1503017-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0100015	City of Frederick	3	Lester R. Dingle Filter Plant	SW	WTP POE	EP	3/18/2015	K1503017-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0100015	City of Frederick	3	Lester R. Dingle Filter Plant	SW	WTP POE	EP	3/18/2015	K1503017-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0100015	City of Frederick	3	Lester R. Dingle Filter Plant	SW	WTP POE	EP	6/10/2015	K1506497-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0100015	City of Frederick	3	Lester R. Dingle Filter Plant	SW	WTP POE	EP	6/10/2015	K1506497-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0100015	City of Frederick	3	Lester R. Dingle Filter Plant	SW	WTP POE	EP	6/10/2015	K1506497-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0100015	City of Frederick	3	Lester R. Dingle Filter Plant	SW	WTP POE	EP	6/10/2015	K1506497-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0100015	City of Frederick	3	Lester R. Dingle Filter Plant	SW	WTP POE	EP	6/10/2015	K1506497-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0100015	City of Frederick	3	Lester R. Dingle Filter Plant	SW	WTP POE	EP	6/10/2015	K1506497-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0100015	City of Frederick	3	Lester R. Dingle Filter Plant	SW	WTP POE	EP	9/2/2015	K1509925-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0100015	City of Frederick	3	Lester R. Dingle Filter Plant	SW	WTP POE	EP	9/2/2015	K1509925-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0100015	City of Frederick	3	Lester R. Dingle Filter Plant	SW	WTP POE	EP	9/2/2015	K1509925-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0100015	City of Frederick	3	Lester R. Dingle Filter Plant	SW	WTP POE	EP	9/2/2015	K1509925-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0100015	City of Frederick	3	Lester R. Dingle Filter Plant	SW	WTP POE	EP	9/2/2015	K1509925-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0100015	City of Frederick	3	Lester R. Dingle Filter Plant	SW	WTP POE	EP	9/2/2015	K1509925-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0100015	City of Frederick	3	Lester R. Dingle Filter Plant	SW	WTP POE	EP	12/9/2015	K1514275-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0100015	City of Frederick	3	Lester R. Dingle Filter Plant	SW	WTP POE	EP	12/9/2015	K1514275-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0100015	City of Frederick	3	Lester R. Dingle Filter Plant	SW	WTP POE	EP	12/9/2015	K1514275-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0100015	City of Frederick	3	Lester R. Dingle Filter Plant	SW	WTP POE	EP	12/9/2015	K1514275-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0100015	City of Frederick	3	Lester R. Dingle Filter Plant	SW	WTP POE	EP	12/9/2015	K1514275-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0100015	City of Frederick	3	Lester R. Dingle Filter Plant	SW	WTP POE	EP	12/9/2015	K1514275-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0100015	City of Frederick	90001	Frederick County Intertie	SW	EPTDS from F	EP	3/10/2015	K1502713-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0100015	City of Frederick	90001	Frederick County Intertie	SW	EPTDS from F	EP	3/10/2015	K1502713-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0100015	City of Frederick	90001	Frederick County Intertie	SW	EPTDS from F	EP	3/10/2015	K1502713-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0100015	City of Frederick	90001	Frederick County Intertie	SW	EPTDS from F	EP	3/10/2015	K1502713-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0100015	City of Frederick	90001	Frederick County Intertie	SW	EPTDS from F	EP	3/10/2015	K1502713-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0100015	City of Frederick	90001	Frederick County Intertie	SW	EPTDS from F	EP	3/10/2015	K1502713-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0100015	City of Frederick	90001	Frederick County Intertie	SW	EPTDS from F	EP	6/10/2015	K1506526-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0100015	City of Frederick	90001	Frederick County Intertie	SW	EPTDS from F	EP	6/10/2015	K1506526-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0100015	City of Frederick	90001	Frederick County Intertie	SW	EPTDS from F	EP	6/10/2015	K1506526-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0100015	City of Frederick	90001	Frederick County Intertie	SW	EPTDS from F	EP	6/10/2015	K1506526-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0100015	City of Frederick	90001	Frederick County Intertie	SW	EPTDS from F	EP	6/10/2015	K1506526-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0100015	City of Frederick	90001	Frederick County Intertie	SW	EPTDS from F	EP	6/10/2015	K1506526-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0100015	City of Frederick	90001	Frederick County Intertie	SW	EPTDS from F	EP	9/2/2015	K1509921-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0100015	City of Frederick	90001	Frederick County Intertie	SW	EPTDS from F	EP	9/2/2015	K1509921-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0100015	City of Frederick	90001	Frederick County Intertie	SW	EPTDS from F	EP	9/2/2015	K1509921-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0100015	City of Frederick	90001	Frederick County Intertie	SW	EPTDS from F	EP	9/2/2015	K1509921-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0100015	City of Frederick	90001	Frederick County Intertie	SW	EPTDS from F	EP	9/2/2015	K1509921-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0100015	City of Frederick	90001	Frederick County Intertie	SW	EPTDS from F	EP	9/2/2015	K1509921-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0100015	City of Frederick	90001	Frederick County Intertie	SW	EPTDS from F	EP	12/9/2015	K1514276-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0100015	City of Frederick	90001	Frederick County Intertie	SW	EPTDS from F	EP	12/9/2015	K1514276-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0100015	City of Frederick	90001	Frederick County Intertie	SW	EPTDS from F	EP	12/9/2015	K1514276-001	PFOS	EPA 537	<		0.04	ppb	MD

MD0100015	City of Frederick	90001	Fredercik County Intertie	SW	EPTDS from F	EP	12/9/2015	K1514276-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0100015	City of Frederick	90001	Fredercik County Intertie	SW	EPTDS from F	EP	12/9/2015	K1514276-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0100015	City of Frederick	90001	Fredercik County Intertie	SW	EPTDS from F	EP	12/9/2015	K1514276-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0100030	New Design	1	New Design Plant 1 & 2	SW	WTP POE	EP	2/5/2014	K1401321-003	PFNA	EPA 537	<		0.02	ppb	MD
MD0100030	New Design	1	New Design Plant 1 & 2	SW	WTP POE	EP	2/5/2014	K1401321-003	PFHpA	EPA 537	<		0.01	ppb	MD
MD0100030	New Design	1	New Design Plant 1 & 2	SW	WTP POE	EP	2/5/2014	K1401321-003	PFBS	EPA 537	<		0.09	ppb	MD
MD0100030	New Design	1	New Design Plant 1 & 2	SW	WTP POE	EP	2/5/2014	K1401321-003	PFHxS	EPA 537	<		0.03	ppb	MD
MD0100030	New Design	1	New Design Plant 1 & 2	SW	WTP POE	EP	2/5/2014	K1401321-003	PFOA	EPA 537	<		0.02	ppb	MD
MD0100030	New Design	1	New Design Plant 1 & 2	SW	WTP POE	EP	2/5/2014	K1401321-003	PFOS	EPA 537	<		0.04	ppb	MD
MD0100030	New Design	1	New Design Plant 1 & 2	SW	WTP POE	EP	5/8/2014	K1404747-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0100030	New Design	1	New Design Plant 1 & 2	SW	WTP POE	EP	5/8/2014	K1404747-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0100030	New Design	1	New Design Plant 1 & 2	SW	WTP POE	EP	5/8/2014	K1404747-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0100030	New Design	1	New Design Plant 1 & 2	SW	WTP POE	EP	5/8/2014	K1404747-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0100030	New Design	1	New Design Plant 1 & 2	SW	WTP POE	EP	5/8/2014	K1404747-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0100030	New Design	1	New Design Plant 1 & 2	SW	WTP POE	EP	5/8/2014	K1404747-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0100030	New Design	1	New Design Plant 1 & 2	SW	WTP POE	EP	8/5/2014	K1408525-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0100030	New Design	1	New Design Plant 1 & 2	SW	WTP POE	EP	8/5/2014	K1408525-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0100030	New Design	1	New Design Plant 1 & 2	SW	WTP POE	EP	8/5/2014	K1408525-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0100030	New Design	1	New Design Plant 1 & 2	SW	WTP POE	EP	8/5/2014	K1408525-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0100030	New Design	1	New Design Plant 1 & 2	SW	WTP POE	EP	8/5/2014	K1408525-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0100030	New Design	1	New Design Plant 1 & 2	SW	WTP POE	EP	8/5/2014	K1408525-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0100030	New Design	1	New Design Plant 1 & 2	SW	WTP POE	EP	11/7/2014	K1412796-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0100030	New Design	1	New Design Plant 1 & 2	SW	WTP POE	EP	11/7/2014	K1412796-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0100030	New Design	1	New Design Plant 1 & 2	SW	WTP POE	EP	11/7/2014	K1412796-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0100030	New Design	1	New Design Plant 1 & 2	SW	WTP POE	EP	11/7/2014	K1412796-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0100030	New Design	1	New Design Plant 1 & 2	SW	WTP POE	EP	11/7/2014	K1412796-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0100030	New Design	1	New Design Plant 1 & 2	SW	WTP POE	EP	11/7/2014	K1412796-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0100030	New Design	5	Woodspring WTP (Wells 1 & 2)	GW	WTP POE	EP	2/5/2014	K1401321-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0100030	New Design	5	Woodspring WTP (Wells 1 & 2)	GW	WTP POE	EP	2/5/2014	K1401321-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0100030	New Design	5	Woodspring WTP (Wells 1 & 2)	GW	WTP POE	EP	2/5/2014	K1401321-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0100030	New Design	5	Woodspring WTP (Wells 1 & 2)	GW	WTP POE	EP	2/5/2014	K1401321-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0100030	New Design	5	Woodspring WTP (Wells 1 & 2)	GW	WTP POE	EP	2/5/2014	K1401321-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0100030	New Design	5	Woodspring WTP (Wells 1 & 2)	GW	WTP POE	EP	2/5/2014	K1401321-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0100030	New Design	5	Woodspring WTP (Wells 1 & 2)	GW	WTP POE	EP	8/5/2014	K1408525-003	PFOA	EPA 537	<		0.02	ppb	MD
MD0100030	New Design	5	Woodspring WTP (Wells 1 & 2)	GW	WTP POE	EP	8/5/2014	K1408525-003	PFHpA	EPA 537	<		0.01	ppb	MD
MD0100030	New Design	5	Woodspring WTP (Wells 1 & 2)	GW	WTP POE	EP	8/5/2014	K1408525-003	PFHxS	EPA 537	<		0.03	ppb	MD
MD0100030	New Design	5	Woodspring WTP (Wells 1 & 2)	GW	WTP POE	EP	8/5/2014	K1408525-003	PFNA	EPA 537	<		0.02	ppb	MD
MD0100030	New Design	5	Woodspring WTP (Wells 1 & 2)	GW	WTP POE	EP	8/5/2014	K1408525-003	PFBS	EPA 537	<		0.09	ppb	MD
MD0100030	New Design	5	Woodspring WTP (Wells 1 & 2)	GW	WTP POE	EP	8/5/2014	K1408525-003	PFOS	EPA 537	<		0.04	ppb	MD
MD0100040	Sam Hill Estates (Mill Bottom)	1	Sam Hill WTP	GW	WTP POE	EP	3/10/2014	105921P	PFBS	EPA 537	<		0.09	ppb	MD
MD0100040	Sam Hill Estates (Mill Bottom)	1	Sam Hill WTP	GW	WTP POE	EP	3/10/2014	105921P	PFHpA	EPA 537	<		0.01	ppb	MD
MD0100040	Sam Hill Estates (Mill Bottom)	1	Sam Hill WTP	GW	WTP POE	EP	3/10/2014	105921P	PFHxS	EPA 537	<		0.03	ppb	MD
MD0100040	Sam Hill Estates (Mill Bottom)	1	Sam Hill WTP	GW	WTP POE	EP	3/10/2014	105921P	PFNA	EPA 537	<		0.02	ppb	MD
MD0100040	Sam Hill Estates (Mill Bottom)	1	Sam Hill WTP	GW	WTP POE	EP	3/10/2014	105921P	PFOS	EPA 537	<		0.04	ppb	MD
MD0100040	Sam Hill Estates (Mill Bottom)	1	Sam Hill WTP	GW	WTP POE	EP	3/10/2014	105921P	PFOA	EPA 537	<		0.02	ppb	MD
MD0100040	Sam Hill Estates (Mill Bottom)	1	Sam Hill WTP	GW	WTP POE	EP	9/15/2014	109067P	PFBS	EPA 537	<		0.09	ppb	MD
MD0100040	Sam Hill Estates (Mill Bottom)	1	Sam Hill WTP	GW	WTP POE	EP	9/15/2014	109067P	PFHpA	EPA 537	<		0.01	ppb	MD
MD0100040	Sam Hill Estates (Mill Bottom)	1	Sam Hill WTP	GW	WTP POE	EP	9/15/2014	109067P	PFHxS	EPA 537	<		0.03	ppb	MD
MD0100040	Sam Hill Estates (Mill Bottom)	1	Sam Hill WTP	GW	WTP POE	EP	9/15/2014	109067P	PFNA	EPA 537	<		0.02	ppb	MD
MD0100040	Sam Hill Estates (Mill Bottom)	1	Sam Hill WTP	GW	WTP POE	EP	9/15/2014	109067P	PFOS	EPA 537	<		0.04	ppb	MD
MD0100040	Sam Hill Estates (Mill Bottom)	1	Sam Hill WTP	GW	WTP POE	EP	9/15/2014	109067P	PFOA	EPA 537	<		0.02	ppb	MD
MD0120001	City of Aberdeen	1	Aberdeen WTP	GW	WTP POE	EP	11/20/2014	K1413313-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0120001	City of Aberdeen	1	Aberdeen WTP	GW	WTP POE	EP	11/20/2014	K1413313-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0120001	City of Aberdeen	1	Aberdeen WTP	GW	WTP POE	EP	11/20/2014	K1413313-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0120001	City of Aberdeen	1	Aberdeen WTP	GW	WTP POE	EP	11/20/2014	K1413313-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0120001	City of Aberdeen	1	Aberdeen WTP	GW	WTP POE	EP	11/20/2014	K1413313-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0120001	City of Aberdeen	1	Aberdeen WTP	GW	WTP POE	EP	11/20/2014	K1413313-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0120001	City of Aberdeen	1	Aberdeen WTP	GW	WTP POE	EP	5/21/2015	K1505743-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0120001	City of Aberdeen	1	Aberdeen WTP	GW	WTP POE	EP	5/21/2015	K1505743-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0120001	City of Aberdeen	1	Aberdeen WTP	GW	WTP POE	EP	5/21/2015	K1505743-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0120001	City of Aberdeen	1	Aberdeen WTP	GW	WTP POE	EP	5/21/2015	K1505743-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0120001	City of Aberdeen	1	Aberdeen WTP	GW	WTP POE	EP	5/21/2015	K1505743-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0120001	City of Aberdeen	1	Aberdeen WTP	GW	WTP POE	EP	5/21/2015	K1505743-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0120001	City of Aberdeen	3	Harford DPW Intertie	SW	EPTDS from H	EP	11/20/2014	K1413320-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0120001	City of Aberdeen	3	Harford DPW Intertie	SW	EPTDS from H	EP	11/20/2014	K1413320-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0120001	City of Aberdeen	3	Harford DPW Intertie	SW	EPTDS from H	EP	11/20/2014	K1413320-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0120001	City of Aberdeen	3	Harford DPW Intertie	SW	EPTDS from H	EP	11/20/2014	K1413320-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0120001	City of Aberdeen	3	Harford DPW Intertie	SW	EPTDS from H	EP	11/20/2014	K1413320-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0120001	City of Aberdeen	3	Harford DPW Intertie	SW	EPTDS from H	EP	11/20/2014	K1413320-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0120001	City of Aberdeen	3	Harford DPW Intertie	SW	EPTDS from H	EP	2/12/2015	K1501633-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0120001	City of Aberdeen	3	Harford DPW Intertie	SW	EPTDS from H	EP	2/12/2015	K1501633-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0120001	City of Aberdeen	3	Harford DPW Intertie	SW	EPTDS from H	EP	2/12/2015	K1501633-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0120001	City of Aberdeen	3	Harford DPW Intertie	SW	EPTDS from H	EP	2/12/2015	K1501633-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0120001	City of Aberdeen	3	Harford DPW Intertie	SW	EPTDS from H	EP	2/12/2015	K1501633-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0120001	City of Aberdeen	3	Harford DPW Intertie	SW	EPTDS from H	EP	2/12/2015	K1501633-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0120001	City of Aberdeen	3	Harford DPW Intertie	SW	EPTDS from H	EP	5/21/2015	K1505739-001	PFOS	EPA 537	<		0.04	ppb	MD

MD0120001	City of Aberdeen	3	Harford DPW Intertie	SW	EPTDS from H	EP	5/21/2015	K1505739-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0120001	City of Aberdeen	3	Harford DPW Intertie	SW	EPTDS from H	EP	5/21/2015	K1505739-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0120001	City of Aberdeen	3	Harford DPW Intertie	SW	EPTDS from H	EP	5/21/2015	K1505739-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0120001	City of Aberdeen	3	Harford DPW Intertie	SW	EPTDS from H	EP	5/21/2015	K1505739-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0120001	City of Aberdeen	3	Harford DPW Intertie	SW	EPTDS from H	EP	5/21/2015	K1505739-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0120001	City of Aberdeen	3	Harford DPW Intertie	SW	EPTDS from H	EP	8/17/2015	K1509148-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0120001	City of Aberdeen	3	Harford DPW Intertie	SW	EPTDS from H	EP	8/17/2015	K1509148-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0120001	City of Aberdeen	3	Harford DPW Intertie	SW	EPTDS from H	EP	8/17/2015	K1509148-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0120001	City of Aberdeen	3	Harford DPW Intertie	SW	EPTDS from H	EP	8/17/2015	K1509148-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0120001	City of Aberdeen	3	Harford DPW Intertie	SW	EPTDS from H	EP	8/17/2015	K1509148-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0120001	City of Aberdeen	3	Harford DPW Intertie	SW	EPTDS from H	EP	8/17/2015	K1509148-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0120002	Chapel Hill	1	Chapel Hill WTP	SW	WTP POE	EP	10/22/2014	K1411980-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0120002	Chapel Hill	1	Chapel Hill WTP	SW	WTP POE	EP	10/22/2014	K1411980-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0120002	Chapel Hill	1	Chapel Hill WTP	SW	WTP POE	EP	10/22/2014	K1411980-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0120002	Chapel Hill	1	Chapel Hill WTP	SW	WTP POE	EP	10/22/2014	K1411980-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0120002	Chapel Hill	1	Chapel Hill WTP	SW	WTP POE	EP	10/22/2014	K1411980-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0120002	Chapel Hill	1	Chapel Hill WTP	SW	WTP POE	EP	10/22/2014	K1411980-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0120002	Chapel Hill	1	Chapel Hill WTP	SW	WTP POE	EP	1/21/2015	K1500685-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0120002	Chapel Hill	1	Chapel Hill WTP	SW	WTP POE	EP	1/21/2015	K1500685-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0120002	Chapel Hill	1	Chapel Hill WTP	SW	WTP POE	EP	1/21/2015	K1500685-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0120002	Chapel Hill	1	Chapel Hill WTP	SW	WTP POE	EP	1/21/2015	K1500685-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0120002	Chapel Hill	1	Chapel Hill WTP	SW	WTP POE	EP	1/21/2015	K1500685-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0120002	Chapel Hill	1	Chapel Hill WTP	SW	WTP POE	EP	1/21/2015	K1500685-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0120002	Chapel Hill	1	Chapel Hill WTP	SW	WTP POE	EP	4/28/2015	K1504539-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0120002	Chapel Hill	1	Chapel Hill WTP	SW	WTP POE	EP	4/28/2015	K1504539-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0120002	Chapel Hill	1	Chapel Hill WTP	SW	WTP POE	EP	4/28/2015	K1504539-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0120002	Chapel Hill	1	Chapel Hill WTP	SW	WTP POE	EP	4/28/2015	K1504539-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0120002	Chapel Hill	1	Chapel Hill WTP	SW	WTP POE	EP	4/28/2015	K1504539-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0120002	Chapel Hill	1	Chapel Hill WTP	SW	WTP POE	EP	4/28/2015	K1504539-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0120002	Chapel Hill	1	Chapel Hill WTP	SW	WTP POE	EP	7/23/2015	K1508155-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0120002	Chapel Hill	1	Chapel Hill WTP	SW	WTP POE	EP	7/23/2015	K1508155-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0120002	Chapel Hill	1	Chapel Hill WTP	SW	WTP POE	EP	7/23/2015	K1508155-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0120002	Chapel Hill	1	Chapel Hill WTP	SW	WTP POE	EP	7/23/2015	K1508155-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0120002	Chapel Hill	1	Chapel Hill WTP	SW	WTP POE	EP	7/23/2015	K1508155-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0120002	Chapel Hill	1	Chapel Hill WTP	SW	WTP POE	EP	7/23/2015	K1508155-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0120003	MD American Water Co.	1	Winters Run Filter Plant	SW	WTP POE	EP	11/11/2014	27547501	PFNA	EPA 537	<		0.02	ppb	MD
MD0120003	MD American Water Co.	1	Winters Run Filter Plant	SW	WTP POE	EP	11/11/2014	27547501	PFHxS	EPA 537	<		0.03	ppb	MD
MD0120003	MD American Water Co.	1	Winters Run Filter Plant	SW	WTP POE	EP	11/11/2014	27547501	PFOS	EPA 537	<		0.04	ppb	MD
MD0120003	MD American Water Co.	1	Winters Run Filter Plant	SW	WTP POE	EP	11/11/2014	27547501	PFBS	EPA 537	<		0.09	ppb	MD
MD0120003	MD American Water Co.	1	Winters Run Filter Plant	SW	WTP POE	EP	11/11/2014	27547501	PFHpA	EPA 537	<		0.01	ppb	MD
MD0120003	MD American Water Co.	1	Winters Run Filter Plant	SW	WTP POE	EP	11/11/2014	27547501	PFOA	EPA 537	<		0.02	ppb	MD
MD0120003	MD American Water Co.	1	Winters Run Filter Plant	SW	WTP POE	EP	2/12/2015	28168801	PFOS	EPA 537	<		0.04	ppb	MD
MD0120003	MD American Water Co.	1	Winters Run Filter Plant	SW	WTP POE	EP	2/12/2015	28168801	PFOA	EPA 537	<		0.02	ppb	MD
MD0120003	MD American Water Co.	1	Winters Run Filter Plant	SW	WTP POE	EP	2/12/2015	28168801	PFNA	EPA 537	<		0.02	ppb	MD
MD0120003	MD American Water Co.	1	Winters Run Filter Plant	SW	WTP POE	EP	2/12/2015	28168801	PFHxS	EPA 537	<		0.03	ppb	MD
MD0120003	MD American Water Co.	1	Winters Run Filter Plant	SW	WTP POE	EP	2/12/2015	28168801	PFHpA	EPA 537	<		0.01	ppb	MD
MD0120003	MD American Water Co.	1	Winters Run Filter Plant	SW	WTP POE	EP	2/12/2015	28168801	PFBS	EPA 537	<		0.09	ppb	MD
MD0120003	MD American Water Co.	1	Winters Run Filter Plant	SW	WTP POE	EP	5/11/2015	28899201	PFNA	EPA 537	<		0.02	ppb	MD
MD0120003	MD American Water Co.	1	Winters Run Filter Plant	SW	WTP POE	EP	5/11/2015	28899201	PFOA	EPA 537	<		0.02	ppb	MD
MD0120003	MD American Water Co.	1	Winters Run Filter Plant	SW	WTP POE	EP	5/11/2015	28899201	PFOS	EPA 537	<		0.04	ppb	MD
MD0120003	MD American Water Co.	1	Winters Run Filter Plant	SW	WTP POE	EP	5/11/2015	28899201	PFHxS	EPA 537	<		0.03	ppb	MD
MD0120003	MD American Water Co.	1	Winters Run Filter Plant	SW	WTP POE	EP	5/11/2015	28899201	PFHpA	EPA 537	<		0.01	ppb	MD
MD0120003	MD American Water Co.	1	Winters Run Filter Plant	SW	WTP POE	EP	5/11/2015	28899201	PFBS	EPA 537	<		0.09	ppb	MD
MD0120003	MD American Water Co.	1	Winters Run Filter Plant	SW	WTP POE	EP	8/11/2015	29934201	PFBS	EPA 537	<		0.09	ppb	MD
MD0120003	MD American Water Co.	1	Winters Run Filter Plant	SW	WTP POE	EP	8/11/2015	29934201	PFOA	EPA 537	<		0.02	ppb	MD
MD0120003	MD American Water Co.	1	Winters Run Filter Plant	SW	WTP POE	EP	8/11/2015	29934201	PFOS	EPA 537	<		0.04	ppb	MD
MD0120003	MD American Water Co.	1	Winters Run Filter Plant	SW	WTP POE	EP	8/11/2015	29934201	PFNA	EPA 537	<		0.02	ppb	MD
MD0120003	MD American Water Co.	1	Winters Run Filter Plant	SW	WTP POE	EP	8/11/2015	29934201	PFHxS	EPA 537	<		0.03	ppb	MD
MD0120003	MD American Water Co.	1	Winters Run Filter Plant	SW	WTP POE	EP	8/11/2015	29934201	PFHpA	EPA 537	<		0.01	ppb	MD
MD0120003	MD American Water Co.	2	Bynum Well	GW	WTP POE	EP	11/11/2014	27547401	PFOS	EPA 537	<		0.04	ppb	MD
MD0120003	MD American Water Co.	2	Bynum Well	GW	WTP POE	EP	11/11/2014	27547401	PFOA	EPA 537	<		0.02	ppb	MD
MD0120003	MD American Water Co.	2	Bynum Well	GW	WTP POE	EP	11/11/2014	27547401	PFNA	EPA 537	<		0.02	ppb	MD
MD0120003	MD American Water Co.	2	Bynum Well	GW	WTP POE	EP	11/11/2014	27547401	PFHpA	EPA 537	<		0.01	ppb	MD
MD0120003	MD American Water Co.	2	Bynum Well	GW	WTP POE	EP	11/11/2014	27547401	PFBS	EPA 537	<		0.09	ppb	MD
MD0120003	MD American Water Co.	2	Bynum Well	GW	WTP POE	EP	11/11/2014	27547401	PFHxS	EPA 537	<		0.03	ppb	MD
MD0120003	MD American Water Co.	2	Bynum Well	GW	WTP POE	EP	5/11/2015	28899101	PFOS	EPA 537	<		0.04	ppb	MD
MD0120003	MD American Water Co.	2	Bynum Well	GW	WTP POE	EP	5/11/2015	28899101	PFNA	EPA 537	<		0.02	ppb	MD
MD0120003	MD American Water Co.	2	Bynum Well	GW	WTP POE	EP	5/11/2015	28899101	PFHxS	EPA 537	<		0.03	ppb	MD
MD0120003	MD American Water Co.	2	Bynum Well	GW	WTP POE	EP	5/11/2015	28899101	PFBS	EPA 537	<		0.09	ppb	MD
MD0120003	MD American Water Co.	2	Bynum Well	GW	WTP POE	EP	5/11/2015	28899101	PFOA	EPA 537	<		0.02	ppb	MD
MD0120003	MD American Water Co.	2	Bynum Well	GW	WTP POE	EP	5/11/2015	28899101	PFHpA	EPA 537	<		0.01	ppb	MD
MD0120012	City of Havre de Grace	1	Havre de Grace Filtration Plant	SW	WTP POE	EP	5/22/2013	130528001-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0120012	City of Havre de Grace	1	Havre de Grace Filtration Plant	SW	WTP POE	EP	5/22/2013	130528001-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0120012	City of Havre de Grace	1	Havre de Grace Filtration Plant	SW	WTP POE	EP	5/22/2013	130528001-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0120012	City of Havre de Grace	1	Havre de Grace Filtration Plant	SW	WTP POE	EP	5/22/2013	130528001-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0120012	City of Havre de Grace	1	Havre de Grace Filtration Plant	SW	WTP POE	EP	5/22/2013	130528001-001	PFHxS	EPA 537	<		0.03	ppb	MD

MD0120012	City of Havre de Grace	1	Havre de Grace Filtration Plant	SW	WTP POE	EP	5/22/2013	130528001-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0120012	City of Havre de Grace	1	Havre de Grace Filtration Plant	SW	WTP POE	EP	8/26/2013	130828012-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0120012	City of Havre de Grace	1	Havre de Grace Filtration Plant	SW	WTP POE	EP	8/26/2013	130828012-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0120012	City of Havre de Grace	1	Havre de Grace Filtration Plant	SW	WTP POE	EP	8/26/2013	130828012-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0120012	City of Havre de Grace	1	Havre de Grace Filtration Plant	SW	WTP POE	EP	8/26/2013	130828012-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0120012	City of Havre de Grace	1	Havre de Grace Filtration Plant	SW	WTP POE	EP	8/26/2013	130828012-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0120012	City of Havre de Grace	1	Havre de Grace Filtration Plant	SW	WTP POE	EP	8/26/2013	130828012-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0120012	City of Havre de Grace	1	Havre de Grace Filtration Plant	SW	WTP POE	EP	11/14/2013	131115037-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0120012	City of Havre de Grace	1	Havre de Grace Filtration Plant	SW	WTP POE	EP	11/14/2013	131115037-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0120012	City of Havre de Grace	1	Havre de Grace Filtration Plant	SW	WTP POE	EP	11/14/2013	131115037-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0120012	City of Havre de Grace	1	Havre de Grace Filtration Plant	SW	WTP POE	EP	11/14/2013	131115037-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0120012	City of Havre de Grace	1	Havre de Grace Filtration Plant	SW	WTP POE	EP	11/14/2013	131115037-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0120012	City of Havre de Grace	1	Havre de Grace Filtration Plant	SW	WTP POE	EP	11/14/2013	131115037-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0120012	City of Havre de Grace	1	Havre de Grace Filtration Plant	SW	WTP POE	EP	2/19/2014	140220019-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0120012	City of Havre de Grace	1	Havre de Grace Filtration Plant	SW	WTP POE	EP	2/19/2014	140220019-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0120012	City of Havre de Grace	1	Havre de Grace Filtration Plant	SW	WTP POE	EP	2/19/2014	140220019-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0120012	City of Havre de Grace	1	Havre de Grace Filtration Plant	SW	WTP POE	EP	2/19/2014	140220019-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0120012	City of Havre de Grace	1	Havre de Grace Filtration Plant	SW	WTP POE	EP	2/19/2014	140220019-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0120012	City of Havre de Grace	1	Havre de Grace Filtration Plant	SW	WTP POE	EP	2/19/2014	140220019-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0120016	Harford County DPW	1	Perryman WTP	GW	WTP POE	EP	3/4/2013	707726-8270	PFOA	EPA 537	<		0.02	ppb	MD
MD0120016	Harford County DPW	1	Perryman WTP	GW	WTP POE	EP	3/4/2013	707726-8270	PFNA	EPA 537	<		0.02	ppb	MD
MD0120016	Harford County DPW	1	Perryman WTP	GW	WTP POE	EP	3/4/2013	707726-8270	PFHpA	EPA 537	<		0.01	ppb	MD
MD0120016	Harford County DPW	1	Perryman WTP	GW	WTP POE	EP	3/4/2013	707726-8270	PFBS	EPA 537	<		0.09	ppb	MD
MD0120016	Harford County DPW	1	Perryman WTP	GW	WTP POE	EP	3/4/2013	707726-8270	PFHxS	EPA 537	<		0.03	ppb	MD
MD0120016	Harford County DPW	1	Perryman WTP	GW	WTP POE	EP	3/4/2013	707726-8270	PFOS	EPA 537	<		0.04	ppb	MD
MD0120016	Harford County DPW	1	Perryman WTP	GW	WTP POE	EP	9/3/2013	741741-9706	PFOS	EPA 537	<		0.04	ppb	MD
MD0120016	Harford County DPW	1	Perryman WTP	GW	WTP POE	EP	9/3/2013	741741-9706	PFNA	EPA 537	<		0.02	ppb	MD
MD0120016	Harford County DPW	1	Perryman WTP	GW	WTP POE	EP	9/3/2013	741741-9706	PFHxS	EPA 537	<		0.03	ppb	MD
MD0120016	Harford County DPW	1	Perryman WTP	GW	WTP POE	EP	9/3/2013	741741-9706	PFOA	EPA 537	=	0.02123	0.02	ppb	MD
MD0120016	Harford County DPW	1	Perryman WTP	GW	WTP POE	EP	9/3/2013	741741-9706	PFBS	EPA 537	<		0.09	ppb	MD
MD0120016	Harford County DPW	1	Perryman WTP	GW	WTP POE	EP	9/3/2013	741741-9706	PFHpA	EPA 537	<		0.01	ppb	MD
MD0120016	Harford County DPW	2	Havre de Grace FP Susquehana	SW	WTP POE	EP	3/4/2013	707728-8270	PFOA	EPA 537	<		0.02	ppb	MD
MD0120016	Harford County DPW	2	Havre de Grace FP Susquehana	SW	WTP POE	EP	3/4/2013	707728-8270	PFOS	EPA 537	<		0.04	ppb	MD
MD0120016	Harford County DPW	2	Havre de Grace FP Susquehana	SW	WTP POE	EP	3/4/2013	707728-8270	PFHpA	EPA 537	<		0.01	ppb	MD
MD0120016	Harford County DPW	2	Havre de Grace FP Susquehana	SW	WTP POE	EP	3/4/2013	707728-8270	PFBS	EPA 537	<		0.09	ppb	MD
MD0120016	Harford County DPW	2	Havre de Grace FP Susquehana	SW	WTP POE	EP	3/4/2013	707728-8270	PFHxS	EPA 537	<		0.03	ppb	MD
MD0120016	Harford County DPW	2	Havre de Grace FP Susquehana	SW	WTP POE	EP	3/4/2013	707728-8270	PFNA	EPA 537	<		0.02	ppb	MD
MD0120016	Harford County DPW	2	Havre de Grace FP Susquehana	SW	WTP POE	EP	6/3/2013	722832-9087	PFOA	EPA 537	<		0.02	ppb	MD
MD0120016	Harford County DPW	2	Havre de Grace FP Susquehana	SW	WTP POE	EP	6/3/2013	722832-9087	PFOS	EPA 537	<		0.04	ppb	MD
MD0120016	Harford County DPW	2	Havre de Grace FP Susquehana	SW	WTP POE	EP	6/3/2013	722832-9087	PFNA	EPA 537	<		0.02	ppb	MD
MD0120016	Harford County DPW	2	Havre de Grace FP Susquehana	SW	WTP POE	EP	6/3/2013	722832-9087	PFHxS	EPA 537	<		0.03	ppb	MD
MD0120016	Harford County DPW	2	Havre de Grace FP Susquehana	SW	WTP POE	EP	6/3/2013	722832-9087	PFBS	EPA 537	<		0.09	ppb	MD
MD0120016	Harford County DPW	2	Havre de Grace FP Susquehana	SW	WTP POE	EP	6/3/2013	722832-9087	PFHpA	EPA 537	<		0.01	ppb	MD
MD0120016	Harford County DPW	2	Havre de Grace FP Susquehana	SW	WTP POE	EP	9/3/2013	741743-9706	PFBS	EPA 537	<		0.09	ppb	MD
MD0120016	Harford County DPW	2	Havre de Grace FP Susquehana	SW	WTP POE	EP	9/3/2013	741743-9706	PFHpA	EPA 537	<		0.01	ppb	MD
MD0120016	Harford County DPW	2	Havre de Grace FP Susquehana	SW	WTP POE	EP	9/3/2013	741743-9706	PFHxS	EPA 537	<		0.03	ppb	MD
MD0120016	Harford County DPW	2	Havre de Grace FP Susquehana	SW	WTP POE	EP	9/3/2013	741743-9706	PFNA	EPA 537	<		0.02	ppb	MD
MD0120016	Harford County DPW	2	Havre de Grace FP Susquehana	SW	WTP POE	EP	9/3/2013	741743-9706	PFOA	EPA 537	<		0.02	ppb	MD
MD0120016	Harford County DPW	2	Havre de Grace FP Susquehana	SW	WTP POE	EP	9/3/2013	741743-9706	PFOS	EPA 537	<		0.04	ppb	MD
MD0120016	Harford County DPW	2	Havre de Grace FP Susquehana	SW	WTP POE	EP	12/3/2013	761265-10407	PFOA	EPA 537	<		0.02	ppb	MD
MD0120016	Harford County DPW	2	Havre de Grace FP Susquehana	SW	WTP POE	EP	12/3/2013	761265-10407	PFOS	EPA 537	<		0.04	ppb	MD
MD0120016	Harford County DPW	2	Havre de Grace FP Susquehana	SW	WTP POE	EP	12/3/2013	761265-10407	PFNA	EPA 537	<		0.02	ppb	MD
MD0120016	Harford County DPW	2	Havre de Grace FP Susquehana	SW	WTP POE	EP	12/3/2013	761265-10407	PFHxS	EPA 537	<		0.03	ppb	MD
MD0120016	Harford County DPW	2	Havre de Grace FP Susquehana	SW	WTP POE	EP	12/3/2013	761265-10407	PFHpA	EPA 537	<		0.01	ppb	MD
MD0120016	Harford County DPW	2	Havre de Grace FP Susquehana	SW	WTP POE	EP	12/3/2013	761265-10407	PFBS	EPA 537	<		0.09	ppb	MD
MD0120016	Harford County DPW	3	Abingdon Filter Plant	SW	WTP POE	EP	3/4/2013	707718-8270	PFHpA	EPA 537	<		0.01	ppb	MD
MD0120016	Harford County DPW	3	Abingdon Filter Plant	SW	WTP POE	EP	3/4/2013	707718-8270	PFOA	EPA 537	<		0.02	ppb	MD
MD0120016	Harford County DPW	3	Abingdon Filter Plant	SW	WTP POE	EP	3/4/2013	707718-8270	PFOS	EPA 537	<		0.04	ppb	MD
MD0120016	Harford County DPW	3	Abingdon Filter Plant	SW	WTP POE	EP	3/4/2013	707718-8270	PFHxS	EPA 537	<		0.03	ppb	MD
MD0120016	Harford County DPW	3	Abingdon Filter Plant	SW	WTP POE	EP	3/4/2013	707718-8270	PFBS	EPA 537	<		0.09	ppb	MD
MD0120016	Harford County DPW	3	Abingdon Filter Plant	SW	WTP POE	EP	3/4/2013	707718-8270	PFNA	EPA 537	<		0.02	ppb	MD
MD0120016	Harford County DPW	3	Abingdon Filter Plant	SW	WTP POE	EP	6/3/2013	722826-9087	PFOS	EPA 537	<		0.04	ppb	MD
MD0120016	Harford County DPW	3	Abingdon Filter Plant	SW	WTP POE	EP	6/3/2013	722826-9087	PFBS	EPA 537	<		0.09	ppb	MD
MD0120016	Harford County DPW	3	Abingdon Filter Plant	SW	WTP POE	EP	6/3/2013	722826-9087	PFHpA	EPA 537	<		0.01	ppb	MD
MD0120016	Harford County DPW	3	Abingdon Filter Plant	SW	WTP POE	EP	6/3/2013	722826-9087	PFNA	EPA 537	<		0.02	ppb	MD
MD0120016	Harford County DPW	3	Abingdon Filter Plant	SW	WTP POE	EP	6/3/2013	722826-9087	PFOA	EPA 537	<		0.02	ppb	MD
MD0120016	Harford County DPW	3	Abingdon Filter Plant	SW	WTP POE	EP	6/3/2013	722826-9087	PFHxS	EPA 537	<		0.03	ppb	MD
MD0120016	Harford County DPW	3	Abingdon Filter Plant	SW	WTP POE	EP	9/3/2013	741717-9706	PFBS	EPA 537	<		0.09	ppb	MD
MD0120016	Harford County DPW	3	Abingdon Filter Plant	SW	WTP POE	EP	9/3/2013	741717-9706	PFOA	EPA 537	<		0.02	ppb	MD
MD0120016	Harford County DPW	3	Abingdon Filter Plant	SW	WTP POE	EP	9/3/2013	741717-9706	PFOS	EPA 537	<		0.04	ppb	MD
MD0120016	Harford County DPW	3	Abingdon Filter Plant	SW	WTP POE	EP	9/3/2013	741717-9706	PFNA	EPA 537	<		0.02	ppb	MD
MD0120016	Harford County DPW	3	Abingdon Filter Plant	SW	WTP POE	EP	9/3/2013	741717-9706	PFHxS	EPA 537	<		0.03	ppb	MD
MD0120016	Harford County DPW	3	Abingdon Filter Plant	SW	WTP POE	EP	9/3/2013	741717-9706	PFHpA	EPA 537	<		0.01	ppb	MD
MD0120016	Harford County DPW	3	Abingdon Filter Plant	SW	WTP POE	EP	12/2/2013	760947-10360	PFOA	EPA 537	<		0.02	ppb	MD
MD0120016	Harford County DPW	3	Abingdon Filter Plant	SW	WTP POE	EP	12/2/2013	760947-10360	PFOS	EPA 537	<		0.04	ppb	MD
MD0120016	Harford County DPW	3	Abingdon Filter Plant	SW	WTP POE	EP	12/2/2013	760947-10360	PFNA	EPA 537	<		0.02	ppb	MD

MD0120016	Harford County DPW	3	Abingdon Filter Plant	SW	WTP POE	EP	12/2/2013	760947-10360	PFBS	EPA 537	<		0.09	ppb	MD
MD0120016	Harford County DPW	3	Abingdon Filter Plant	SW	WTP POE	EP	12/2/2013	760947-10360	PFHpA	EPA 537	<		0.01	ppb	MD
MD0120016	Harford County DPW	3	Abingdon Filter Plant	SW	WTP POE	EP	12/2/2013	760947-10360	PFHxS	EPA 537	<		0.03	ppb	MD
MD0130002	Howard County DPW Distribution	1	Baltimore City Water Intertie	SW	EPTDS from E	EP	1/28/2015	K1501015-001AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0130002	Howard County DPW Distribution	1	Baltimore City Water Intertie	SW	EPTDS from E	EP	1/28/2015	K1501015-001AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0130002	Howard County DPW Distribution	1	Baltimore City Water Intertie	SW	EPTDS from E	EP	1/28/2015	K1501015-001AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0130002	Howard County DPW Distribution	1	Baltimore City Water Intertie	SW	EPTDS from E	EP	1/28/2015	K1501015-001AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0130002	Howard County DPW Distribution	1	Baltimore City Water Intertie	SW	EPTDS from E	EP	1/28/2015	K1501015-001AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0130002	Howard County DPW Distribution	1	Baltimore City Water Intertie	SW	EPTDS from E	EP	1/28/2015	K1501015-001AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0130002	Howard County DPW Distribution	1	Baltimore City Water Intertie	SW	EPTDS from E	EP	4/23/2015	K1504454-001AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0130002	Howard County DPW Distribution	1	Baltimore City Water Intertie	SW	EPTDS from E	EP	4/23/2015	K1504454-001AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0130002	Howard County DPW Distribution	1	Baltimore City Water Intertie	SW	EPTDS from E	EP	4/23/2015	K1504454-001AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0130002	Howard County DPW Distribution	1	Baltimore City Water Intertie	SW	EPTDS from E	EP	4/23/2015	K1504454-001AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0130002	Howard County DPW Distribution	1	Baltimore City Water Intertie	SW	EPTDS from E	EP	4/23/2015	K1504454-001AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0130002	Howard County DPW Distribution	1	Baltimore City Water Intertie	SW	EPTDS from E	EP	4/23/2015	K1504454-001AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0130002	Howard County DPW Distribution	1	Baltimore City Water Intertie	SW	EPTDS from E	EP	7/30/2015	K1508447-003AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0130002	Howard County DPW Distribution	1	Baltimore City Water Intertie	SW	EPTDS from E	EP	7/30/2015	K1508447-003AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0130002	Howard County DPW Distribution	1	Baltimore City Water Intertie	SW	EPTDS from E	EP	7/30/2015	K1508447-003AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0130002	Howard County DPW Distribution	1	Baltimore City Water Intertie	SW	EPTDS from E	EP	7/30/2015	K1508447-003AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0130002	Howard County DPW Distribution	1	Baltimore City Water Intertie	SW	EPTDS from E	EP	7/30/2015	K1508447-003AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0130002	Howard County DPW Distribution	1	Baltimore City Water Intertie	SW	EPTDS from E	EP	7/30/2015	K1508447-003AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0130002	Howard County DPW Distribution	1	Baltimore City Water Intertie	SW	EPTDS from E	EP	10/29/2015	K1512626-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0130002	Howard County DPW Distribution	1	Baltimore City Water Intertie	SW	EPTDS from E	EP	10/29/2015	K1512626-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0130002	Howard County DPW Distribution	1	Baltimore City Water Intertie	SW	EPTDS from E	EP	10/29/2015	K1512626-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0130002	Howard County DPW Distribution	1	Baltimore City Water Intertie	SW	EPTDS from E	EP	10/29/2015	K1512626-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0130002	Howard County DPW Distribution	1	Baltimore City Water Intertie	SW	EPTDS from E	EP	10/29/2015	K1512626-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0130002	Howard County DPW Distribution	1	Baltimore City Water Intertie	SW	EPTDS from E	EP	10/29/2015	K1512626-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0130002	Howard County DPW Distribution	2	WSSC	SW	EPFWSSC	EP	1/28/2015	K1501022-001AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0130002	Howard County DPW Distribution	2	WSSC	SW	EPFWSSC	EP	1/28/2015	K1501022-001AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0130002	Howard County DPW Distribution	2	WSSC	SW	EPFWSSC	EP	1/28/2015	K1501022-001AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0130002	Howard County DPW Distribution	2	WSSC	SW	EPFWSSC	EP	1/28/2015	K1501022-001AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0130002	Howard County DPW Distribution	2	WSSC	SW	EPFWSSC	EP	1/28/2015	K1501022-001AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0130002	Howard County DPW Distribution	2	WSSC	SW	EPFWSSC	EP	1/28/2015	K1501022-001AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0130002	Howard County DPW Distribution	2	WSSC	SW	EPFWSSC	EP	4/23/2015	K1504456-001AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0130002	Howard County DPW Distribution	2	WSSC	SW	EPFWSSC	EP	4/23/2015	K1504456-001AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0130002	Howard County DPW Distribution	2	WSSC	SW	EPFWSSC	EP	4/23/2015	K1504456-001AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0130002	Howard County DPW Distribution	2	WSSC	SW	EPFWSSC	EP	4/23/2015	K1504456-001AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0130002	Howard County DPW Distribution	2	WSSC	SW	EPFWSSC	EP	4/23/2015	K1504456-001AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0130002	Howard County DPW Distribution	2	WSSC	SW	EPFWSSC	EP	4/23/2015	K1504456-001AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0130002	Howard County DPW Distribution	2	WSSC	SW	EPFWSSC	EP	7/29/2015	K1508447-001AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0130002	Howard County DPW Distribution	2	WSSC	SW	EPFWSSC	EP	7/29/2015	K1508447-001AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0130002	Howard County DPW Distribution	2	WSSC	SW	EPFWSSC	EP	7/29/2015	K1508447-001AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0130002	Howard County DPW Distribution	2	WSSC	SW	EPFWSSC	EP	7/29/2015	K1508447-001AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0130002	Howard County DPW Distribution	2	WSSC	SW	EPFWSSC	EP	7/29/2015	K1508447-001AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0130002	Howard County DPW Distribution	2	WSSC	SW	EPFWSSC	EP	7/29/2015	K1508447-001AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0130002	Howard County DPW Distribution	2	WSSC	SW	EPFWSSC	EP	10/29/2015	K1512623-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0130002	Howard County DPW Distribution	2	WSSC	SW	EPFWSSC	EP	10/29/2015	K1512623-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0130002	Howard County DPW Distribution	2	WSSC	SW	EPFWSSC	EP	10/29/2015	K1512623-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0130002	Howard County DPW Distribution	2	WSSC	SW	EPFWSSC	EP	10/29/2015	K1512623-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0130002	Howard County DPW Distribution	2	WSSC	SW	EPFWSSC	EP	10/29/2015	K1512623-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0130002	Howard County DPW Distribution	2	WSSC	SW	EPFWSSC	EP	10/29/2015	K1512623-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0150003	City of Rockville	1	Potomac Filter Plant	SW	WTP POE	EP	3/18/2014	K1402843-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0150003	City of Rockville	1	Potomac Filter Plant	SW	WTP POE	EP	3/18/2014	K1402843-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0150003	City of Rockville	1	Potomac Filter Plant	SW	WTP POE	EP	3/18/2014	K1402843-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0150003	City of Rockville	1	Potomac Filter Plant	SW	WTP POE	EP	3/18/2014	K1402843-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0150003	City of Rockville	1	Potomac Filter Plant	SW	WTP POE	EP	3/18/2014	K1402843-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0150003	City of Rockville	1	Potomac Filter Plant	SW	WTP POE	EP	3/18/2014	K1402843-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0150003	City of Rockville	1	Potomac Filter Plant	SW	WTP POE	EP	6/10/2014	K1405960-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0150003	City of Rockville	1	Potomac Filter Plant	SW	WTP POE	EP	6/10/2014	K1405960-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0150003	City of Rockville	1	Potomac Filter Plant	SW	WTP POE	EP	6/10/2014	K1405960-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0150003	City of Rockville	1	Potomac Filter Plant	SW	WTP POE	EP	6/10/2014	K1405960-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0150003	City of Rockville	1	Potomac Filter Plant	SW	WTP POE	EP	6/10/2014	K1405960-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0150003	City of Rockville	1	Potomac Filter Plant	SW	WTP POE	EP	6/10/2014	K1405960-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0150003	City of Rockville	1	Potomac Filter Plant	SW	WTP POE	EP	9/10/2014	K1409918-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0150003	City of Rockville	1	Potomac Filter Plant	SW	WTP POE	EP	9/10/2014	K1409918-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0150003	City of Rockville	1	Potomac Filter Plant	SW	WTP POE	EP	9/10/2014	K1409918-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0150003	City of Rockville	1	Potomac Filter Plant	SW	WTP POE	EP	9/10/2014	K1409918-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0150003	City of Rockville	1	Potomac Filter Plant	SW	WTP POE	EP	9/10/2014	K1409918-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0150003	City of Rockville	1	Potomac Filter Plant	SW	WTP POE	EP	9/10/2014	K1409918-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0150003	City of Rockville	1	Potomac Filter Plant	SW	WTP POE	EP	12/9/2014	K1413883-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0150003	City of Rockville	1	Potomac Filter Plant	SW	WTP POE	EP	12/9/2014	K1413883-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0150003	City of Rockville	1	Potomac Filter Plant	SW	WTP POE	EP	12/9/2014	K1413883-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0150003	City of Rockville	1	Potomac Filter Plant	SW	WTP POE	EP	12/9/2014	K1413883-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0150003	City of Rockville	1	Potomac Filter Plant	SW	WTP POE	EP	12/9/2014	K1413883-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0150003	City of Rockville	1	Potomac Filter Plant	SW	WTP POE	EP	12/9/2014	K1413883-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	1	Potomac Filter Plant	SW	WTP POE	EP	7/15/2013	201307160497AM	PFNA	EPA 537	<		0.02	ppb	MD

MD0150005	Washington Suburban Sanitary Commission	1	Potomac Filter Plant	SW	WTP POE	EP	7/15/2013	201307160497AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	1	Potomac Filter Plant	SW	WTP POE	EP	7/15/2013	201307160497AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	1	Potomac Filter Plant	SW	WTP POE	EP	7/15/2013	201307160497AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	1	Potomac Filter Plant	SW	WTP POE	EP	7/15/2013	201307160497AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	1	Potomac Filter Plant	SW	WTP POE	EP	7/15/2013	201307160497AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	1	Potomac Filter Plant	SW	WTP POE	EP	10/21/2013	201310220211AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	1	Potomac Filter Plant	SW	WTP POE	EP	10/21/2013	201310220211AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	1	Potomac Filter Plant	SW	WTP POE	EP	10/21/2013	201310220211AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	1	Potomac Filter Plant	SW	WTP POE	EP	10/21/2013	201310220211AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	1	Potomac Filter Plant	SW	WTP POE	EP	10/21/2013	201310220211AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	1	Potomac Filter Plant	SW	WTP POE	EP	10/21/2013	201310220211AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	1	Potomac Filter Plant	SW	WTP POE	EP	1/21/2014	201401220119AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	1	Potomac Filter Plant	SW	WTP POE	EP	1/21/2014	201401220119AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	1	Potomac Filter Plant	SW	WTP POE	EP	1/21/2014	201401220119AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	1	Potomac Filter Plant	SW	WTP POE	EP	1/21/2014	201401220119AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	1	Potomac Filter Plant	SW	WTP POE	EP	1/21/2014	201401220119AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	1	Potomac Filter Plant	SW	WTP POE	EP	1/21/2014	201401220119AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	1	Potomac Filter Plant	SW	WTP POE	EP	4/14/2014	201404150437AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	1	Potomac Filter Plant	SW	WTP POE	EP	4/14/2014	201404150437AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	1	Potomac Filter Plant	SW	WTP POE	EP	4/14/2014	201404150437AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	1	Potomac Filter Plant	SW	WTP POE	EP	4/14/2014	201404150437AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	1	Potomac Filter Plant	SW	WTP POE	EP	4/14/2014	201404150437AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	1	Potomac Filter Plant	SW	WTP POE	EP	4/14/2014	201404150437AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	2	Patuxent Filter Plant	SW	WTP POE	EP	7/15/2013	201307160419AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	2	Patuxent Filter Plant	SW	WTP POE	EP	7/15/2013	201307160419AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	2	Patuxent Filter Plant	SW	WTP POE	EP	7/15/2013	201307160419AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	2	Patuxent Filter Plant	SW	WTP POE	EP	7/15/2013	201307160419AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	2	Patuxent Filter Plant	SW	WTP POE	EP	7/15/2013	201307160419AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	2	Patuxent Filter Plant	SW	WTP POE	EP	7/15/2013	201307160419AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	2	Patuxent Filter Plant	SW	WTP POE	EP	10/21/2013	201310220261AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	2	Patuxent Filter Plant	SW	WTP POE	EP	10/21/2013	201310220261AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	2	Patuxent Filter Plant	SW	WTP POE	EP	10/21/2013	201310220261AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	2	Patuxent Filter Plant	SW	WTP POE	EP	10/21/2013	201310220261AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	2	Patuxent Filter Plant	SW	WTP POE	EP	10/21/2013	201310220261AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	2	Patuxent Filter Plant	SW	WTP POE	EP	10/21/2013	201310220261AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	2	Patuxent Filter Plant	SW	WTP POE	EP	1/21/2014	201401220157AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	2	Patuxent Filter Plant	SW	WTP POE	EP	1/21/2014	201401220157AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	2	Patuxent Filter Plant	SW	WTP POE	EP	1/21/2014	201401220157AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	2	Patuxent Filter Plant	SW	WTP POE	EP	1/21/2014	201401220157AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	2	Patuxent Filter Plant	SW	WTP POE	EP	1/21/2014	201401220157AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	2	Patuxent Filter Plant	SW	WTP POE	EP	1/21/2014	201401220157AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	2	Patuxent Filter Plant	SW	WTP POE	EP	4/14/2014	201404150446AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	2	Patuxent Filter Plant	SW	WTP POE	EP	4/14/2014	201404150446AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	2	Patuxent Filter Plant	SW	WTP POE	EP	4/14/2014	201404150446AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	2	Patuxent Filter Plant	SW	WTP POE	EP	4/14/2014	201404150446AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	2	Patuxent Filter Plant	SW	WTP POE	EP	4/14/2014	201404150446AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0150005	Washington Suburban Sanitary Commission	2	Patuxent Filter Plant	SW	WTP POE	EP	4/14/2014	201404150446AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0160002	Bowie	1	Bowie WTP for Wells	GW	WTP POE	EP	3/4/2013	707722-8270	PFOS	EPA 537	<		0.04	ppb	MD
MD0160002	Bowie	1	Bowie WTP for Wells	GW	WTP POE	EP	3/4/2013	707722-8270	PFHxS	EPA 537	<		0.03	ppb	MD
MD0160002	Bowie	1	Bowie WTP for Wells	GW	WTP POE	EP	3/4/2013	707722-8270	PFHpA	EPA 537	<		0.01	ppb	MD
MD0160002	Bowie	1	Bowie WTP for Wells	GW	WTP POE	EP	3/4/2013	707722-8270	PFBS	EPA 537	<		0.09	ppb	MD
MD0160002	Bowie	1	Bowie WTP for Wells	GW	WTP POE	EP	3/4/2013	707722-8270	PFNA	EPA 537	<		0.02	ppb	MD
MD0160002	Bowie	1	Bowie WTP for Wells	GW	WTP POE	EP	3/4/2013	707722-8270	PFOA	EPA 537	<		0.02	ppb	MD
MD0160002	Bowie	1	Bowie WTP for Wells	GW	WTP POE	EP	9/11/2013	744317-9733	PFOS	EPA 537	<		0.04	ppb	MD
MD0160002	Bowie	1	Bowie WTP for Wells	GW	WTP POE	EP	9/11/2013	744317-9733	PFHpA	EPA 537	<		0.01	ppb	MD
MD0160002	Bowie	1	Bowie WTP for Wells	GW	WTP POE	EP	9/11/2013	744317-9733	PFOA	EPA 537	<		0.02	ppb	MD
MD0160002	Bowie	1	Bowie WTP for Wells	GW	WTP POE	EP	9/11/2013	744317-9733	PFNA	EPA 537	<		0.02	ppb	MD
MD0160002	Bowie	1	Bowie WTP for Wells	GW	WTP POE	EP	9/11/2013	744317-9733	PFHxS	EPA 537	<		0.03	ppb	MD
MD0160002	Bowie	1	Bowie WTP for Wells	GW	WTP POE	EP	9/11/2013	744317-9733	PFBS	EPA 537	<		0.09	ppb	MD
MD0180007	Lexington Park	5	Town Creek 3	GW	WTP POE	EP	2/27/2015	35177878001AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0180007	Lexington Park	5	Town Creek 3	GW	WTP POE	EP	2/27/2015	35177878001AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0180007	Lexington Park	5	Town Creek 3	GW	WTP POE	EP	2/27/2015	35177878001AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0180007	Lexington Park	5	Town Creek 3	GW	WTP POE	EP	2/27/2015	35177878001AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0180007	Lexington Park	5	Town Creek 3	GW	WTP POE	EP	2/27/2015	35177878001AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0180007	Lexington Park	5	Town Creek 3	GW	WTP POE	EP	2/27/2015	35177878001AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0180007	Lexington Park	5	Town Creek 3	GW	WTP POE	EP	8/26/2015	35205363001AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0180007	Lexington Park	5	Town Creek 3	GW	WTP POE	EP	8/26/2015	35205363001AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0180007	Lexington Park	5	Town Creek 3	GW	WTP POE	EP	8/26/2015	35205363001AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0180007	Lexington Park	5	Town Creek 3	GW	WTP POE	EP	8/26/2015	35205363001AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0180007	Lexington Park	5	Town Creek 3	GW	WTP POE	EP	8/26/2015	35205363001AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0180007	Lexington Park	5	Town Creek 3	GW	WTP POE	EP	8/26/2015	35205363001AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0180007	Lexington Park	12	Wildewood 1	GW	WTP POE	EP	4/13/2015	35184391003AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0180007	Lexington Park	12	Wildewood 1	GW	WTP POE	EP	4/13/2015	35184391003AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0180007	Lexington Park	12	Wildewood 1	GW	WTP POE	EP	4/13/2015	35184391003AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0180007	Lexington Park	12	Wildewood 1	GW	WTP POE	EP	4/13/2015	35184391003AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0180007	Lexington Park	12	Wildewood 1	GW	WTP POE	EP	4/13/2015	35184391003AM	PFHxS	EPA 537	<		0.03	ppb	MD

MD0180007	Lexington Park	12	Wildewood 1	GW	WTP POE	EP	4/13/2015	35184391003AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0180007	Lexington Park	12	Wildewood 1	GW	WTP POE	EP	8/26/2015	35205363003AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0180007	Lexington Park	12	Wildewood 1	GW	WTP POE	EP	8/26/2015	35205363003AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0180007	Lexington Park	12	Wildewood 1	GW	WTP POE	EP	8/26/2015	35205363003AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0180007	Lexington Park	12	Wildewood 1	GW	WTP POE	EP	8/26/2015	35205363003AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0180007	Lexington Park	12	Wildewood 1	GW	WTP POE	EP	8/26/2015	35205363003AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0180007	Lexington Park	12	Wildewood 1	GW	WTP POE	EP	8/26/2015	35205363003AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0180007	Lexington Park	22	First Colony	GW	WTP POE	EP	4/13/2015	35184391005AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0180007	Lexington Park	22	First Colony	GW	WTP POE	EP	4/13/2015	35184391005AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0180007	Lexington Park	22	First Colony	GW	WTP POE	EP	4/13/2015	35184391005AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0180007	Lexington Park	22	First Colony	GW	WTP POE	EP	4/13/2015	35184391005AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0180007	Lexington Park	22	First Colony	GW	WTP POE	EP	4/13/2015	35184391005AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0180007	Lexington Park	22	First Colony	GW	WTP POE	EP	4/13/2015	35184391005AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0180007	Lexington Park	22	First Colony	GW	WTP POE	EP	8/26/2015	35205363005AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0180007	Lexington Park	22	First Colony	GW	WTP POE	EP	8/26/2015	35205363005AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0180007	Lexington Park	22	First Colony	GW	WTP POE	EP	8/26/2015	35205363005AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0180007	Lexington Park	22	First Colony	GW	WTP POE	EP	8/26/2015	35205363005AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0180007	Lexington Park	22	First Colony	GW	WTP POE	EP	8/26/2015	35205363005AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0180007	Lexington Park	22	First Colony	GW	WTP POE	EP	8/26/2015	35205363005AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	1	Pump Station A (Wells 522 & 524)	GW	WTP POE	EP	12/15/2014	35168731001AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	1	Pump Station A (Wells 522 & 524)	GW	WTP POE	EP	12/15/2014	35168731001AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	1	Pump Station A (Wells 522 & 524)	GW	WTP POE	EP	12/15/2014	35168731001AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	1	Pump Station A (Wells 522 & 524)	GW	WTP POE	EP	12/15/2014	35168731001AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	1	Pump Station A (Wells 522 & 524)	GW	WTP POE	EP	12/15/2014	35168731001AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	1	Pump Station A (Wells 522 & 524)	GW	WTP POE	EP	12/15/2014	35168731001AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	1	Pump Station A (Wells 522 & 524)	GW	WTP POE	EP	6/30/2015	35195985001AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	1	Pump Station A (Wells 522 & 524)	GW	WTP POE	EP	6/30/2015	35195985001AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	1	Pump Station A (Wells 522 & 524)	GW	WTP POE	EP	6/30/2015	35195985001AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	1	Pump Station A (Wells 522 & 524)	GW	WTP POE	EP	6/30/2015	35195985001AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	1	Pump Station A (Wells 522 & 524)	GW	WTP POE	EP	6/30/2015	35195985001AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	1	Pump Station A (Wells 522 & 524)	GW	WTP POE	EP	6/30/2015	35195985001AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	2	Building 526 (Wells 530, 531 & 2276)	GW	WTP POE	EP	12/15/2014	35168731003AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	2	Building 526 (Wells 530, 531 & 2276)	GW	WTP POE	EP	12/15/2014	35168731003AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	2	Building 526 (Wells 530, 531 & 2276)	GW	WTP POE	EP	12/15/2014	35168731003AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	2	Building 526 (Wells 530, 531 & 2276)	GW	WTP POE	EP	12/15/2014	35168731003AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	2	Building 526 (Wells 530, 531 & 2276)	GW	WTP POE	EP	12/15/2014	35168731003AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	2	Building 526 (Wells 530, 531 & 2276)	GW	WTP POE	EP	12/15/2014	35168731003AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	2	Building 526 (Wells 530, 531 & 2276)	GW	WTP POE	EP	6/30/2015	35195985003AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	2	Building 526 (Wells 530, 531 & 2276)	GW	WTP POE	EP	6/30/2015	35195985003AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	2	Building 526 (Wells 530, 531 & 2276)	GW	WTP POE	EP	6/30/2015	35195985003AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	2	Building 526 (Wells 530, 531 & 2276)	GW	WTP POE	EP	6/30/2015	35195985003AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	2	Building 526 (Wells 530, 531 & 2276)	GW	WTP POE	EP	6/30/2015	35195985003AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	2	Building 526 (Wells 530, 531 & 2276)	GW	WTP POE	EP	6/30/2015	35195985003AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	3	Building 574 (Well 3A)	GW	WTP POE	EP	12/15/2014	35168731005AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	3	Building 574 (Well 3A)	GW	WTP POE	EP	12/15/2014	35168731005AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	3	Building 574 (Well 3A)	GW	WTP POE	EP	12/15/2014	35168731005AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	3	Building 574 (Well 3A)	GW	WTP POE	EP	12/15/2014	35168731005AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	3	Building 574 (Well 3A)	GW	WTP POE	EP	12/15/2014	35168731005AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	3	Building 574 (Well 3A)	GW	WTP POE	EP	12/15/2014	35168731005AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	3	Building 574 (Well 3A)	GW	WTP POE	EP	6/30/2015	35195985005AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	3	Building 574 (Well 3A)	GW	WTP POE	EP	6/30/2015	35195985005AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	3	Building 574 (Well 3A)	GW	WTP POE	EP	6/30/2015	35195985005AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	3	Building 574 (Well 3A)	GW	WTP POE	EP	6/30/2015	35195985005AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	3	Building 574 (Well 3A)	GW	WTP POE	EP	6/30/2015	35195985005AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	3	Building 574 (Well 3A)	GW	WTP POE	EP	6/30/2015	35195985005AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	4	Building 528 (1C, 2C & 4C)	GW	WTP POE	EP	12/15/2014	35168731007AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	4	Building 528 (1C, 2C & 4C)	GW	WTP POE	EP	12/15/2014	35168731007AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	4	Building 528 (1C, 2C & 4C)	GW	WTP POE	EP	12/15/2014	35168731007AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	4	Building 528 (1C, 2C & 4C)	GW	WTP POE	EP	12/15/2014	35168731007AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	4	Building 528 (1C, 2C & 4C)	GW	WTP POE	EP	12/15/2014	35168731007AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	4	Building 528 (1C, 2C & 4C)	GW	WTP POE	EP	12/15/2014	35168731007AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	4	Building 528 (1C, 2C & 4C)	GW	WTP POE	EP	6/30/2015	35195985007AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	4	Building 528 (1C, 2C & 4C)	GW	WTP POE	EP	6/30/2015	35195985007AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	4	Building 528 (1C, 2C & 4C)	GW	WTP POE	EP	6/30/2015	35195985007AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	4	Building 528 (1C, 2C & 4C)	GW	WTP POE	EP	6/30/2015	35195985007AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	4	Building 528 (1C, 2C & 4C)	GW	WTP POE	EP	6/30/2015	35195985007AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	4	Building 528 (1C, 2C & 4C)	GW	WTP POE	EP	6/30/2015	35195985007AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	15	Building 583 (Well 3C)	GW	WTP POE	EP	12/15/2014	35168731009AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	15	Building 583 (Well 3C)	GW	WTP POE	EP	12/15/2014	35168731009AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	15	Building 583 (Well 3C)	GW	WTP POE	EP	12/15/2014	35168731009AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	15	Building 583 (Well 3C)	GW	WTP POE	EP	12/15/2014	35168731009AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	15	Building 583 (Well 3C)	GW	WTP POE	EP	12/15/2014	35168731009AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	15	Building 583 (Well 3C)	GW	WTP POE	EP	12/15/2014	35168731009AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	15	Building 583 (Well 3C)	GW	WTP POE	EP	6/30/2015	35195985009AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	15	Building 583 (Well 3C)	GW	WTP POE	EP	6/30/2015	35195985009AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	15	Building 583 (Well 3C)	GW	WTP POE	EP	6/30/2015	35195985009AM	PFBS	EPA 537	<		0.09	ppb	MD

MD0180022	Patuxent Naval Air Station (NAWCAD)	15	Building 583 (Well 3C)	GW	WTP POE	EP	6/30/2015	35195985009AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	15	Building 583 (Well 3C)	GW	WTP POE	EP	6/30/2015	35195985009AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	15	Building 583 (Well 3C)	GW	WTP POE	EP	6/30/2015	35195985009AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	16	Building 587 (Well 5A)	GW	WTP POE	EP	12/15/2014	35168731011AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	16	Building 587 (Well 5A)	GW	WTP POE	EP	12/15/2014	35168731011AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	16	Building 587 (Well 5A)	GW	WTP POE	EP	12/15/2014	35168731011AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	16	Building 587 (Well 5A)	GW	WTP POE	EP	12/15/2014	35168731011AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	16	Building 587 (Well 5A)	GW	WTP POE	EP	12/15/2014	35168731011AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	16	Building 587 (Well 5A)	GW	WTP POE	EP	12/15/2014	35168731011AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	16	Building 587 (Well 5A)	GW	WTP POE	EP	6/30/2015	35195985011AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	16	Building 587 (Well 5A)	GW	WTP POE	EP	6/30/2015	35195985011AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	16	Building 587 (Well 5A)	GW	WTP POE	EP	6/30/2015	35195985011AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	16	Building 587 (Well 5A)	GW	WTP POE	EP	6/30/2015	35195985011AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	16	Building 587 (Well 5A)	GW	WTP POE	EP	6/30/2015	35195985011AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	16	Building 587 (Well 5A)	GW	WTP POE	EP	6/30/2015	35195985011AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	17	Building 527 (Well 6B)	GW	WTP POE	EP	12/15/2014	35168731013AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	17	Building 527 (Well 6B)	GW	WTP POE	EP	12/15/2014	35168731013AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	17	Building 527 (Well 6B)	GW	WTP POE	EP	12/15/2014	35168731013AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	17	Building 527 (Well 6B)	GW	WTP POE	EP	12/15/2014	35168731013AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	17	Building 527 (Well 6B)	GW	WTP POE	EP	12/15/2014	35168731013AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	17	Building 527 (Well 6B)	GW	WTP POE	EP	12/15/2014	35168731013AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	17	Building 527 (Well 6B)	GW	WTP POE	EP	6/29/2016	35252205005AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	17	Building 527 (Well 6B)	GW	WTP POE	EP	6/29/2016	35252205005AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	17	Building 527 (Well 6B)	GW	WTP POE	EP	6/29/2016	35252205005AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	17	Building 527 (Well 6B)	GW	WTP POE	EP	6/29/2016	35252205005AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	17	Building 527 (Well 6B)	GW	WTP POE	EP	6/29/2016	35252205005AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	17	Building 527 (Well 6B)	GW	WTP POE	EP	6/29/2016	35252205005AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	18	Building 532 (Well 532B - 1P)	GW	WTP POE	EP	12/15/2014	35168731015AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	18	Building 532 (Well 532B - 1P)	GW	WTP POE	EP	12/15/2014	35168731015AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	18	Building 532 (Well 532B - 1P)	GW	WTP POE	EP	12/15/2014	35168731015AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	18	Building 532 (Well 532B - 1P)	GW	WTP POE	EP	12/15/2014	35168731015AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	18	Building 532 (Well 532B - 1P)	GW	WTP POE	EP	12/15/2014	35168731015AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	18	Building 532 (Well 532B - 1P)	GW	WTP POE	EP	12/15/2014	35168731015AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	18	Building 532 (Well 532B - 1P)	GW	WTP POE	EP	6/29/2016	35252205001AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	18	Building 532 (Well 532B - 1P)	GW	WTP POE	EP	6/29/2016	35252205001AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	18	Building 532 (Well 532B - 1P)	GW	WTP POE	EP	6/29/2016	35252205001AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	18	Building 532 (Well 532B - 1P)	GW	WTP POE	EP	6/29/2016	35252205001AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	18	Building 532 (Well 532B - 1P)	GW	WTP POE	EP	6/29/2016	35252205001AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	18	Building 532 (Well 532B - 1P)	GW	WTP POE	EP	6/29/2016	35252205001AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	19	Building 584 (Well 4A)	GW	WTP POE	EP	12/15/2014	35168731017AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	19	Building 584 (Well 4A)	GW	WTP POE	EP	12/15/2014	35168731017AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	19	Building 584 (Well 4A)	GW	WTP POE	EP	12/15/2014	35168731017AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	19	Building 584 (Well 4A)	GW	WTP POE	EP	12/15/2014	35168731017AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	19	Building 584 (Well 4A)	GW	WTP POE	EP	12/15/2014	35168731017AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	19	Building 584 (Well 4A)	GW	WTP POE	EP	12/15/2014	35168731017AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	19	Building 584 (Well 4A)	GW	WTP POE	EP	6/30/2015	35195985013AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	19	Building 584 (Well 4A)	GW	WTP POE	EP	6/30/2015	35195985013AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	19	Building 584 (Well 4A)	GW	WTP POE	EP	6/30/2015	35195985013AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	19	Building 584 (Well 4A)	GW	WTP POE	EP	6/30/2015	35195985013AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	19	Building 584 (Well 4A)	GW	WTP POE	EP	6/30/2015	35195985013AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	19	Building 584 (Well 4A)	GW	WTP POE	EP	6/30/2015	35195985013AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	21	Building 529 (Well 1B)	GW	WTP POE	EP	12/15/2014	35168731019AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	21	Building 529 (Well 1B)	GW	WTP POE	EP	12/15/2014	35168731019AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	21	Building 529 (Well 1B)	GW	WTP POE	EP	12/15/2014	35168731019AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	21	Building 529 (Well 1B)	GW	WTP POE	EP	12/15/2014	35168731019AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	21	Building 529 (Well 1B)	GW	WTP POE	EP	12/15/2014	35168731019AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	21	Building 529 (Well 1B)	GW	WTP POE	EP	12/15/2014	35168731019AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	21	Building 529 (Well 1B)	GW	WTP POE	EP	6/30/2015	35195985015AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	21	Building 529 (Well 1B)	GW	WTP POE	EP	6/30/2015	35195985015AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	21	Building 529 (Well 1B)	GW	WTP POE	EP	6/30/2015	35195985015AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	21	Building 529 (Well 1B)	GW	WTP POE	EP	6/30/2015	35195985015AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	21	Building 529 (Well 1B)	GW	WTP POE	EP	6/30/2015	35195985015AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0180022	Patuxent Naval Air Station (NAWCAD)	21	Building 529 (Well 1B)	GW	WTP POE	EP	6/30/2015	35195985015AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0200003	Easton Utilities	1	Electric Plant (Well 6)	GW	WTP POE	EP	1/7/2014	1401145-001E	PFNA	EPA 537	<		0.02	ppb	MD
MD0200003	Easton Utilities	1	Electric Plant (Well 6)	GW	WTP POE	EP	1/7/2014	1401145-001E	PFHxS	EPA 537	<		0.03	ppb	MD
MD0200003	Easton Utilities	1	Electric Plant (Well 6)	GW	WTP POE	EP	1/7/2014	1401145-001E	PFOA	EPA 537	<		0.02	ppb	MD
MD0200003	Easton Utilities	1	Electric Plant (Well 6)	GW	WTP POE	EP	1/7/2014	1401145-001E	PFBS	EPA 537	<		0.09	ppb	MD
MD0200003	Easton Utilities	1	Electric Plant (Well 6)	GW	WTP POE	EP	1/7/2014	1401145-001E	PFOS	EPA 537	<		0.04	ppb	MD
MD0200003	Easton Utilities	1	Electric Plant (Well 6)	GW	WTP POE	EP	1/7/2014	1401145-001E	PFHpA	EPA 537	<		0.01	ppb	MD
MD0200003	Easton Utilities	1	Electric Plant (Well 6)	GW	WTP POE	EP	7/14/2014	1407512-001E	PFOS	EPA 537	<		0.04	ppb	MD
MD0200003	Easton Utilities	1	Electric Plant (Well 6)	GW	WTP POE	EP	7/14/2014	1407512-001E	PFOA	EPA 537	<		0.02	ppb	MD
MD0200003	Easton Utilities	1	Electric Plant (Well 6)	GW	WTP POE	EP	7/14/2014	1407512-001E	PFHxS	EPA 537	<		0.03	ppb	MD
MD0200003	Easton Utilities	1	Electric Plant (Well 6)	GW	WTP POE	EP	7/14/2014	1407512-001E	PFHpA	EPA 537	<		0.01	ppb	MD
MD0200003	Easton Utilities	1	Electric Plant (Well 6)	GW	WTP POE	EP	7/14/2014	1407512-001E	PFNA	EPA 537	<		0.02	ppb	MD
MD0200003	Easton Utilities	1	Electric Plant (Well 6)	GW	WTP POE	EP	7/14/2014	1407512-001E	PFBS	EPA 537	<		0.09	ppb	MD
MD0200003	Easton Utilities	5	Glebe WTP (Wells 11 & 12)	GW	WTP POE	EP	1/7/2014	1401146-001F	PFBS	EPA 537	<		0.09	ppb	MD

MD0200003	Easton Utilities	5	Glebe WTP (Wells 11 & 12)	GW	WTP POE	EP	1/7/2014	1401146-001F	PFOS	EPA 537	<		0.04	ppb	MD
MD0200003	Easton Utilities	5	Glebe WTP (Wells 11 & 12)	GW	WTP POE	EP	1/7/2014	1401146-001F	PFOA	EPA 537	<		0.02	ppb	MD
MD0200003	Easton Utilities	5	Glebe WTP (Wells 11 & 12)	GW	WTP POE	EP	1/7/2014	1401146-001F	PFNA	EPA 537	<		0.02	ppb	MD
MD0200003	Easton Utilities	5	Glebe WTP (Wells 11 & 12)	GW	WTP POE	EP	1/7/2014	1401146-001F	PFHpA	EPA 537	<		0.01	ppb	MD
MD0200003	Easton Utilities	5	Glebe WTP (Wells 11 & 12)	GW	WTP POE	EP	1/7/2014	1401146-001F	PFHxS	EPA 537	<		0.03	ppb	MD
MD0200003	Easton Utilities	5	Glebe WTP (Wells 11 & 12)	GW	WTP POE	EP	7/14/2014	1407513-001F	PFNA	EPA 537	<		0.02	ppb	MD
MD0200003	Easton Utilities	5	Glebe WTP (Wells 11 & 12)	GW	WTP POE	EP	7/14/2014	1407513-001F	PFOA	EPA 537	<		0.02	ppb	MD
MD0200003	Easton Utilities	5	Glebe WTP (Wells 11 & 12)	GW	WTP POE	EP	7/14/2014	1407513-001F	PFHpA	EPA 537	<		0.01	ppb	MD
MD0200003	Easton Utilities	5	Glebe WTP (Wells 11 & 12)	GW	WTP POE	EP	7/14/2014	1407513-001F	PFHxS	EPA 537	<		0.03	ppb	MD
MD0200003	Easton Utilities	5	Glebe WTP (Wells 11 & 12)	GW	WTP POE	EP	7/14/2014	1407513-001F	PFBS	EPA 537	<		0.09	ppb	MD
MD0200003	Easton Utilities	5	Glebe WTP (Wells 11 & 12)	GW	WTP POE	EP	7/14/2014	1407513-001F	PFOS	EPA 537	<		0.04	ppb	MD
MD0210010	City of Hagerstown	1	R.C. Willson Filter Plant	SW	WTP POE	EP	8/7/2013	K1308154-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0210010	City of Hagerstown	1	R.C. Willson Filter Plant	SW	WTP POE	EP	8/7/2013	K1308154-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0210010	City of Hagerstown	1	R.C. Willson Filter Plant	SW	WTP POE	EP	8/7/2013	K1308154-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0210010	City of Hagerstown	1	R.C. Willson Filter Plant	SW	WTP POE	EP	8/7/2013	K1308154-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0210010	City of Hagerstown	1	R.C. Willson Filter Plant	SW	WTP POE	EP	8/7/2013	K1308154-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0210010	City of Hagerstown	1	R.C. Willson Filter Plant	SW	WTP POE	EP	8/7/2013	K1308154-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0210010	City of Hagerstown	1	R.C. Willson Filter Plant	SW	WTP POE	EP	11/19/2013	K1313001-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0210010	City of Hagerstown	1	R.C. Willson Filter Plant	SW	WTP POE	EP	11/19/2013	K1313001-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0210010	City of Hagerstown	1	R.C. Willson Filter Plant	SW	WTP POE	EP	11/19/2013	K1313001-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0210010	City of Hagerstown	1	R.C. Willson Filter Plant	SW	WTP POE	EP	11/19/2013	K1313001-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0210010	City of Hagerstown	1	R.C. Willson Filter Plant	SW	WTP POE	EP	11/19/2013	K1313001-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0210010	City of Hagerstown	1	R.C. Willson Filter Plant	SW	WTP POE	EP	11/19/2013	K1313001-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0210010	City of Hagerstown	1	R.C. Willson Filter Plant	SW	WTP POE	EP	2/25/2014	K1402219-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0210010	City of Hagerstown	1	R.C. Willson Filter Plant	SW	WTP POE	EP	2/25/2014	K1402219-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0210010	City of Hagerstown	1	R.C. Willson Filter Plant	SW	WTP POE	EP	2/25/2014	K1402219-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0210010	City of Hagerstown	1	R.C. Willson Filter Plant	SW	WTP POE	EP	2/25/2014	K1402219-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0210010	City of Hagerstown	1	R.C. Willson Filter Plant	SW	WTP POE	EP	2/25/2014	K1402219-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0210010	City of Hagerstown	1	R.C. Willson Filter Plant	SW	WTP POE	EP	2/25/2014	K1402219-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0210010	City of Hagerstown	1	R.C. Willson Filter Plant	SW	WTP POE	EP	5/14/2014	K1405027-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0210010	City of Hagerstown	1	R.C. Willson Filter Plant	SW	WTP POE	EP	5/14/2014	K1405027-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0210010	City of Hagerstown	1	R.C. Willson Filter Plant	SW	WTP POE	EP	5/14/2014	K1405027-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0210010	City of Hagerstown	1	R.C. Willson Filter Plant	SW	WTP POE	EP	5/14/2014	K1405027-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0210010	City of Hagerstown	1	R.C. Willson Filter Plant	SW	WTP POE	EP	5/14/2014	K1405027-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0210010	City of Hagerstown	1	R.C. Willson Filter Plant	SW	WTP POE	EP	5/14/2014	K1405027-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0220004	Salisbury	1	Park WTP	GW	WTP POE	EP	7/24/2013	K1307522-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0220004	Salisbury	1	Park WTP	GW	WTP POE	EP	7/24/2013	K1307522-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0220004	Salisbury	1	Park WTP	GW	WTP POE	EP	7/24/2013	K1307522-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0220004	Salisbury	1	Park WTP	GW	WTP POE	EP	7/24/2013	K1307522-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0220004	Salisbury	1	Park WTP	GW	WTP POE	EP	7/24/2013	K1307522-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0220004	Salisbury	1	Park WTP	GW	WTP POE	EP	7/24/2013	K1307522-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0220004	Salisbury	1	Park WTP	GW	WTP POE	EP	1/15/2014	K1400565-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0220004	Salisbury	1	Park WTP	GW	WTP POE	EP	1/15/2014	K1400565-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0220004	Salisbury	1	Park WTP	GW	WTP POE	EP	1/15/2014	K1400565-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0220004	Salisbury	1	Park WTP	GW	WTP POE	EP	1/15/2014	K1400565-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0220004	Salisbury	1	Park WTP	GW	WTP POE	EP	1/15/2014	K1400565-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0220004	Salisbury	1	Park WTP	GW	WTP POE	EP	1/15/2014	K1400565-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0220004	Salisbury	2	Paleo WTP	GW	WTP POE	EP	7/24/2013	K1307522-003	PFNA	EPA 537	<		0.02	ppb	MD
MD0220004	Salisbury	2	Paleo WTP	GW	WTP POE	EP	7/24/2013	K1307522-003	PFHxS	EPA 537	<		0.03	ppb	MD
MD0220004	Salisbury	2	Paleo WTP	GW	WTP POE	EP	7/24/2013	K1307522-003	PFHpA	EPA 537	<		0.01	ppb	MD
MD0220004	Salisbury	2	Paleo WTP	GW	WTP POE	EP	7/24/2013	K1307522-003	PFOA	EPA 537	<		0.02	ppb	MD
MD0220004	Salisbury	2	Paleo WTP	GW	WTP POE	EP	7/24/2013	K1307522-003	PFOS	EPA 537	<		0.04	ppb	MD
MD0220004	Salisbury	2	Paleo WTP	GW	WTP POE	EP	7/24/2013	K1307522-003	PFBS	EPA 537	<		0.09	ppb	MD
MD0220004	Salisbury	2	Paleo WTP	GW	WTP POE	EP	1/15/2014	K1400565-003	PFOS	EPA 537	<		0.04	ppb	MD
MD0220004	Salisbury	2	Paleo WTP	GW	WTP POE	EP	1/15/2014	K1400565-003	PFBS	EPA 537	<		0.09	ppb	MD
MD0220004	Salisbury	2	Paleo WTP	GW	WTP POE	EP	1/15/2014	K1400565-003	PFHxS	EPA 537	<		0.03	ppb	MD
MD0220004	Salisbury	2	Paleo WTP	GW	WTP POE	EP	1/15/2014	K1400565-003	PFHpA	EPA 537	<		0.01	ppb	MD
MD0220004	Salisbury	2	Paleo WTP	GW	WTP POE	EP	1/15/2014	K1400565-003	PFNA	EPA 537	<		0.02	ppb	MD
MD0220004	Salisbury	2	Paleo WTP	GW	WTP POE	EP	1/15/2014	K1400565-003	PFOA	EPA 537	<		0.02	ppb	MD
MD0220212	Harbour Light Estates	1	Well #3 Pumphouse	GW	WTP POE	EP	6/9/2015	113649P	PFBS	EPA 537	<		0.09	ppb	MD
MD0220212	Harbour Light Estates	1	Well #3 Pumphouse	GW	WTP POE	EP	6/9/2015	113649P	PFHpA	EPA 537	<		0.01	ppb	MD
MD0220212	Harbour Light Estates	1	Well #3 Pumphouse	GW	WTP POE	EP	6/9/2015	113649P	PFHxS	EPA 537	<		0.03	ppb	MD
MD0220212	Harbour Light Estates	1	Well #3 Pumphouse	GW	WTP POE	EP	6/9/2015	113649P	PFNA	EPA 537	<		0.02	ppb	MD
MD0220212	Harbour Light Estates	1	Well #3 Pumphouse	GW	WTP POE	EP	6/9/2015	113649P	PFOS	EPA 537	<		0.04	ppb	MD
MD0220212	Harbour Light Estates	1	Well #3 Pumphouse	GW	WTP POE	EP	6/9/2015	113649P	PFOA	EPA 537	<		0.02	ppb	MD
MD0220212	Harbour Light Estates	1	Well #3 Pumphouse	GW	WTP POE	EP	12/7/2015	116276P	PFBS	EPA 537	<		0.09	ppb	MD
MD0220212	Harbour Light Estates	1	Well #3 Pumphouse	GW	WTP POE	EP	12/7/2015	116276P	PFHpA	EPA 537	<		0.01	ppb	MD
MD0220212	Harbour Light Estates	1	Well #3 Pumphouse	GW	WTP POE	EP	12/7/2015	116276P	PFHxS	EPA 537	<		0.03	ppb	MD
MD0220212	Harbour Light Estates	1	Well #3 Pumphouse	GW	WTP POE	EP	12/7/2015	116276P	PFNA	EPA 537	<		0.02	ppb	MD
MD0220212	Harbour Light Estates	1	Well #3 Pumphouse	GW	WTP POE	EP	12/7/2015	116276P	PFOS	EPA 537	<		0.04	ppb	MD
MD0220212	Harbour Light Estates	1	Well #3 Pumphouse	GW	WTP POE	EP	12/7/2015	116276P	PFOA	EPA 537	<		0.02	ppb	MD
MD0230001	Town of Berlin	1	Williams St. STP	GW	WTP POE	EP	4/15/2013	101042P	PFBS	EPA 537	<		0.09	ppb	MD
MD0230001	Town of Berlin	1	Williams St. STP	GW	WTP POE	EP	4/15/2013	101042P	PFHpA	EPA 537	<		0.01	ppb	MD
MD0230001	Town of Berlin	1	Williams St. STP	GW	WTP POE	EP	4/15/2013	101042P	PFHxS	EPA 537	<		0.03	ppb	MD
MD0230001	Town of Berlin	1	Williams St. STP	GW	WTP POE	EP	4/15/2013	101042P	PFNA	EPA 537	<		0.02	ppb	MD
MD0230001	Town of Berlin	1	Williams St. STP	GW	WTP POE	EP	4/15/2013	101042P	PFOS	EPA 537	<		0.04	ppb	MD

MD0230001	Town of Berlin	1	Williams St. STP	GW	WTP POE	EP	4/15/2013	101042P	PFOA	EPA 537	<		0.02	ppb	MD
MD0230001	Town of Berlin	1	Williams St. STP	GW	WTP POE	EP	10/28/2013	102524P	PFBS	EPA 537	<		0.09	ppb	MD
MD0230001	Town of Berlin	1	Williams St. STP	GW	WTP POE	EP	10/28/2013	102524P	PFHpA	EPA 537	<		0.01	ppb	MD
MD0230001	Town of Berlin	1	Williams St. STP	GW	WTP POE	EP	10/28/2013	102524P	PFHxS	EPA 537	<		0.03	ppb	MD
MD0230001	Town of Berlin	1	Williams St. STP	GW	WTP POE	EP	10/28/2013	102524P	PFNA	EPA 537	<		0.02	ppb	MD
MD0230001	Town of Berlin	1	Williams St. STP	GW	WTP POE	EP	10/28/2013	102524P	PFOS	EPA 537	<		0.04	ppb	MD
MD0230001	Town of Berlin	1	Williams St. STP	GW	WTP POE	EP	10/28/2013	102524P	PFOA	EPA 537	<		0.02	ppb	MD
MD0230001	Town of Berlin	2	Franklin WTP (Well #2)	GW	WTP POE	EP	4/15/2013	101041P	PFBS	EPA 537	<		0.09	ppb	MD
MD0230001	Town of Berlin	2	Franklin WTP (Well #2)	GW	WTP POE	EP	4/15/2013	101041P	PFHpA	EPA 537	<		0.01	ppb	MD
MD0230001	Town of Berlin	2	Franklin WTP (Well #2)	GW	WTP POE	EP	4/15/2013	101041P	PFHxS	EPA 537	<		0.03	ppb	MD
MD0230001	Town of Berlin	2	Franklin WTP (Well #2)	GW	WTP POE	EP	4/15/2013	101041P	PFNA	EPA 537	<		0.02	ppb	MD
MD0230001	Town of Berlin	2	Franklin WTP (Well #2)	GW	WTP POE	EP	4/15/2013	101041P	PFOS	EPA 537	<		0.04	ppb	MD
MD0230001	Town of Berlin	2	Franklin WTP (Well #2)	GW	WTP POE	EP	4/15/2013	101041P	PFOA	EPA 537	<		0.02	ppb	MD
MD0230001	Town of Berlin	2	Franklin WTP (Well #2)	GW	WTP POE	EP	10/28/2013	102525P	PFBS	EPA 537	<		0.09	ppb	MD
MD0230001	Town of Berlin	2	Franklin WTP (Well #2)	GW	WTP POE	EP	10/28/2013	102525P	PFHpA	EPA 537	<		0.01	ppb	MD
MD0230001	Town of Berlin	2	Franklin WTP (Well #2)	GW	WTP POE	EP	10/28/2013	102525P	PFHxS	EPA 537	<		0.03	ppb	MD
MD0230001	Town of Berlin	2	Franklin WTP (Well #2)	GW	WTP POE	EP	10/28/2013	102525P	PFNA	EPA 537	<		0.02	ppb	MD
MD0230001	Town of Berlin	2	Franklin WTP (Well #2)	GW	WTP POE	EP	10/28/2013	102525P	PFOS	EPA 537	<		0.04	ppb	MD
MD0230001	Town of Berlin	2	Franklin WTP (Well #2)	GW	WTP POE	EP	10/28/2013	102525P	PFOA	EPA 537	<		0.02	ppb	MD
MD0230003	Ocean City	1	1400 St. Louis Ave. WTP	GW	WTP POE	EP	3/3/2015	K1502457-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0230003	Ocean City	1	1400 St. Louis Ave. WTP	GW	WTP POE	EP	3/3/2015	K1502457-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0230003	Ocean City	1	1400 St. Louis Ave. WTP	GW	WTP POE	EP	3/3/2015	K1502457-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0230003	Ocean City	1	1400 St. Louis Ave. WTP	GW	WTP POE	EP	3/3/2015	K1502457-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0230003	Ocean City	1	1400 St. Louis Ave. WTP	GW	WTP POE	EP	3/3/2015	K1502457-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0230003	Ocean City	1	1400 St. Louis Ave. WTP	GW	WTP POE	EP	3/3/2015	K1502457-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0230003	Ocean City	1	1400 St. Louis Ave. WTP	GW	WTP POE	EP	9/8/2015	K1510056-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0230003	Ocean City	1	1400 St. Louis Ave. WTP	GW	WTP POE	EP	9/8/2015	K1510056-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0230003	Ocean City	1	1400 St. Louis Ave. WTP	GW	WTP POE	EP	9/8/2015	K1510056-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0230003	Ocean City	1	1400 St. Louis Ave. WTP	GW	WTP POE	EP	9/8/2015	K1510056-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0230003	Ocean City	1	1400 St. Louis Ave. WTP	GW	WTP POE	EP	9/8/2015	K1510056-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0230003	Ocean City	1	1400 St. Louis Ave. WTP	GW	WTP POE	EP	9/8/2015	K1510056-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0230003	Ocean City	3	Gorman Avenue WTP	GW	WTP POE	EP	5/11/2015	K1505191-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0230003	Ocean City	3	Gorman Avenue WTP	GW	WTP POE	EP	5/11/2015	K1505191-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0230003	Ocean City	3	Gorman Avenue WTP	GW	WTP POE	EP	5/11/2015	K1505191-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0230003	Ocean City	3	Gorman Avenue WTP	GW	WTP POE	EP	5/11/2015	K1505191-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0230003	Ocean City	3	Gorman Avenue WTP	GW	WTP POE	EP	5/11/2015	K1505191-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0230003	Ocean City	3	Gorman Avenue WTP	GW	WTP POE	EP	5/11/2015	K1505191-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0230003	Ocean City	3	Gorman Avenue WTP	GW	WTP POE	EP	11/2/2015	K1512627-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0230003	Ocean City	3	Gorman Avenue WTP	GW	WTP POE	EP	11/2/2015	K1512627-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0230003	Ocean City	3	Gorman Avenue WTP	GW	WTP POE	EP	11/2/2015	K1512627-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0230003	Ocean City	3	Gorman Avenue WTP	GW	WTP POE	EP	11/2/2015	K1512627-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0230003	Ocean City	3	Gorman Avenue WTP	GW	WTP POE	EP	11/2/2015	K1512627-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0230003	Ocean City	3	Gorman Avenue WTP	GW	WTP POE	EP	11/2/2015	K1512627-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0230005	Ocean Pines	1	Well 3 WTP	GW	WTP POE	EP	11/13/2013	35116107001AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0230005	Ocean Pines	1	Well 3 WTP	GW	WTP POE	EP	11/13/2013	35116107001AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0230005	Ocean Pines	1	Well 3 WTP	GW	WTP POE	EP	11/13/2013	35116107001AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0230005	Ocean Pines	1	Well 3 WTP	GW	WTP POE	EP	11/13/2013	35116107001AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0230005	Ocean Pines	1	Well 3 WTP	GW	WTP POE	EP	11/13/2013	35116107001AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0230005	Ocean Pines	1	Well 3 WTP	GW	WTP POE	EP	11/13/2013	35116107001AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0230005	Ocean Pines	1	Well 3 WTP	GW	WTP POE	EP	5/15/2014	35138178001AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0230005	Ocean Pines	1	Well 3 WTP	GW	WTP POE	EP	5/15/2014	35138178001AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0230005	Ocean Pines	1	Well 3 WTP	GW	WTP POE	EP	5/15/2014	35138178001AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0230005	Ocean Pines	1	Well 3 WTP	GW	WTP POE	EP	5/15/2014	35138178001AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0230005	Ocean Pines	1	Well 3 WTP	GW	WTP POE	EP	5/15/2014	35138178001AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0230005	Ocean Pines	1	Well 3 WTP	GW	WTP POE	EP	5/15/2014	35138178001AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0230005	Ocean Pines	2	Well 4 WTP	GW	WTP POE	EP	11/13/2013	35116107005AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0230005	Ocean Pines	2	Well 4 WTP	GW	WTP POE	EP	11/13/2013	35116107005AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0230005	Ocean Pines	2	Well 4 WTP	GW	WTP POE	EP	11/13/2013	35116107005AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0230005	Ocean Pines	2	Well 4 WTP	GW	WTP POE	EP	11/13/2013	35116107005AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0230005	Ocean Pines	2	Well 4 WTP	GW	WTP POE	EP	11/13/2013	35116107005AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0230005	Ocean Pines	2	Well 4 WTP	GW	WTP POE	EP	11/13/2013	35116107005AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0230005	Ocean Pines	2	Well 4 WTP	GW	WTP POE	EP	5/14/2014	35138224001AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0230005	Ocean Pines	2	Well 4 WTP	GW	WTP POE	EP	5/14/2014	35138224001AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0230005	Ocean Pines	2	Well 4 WTP	GW	WTP POE	EP	5/14/2014	35138224001AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0230005	Ocean Pines	2	Well 4 WTP	GW	WTP POE	EP	5/14/2014	35138224001AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0230005	Ocean Pines	2	Well 4 WTP	GW	WTP POE	EP	5/14/2014	35138224001AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0230005	Ocean Pines	2	Well 4 WTP	GW	WTP POE	EP	5/14/2014	35138224001AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0230005	Ocean Pines	3	Well 5 WTP	GW	WTP POE	EP	11/12/2013	35115905001AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0230005	Ocean Pines	3	Well 5 WTP	GW	WTP POE	EP	11/12/2013	35115905001AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0230005	Ocean Pines	3	Well 5 WTP	GW	WTP POE	EP	11/12/2013	35115905001AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0230005	Ocean Pines	3	Well 5 WTP	GW	WTP POE	EP	11/12/2013	35115905001AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0230005	Ocean Pines	3	Well 5 WTP	GW	WTP POE	EP	11/12/2013	35115905001AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0230005	Ocean Pines	3	Well 5 WTP	GW	WTP POE	EP	11/12/2013	35115905001AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0230005	Ocean Pines	3	Well 5 WTP	GW	WTP POE	EP	5/14/2014	35138176001AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0230005	Ocean Pines	3	Well 5 WTP	GW	WTP POE	EP	5/14/2014	35138176001AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0230005	Ocean Pines	3	Well 5 WTP	GW	WTP POE	EP	5/14/2014	35138176001AM	PFHxS	EPA 537	<		0.03	ppb	MD

MD0230005	Ocean Pines	3	Well 5 WTP	GW	WTP POE	EP	5/14/2014	35138176001AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0230005	Ocean Pines	3	Well 5 WTP	GW	WTP POE	EP	5/14/2014	35138176001AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0230005	Ocean Pines	3	Well 5 WTP	GW	WTP POE	EP	5/14/2014	35138176001AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0230005	Ocean Pines	4	Well 2 WTP	GW	WTP POE	EP	11/12/2013	35115903001AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0230005	Ocean Pines	4	Well 2 WTP	GW	WTP POE	EP	11/12/2013	35115903001AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0230005	Ocean Pines	4	Well 2 WTP	GW	WTP POE	EP	11/12/2013	35115903001AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0230005	Ocean Pines	4	Well 2 WTP	GW	WTP POE	EP	11/12/2013	35115903001AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0230005	Ocean Pines	4	Well 2 WTP	GW	WTP POE	EP	11/12/2013	35115903001AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0230005	Ocean Pines	4	Well 2 WTP	GW	WTP POE	EP	11/12/2013	35115903001AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0230005	Ocean Pines	4	Well 2 WTP	GW	WTP POE	EP	5/14/2014	35138174001AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0230005	Ocean Pines	4	Well 2 WTP	GW	WTP POE	EP	5/14/2014	35138174001AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0230005	Ocean Pines	4	Well 2 WTP	GW	WTP POE	EP	5/14/2014	35138174001AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0230005	Ocean Pines	4	Well 2 WTP	GW	WTP POE	EP	5/14/2014	35138174001AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0230005	Ocean Pines	4	Well 2 WTP	GW	WTP POE	EP	5/14/2014	35138174001AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0230005	Ocean Pines	4	Well 2 WTP	GW	WTP POE	EP	5/14/2014	35138174001AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0230005	Ocean Pines	5	Well 10 WTP	GW	WTP POE	EP	11/12/2013	35115909001AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0230005	Ocean Pines	5	Well 10 WTP	GW	WTP POE	EP	11/12/2013	35115909001AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0230005	Ocean Pines	5	Well 10 WTP	GW	WTP POE	EP	11/12/2013	35115909001AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0230005	Ocean Pines	5	Well 10 WTP	GW	WTP POE	EP	11/12/2013	35115909001AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0230005	Ocean Pines	5	Well 10 WTP	GW	WTP POE	EP	11/12/2013	35115909001AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0230005	Ocean Pines	5	Well 10 WTP	GW	WTP POE	EP	11/12/2013	35115909001AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0230005	Ocean Pines	5	Well 10 WTP	GW	WTP POE	EP	5/14/2014	35138218001AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0230005	Ocean Pines	5	Well 10 WTP	GW	WTP POE	EP	5/14/2014	35138218001AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0230005	Ocean Pines	5	Well 10 WTP	GW	WTP POE	EP	5/14/2014	35138218001AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0230005	Ocean Pines	5	Well 10 WTP	GW	WTP POE	EP	5/14/2014	35138218001AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0230005	Ocean Pines	5	Well 10 WTP	GW	WTP POE	EP	5/14/2014	35138218001AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0230005	Ocean Pines	5	Well 10 WTP	GW	WTP POE	EP	5/14/2014	35138218001AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0230007	Town of Snow Hill	1	Ross Street WTP	GW	WTP POE	EP	4/8/2014	106569P	PFBS	EPA 537	<		0.09	ppb	MD
MD0230007	Town of Snow Hill	1	Ross Street WTP	GW	WTP POE	EP	4/8/2014	106569P	PFHpA	EPA 537	<		0.01	ppb	MD
MD0230007	Town of Snow Hill	1	Ross Street WTP	GW	WTP POE	EP	4/8/2014	106569P	PFHxS	EPA 537	<		0.03	ppb	MD
MD0230007	Town of Snow Hill	1	Ross Street WTP	GW	WTP POE	EP	4/8/2014	106569P	PFNA	EPA 537	<		0.02	ppb	MD
MD0230007	Town of Snow Hill	1	Ross Street WTP	GW	WTP POE	EP	4/8/2014	106569P	PFOS	EPA 537	<		0.04	ppb	MD
MD0230007	Town of Snow Hill	1	Ross Street WTP	GW	WTP POE	EP	4/8/2014	106569P	PFOA	EPA 537	<		0.02	ppb	MD
MD0230007	Town of Snow Hill	1	Ross Street WTP	GW	WTP POE	EP	10/8/2014	109422P	PFBS	EPA 537	<		0.09	ppb	MD
MD0230007	Town of Snow Hill	1	Ross Street WTP	GW	WTP POE	EP	10/8/2014	109422P	PFHpA	EPA 537	<		0.01	ppb	MD
MD0230007	Town of Snow Hill	1	Ross Street WTP	GW	WTP POE	EP	10/8/2014	109422P	PFHxS	EPA 537	<		0.03	ppb	MD
MD0230007	Town of Snow Hill	1	Ross Street WTP	GW	WTP POE	EP	10/8/2014	109422P	PFNA	EPA 537	<		0.02	ppb	MD
MD0230007	Town of Snow Hill	1	Ross Street WTP	GW	WTP POE	EP	10/8/2014	109422P	PFOS	EPA 537	<		0.04	ppb	MD
MD0230007	Town of Snow Hill	1	Ross Street WTP	GW	WTP POE	EP	10/8/2014	109422P	PFOA	EPA 537	<		0.02	ppb	MD
MD0230007	Town of Snow Hill	2	Washington St. WTP	GW	WTP POE	EP	4/8/2014	106570P	PFBS	EPA 537	<		0.09	ppb	MD
MD0230007	Town of Snow Hill	2	Washington St. WTP	GW	WTP POE	EP	4/8/2014	106570P	PFHpA	EPA 537	<		0.01	ppb	MD
MD0230007	Town of Snow Hill	2	Washington St. WTP	GW	WTP POE	EP	4/8/2014	106570P	PFHxS	EPA 537	<		0.03	ppb	MD
MD0230007	Town of Snow Hill	2	Washington St. WTP	GW	WTP POE	EP	4/8/2014	106570P	PFNA	EPA 537	<		0.02	ppb	MD
MD0230007	Town of Snow Hill	2	Washington St. WTP	GW	WTP POE	EP	4/8/2014	106570P	PFOS	EPA 537	<		0.04	ppb	MD
MD0230007	Town of Snow Hill	2	Washington St. WTP	GW	WTP POE	EP	4/8/2014	106570P	PFOA	EPA 537	<		0.02	ppb	MD
MD0230007	Town of Snow Hill	2	Washington St. WTP	GW	WTP POE	EP	10/14/2014	109423P	PFBS	EPA 537	<		0.09	ppb	MD
MD0230007	Town of Snow Hill	2	Washington St. WTP	GW	WTP POE	EP	10/14/2014	109423P	PFHpA	EPA 537	<		0.01	ppb	MD
MD0230007	Town of Snow Hill	2	Washington St. WTP	GW	WTP POE	EP	10/14/2014	109423P	PFHxS	EPA 537	<		0.03	ppb	MD
MD0230007	Town of Snow Hill	2	Washington St. WTP	GW	WTP POE	EP	10/14/2014	109423P	PFNA	EPA 537	<		0.02	ppb	MD
MD0230007	Town of Snow Hill	2	Washington St. WTP	GW	WTP POE	EP	10/14/2014	109423P	PFOS	EPA 537	<		0.04	ppb	MD
MD0230007	Town of Snow Hill	2	Washington St. WTP	GW	WTP POE	EP	10/14/2014	109423P	PFOA	EPA 537	<		0.02	ppb	MD
MD0230007	Town of Snow Hill	3	Colbourne Lane WTP	GW	WTP POE	EP	4/8/2014	106571P	PFBS	EPA 537	<		0.09	ppb	MD
MD0230007	Town of Snow Hill	3	Colbourne Lane WTP	GW	WTP POE	EP	4/8/2014	106571P	PFHpA	EPA 537	<		0.01	ppb	MD
MD0230007	Town of Snow Hill	3	Colbourne Lane WTP	GW	WTP POE	EP	4/8/2014	106571P	PFHxS	EPA 537	<		0.03	ppb	MD
MD0230007	Town of Snow Hill	3	Colbourne Lane WTP	GW	WTP POE	EP	4/8/2014	106571P	PFNA	EPA 537	<		0.02	ppb	MD
MD0230007	Town of Snow Hill	3	Colbourne Lane WTP	GW	WTP POE	EP	4/8/2014	106571P	PFOS	EPA 537	<		0.04	ppb	MD
MD0230007	Town of Snow Hill	3	Colbourne Lane WTP	GW	WTP POE	EP	4/8/2014	106571P	PFOA	EPA 537	<		0.02	ppb	MD
MD0230007	Town of Snow Hill	3	Colbourne Lane WTP	GW	WTP POE	EP	11/5/2014	109805R	PFBS	EPA 537	<		0.09	ppb	MD
MD0230007	Town of Snow Hill	3	Colbourne Lane WTP	GW	WTP POE	EP	11/5/2014	109805R	PFHpA	EPA 537	<		0.01	ppb	MD
MD0230007	Town of Snow Hill	3	Colbourne Lane WTP	GW	WTP POE	EP	11/5/2014	109805R	PFHxS	EPA 537	<		0.03	ppb	MD
MD0230007	Town of Snow Hill	3	Colbourne Lane WTP	GW	WTP POE	EP	11/5/2014	109805R	PFNA	EPA 537	<		0.02	ppb	MD
MD0230007	Town of Snow Hill	3	Colbourne Lane WTP	GW	WTP POE	EP	11/5/2014	109805R	PFOS	EPA 537	<		0.04	ppb	MD
MD0230007	Town of Snow Hill	3	Colbourne Lane WTP	GW	WTP POE	EP	11/5/2014	109805R	PFOA	EPA 537	<		0.02	ppb	MD
MD0300002	Baltimore City	1	Ashburton Filter Plant	SW	WTP POE	EP	2/2/2015	K1501252-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0300002	Baltimore City	1	Ashburton Filter Plant	SW	WTP POE	EP	2/2/2015	K1501252-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0300002	Baltimore City	1	Ashburton Filter Plant	SW	WTP POE	EP	2/2/2015	K1501252-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0300002	Baltimore City	1	Ashburton Filter Plant	SW	WTP POE	EP	2/2/2015	K1501252-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0300002	Baltimore City	1	Ashburton Filter Plant	SW	WTP POE	EP	2/2/2015	K1501252-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0300002	Baltimore City	1	Ashburton Filter Plant	SW	WTP POE	EP	2/2/2015	K1501252-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0300002	Baltimore City	1	Ashburton Filter Plant	SW	WTP POE	EP	4/23/2015	K1504552-001AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0300002	Baltimore City	1	Ashburton Filter Plant	SW	WTP POE	EP	4/23/2015	K1504552-001AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0300002	Baltimore City	1	Ashburton Filter Plant	SW	WTP POE	EP	4/23/2015	K1504552-001AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0300002	Baltimore City	1	Ashburton Filter Plant	SW	WTP POE	EP	4/23/2015	K1504552-001AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0300002	Baltimore City	1	Ashburton Filter Plant	SW	WTP POE	EP	4/23/2015	K1504552-001AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0300002	Baltimore City	1	Ashburton Filter Plant	SW	WTP POE	EP	4/23/2015	K1504552-001AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0300002	Baltimore City	1	Ashburton Filter Plant	SW	WTP POE	EP	7/22/2015	K1508273-003AM	PFHpA	EPA 537	<		0.01	ppb	MD

MD0300002	Baltimore City	1	Ashburton Filter Plant	SW	WTP POE	EP	7/22/2015	K1508273-003AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0300002	Baltimore City	1	Ashburton Filter Plant	SW	WTP POE	EP	7/22/2015	K1508273-003AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0300002	Baltimore City	1	Ashburton Filter Plant	SW	WTP POE	EP	7/22/2015	K1508273-003AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0300002	Baltimore City	1	Ashburton Filter Plant	SW	WTP POE	EP	7/22/2015	K1508273-003AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0300002	Baltimore City	1	Ashburton Filter Plant	SW	WTP POE	EP	7/22/2015	K1508273-003AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0300002	Baltimore City	1	Ashburton Filter Plant	SW	WTP POE	EP	10/27/2015	K1512379-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0300002	Baltimore City	1	Ashburton Filter Plant	SW	WTP POE	EP	10/27/2015	K1512379-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0300002	Baltimore City	1	Ashburton Filter Plant	SW	WTP POE	EP	10/27/2015	K1512379-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0300002	Baltimore City	1	Ashburton Filter Plant	SW	WTP POE	EP	10/27/2015	K1512379-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0300002	Baltimore City	1	Ashburton Filter Plant	SW	WTP POE	EP	10/27/2015	K1512379-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0300002	Baltimore City	1	Ashburton Filter Plant	SW	WTP POE	EP	10/27/2015	K1512379-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0300002	Baltimore City	2	Montebello Filter Plant #1	SW	WTP POE	EP	2/2/2015	K1501251-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0300002	Baltimore City	2	Montebello Filter Plant #1	SW	WTP POE	EP	2/2/2015	K1501251-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0300002	Baltimore City	2	Montebello Filter Plant #1	SW	WTP POE	EP	2/2/2015	K1501251-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0300002	Baltimore City	2	Montebello Filter Plant #1	SW	WTP POE	EP	2/2/2015	K1501251-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0300002	Baltimore City	2	Montebello Filter Plant #1	SW	WTP POE	EP	2/2/2015	K1501251-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0300002	Baltimore City	2	Montebello Filter Plant #1	SW	WTP POE	EP	2/2/2015	K1501251-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0300002	Baltimore City	2	Montebello Filter Plant #1	SW	WTP POE	EP	4/23/2015	K1504552-003AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0300002	Baltimore City	2	Montebello Filter Plant #1	SW	WTP POE	EP	4/23/2015	K1504552-003AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0300002	Baltimore City	2	Montebello Filter Plant #1	SW	WTP POE	EP	4/23/2015	K1504552-003AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0300002	Baltimore City	2	Montebello Filter Plant #1	SW	WTP POE	EP	4/23/2015	K1504552-003AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0300002	Baltimore City	2	Montebello Filter Plant #1	SW	WTP POE	EP	4/23/2015	K1504552-003AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0300002	Baltimore City	2	Montebello Filter Plant #1	SW	WTP POE	EP	4/23/2015	K1504552-003AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0300002	Baltimore City	2	Montebello Filter Plant #1	SW	WTP POE	EP	7/22/2015	K1508273-005AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0300002	Baltimore City	2	Montebello Filter Plant #1	SW	WTP POE	EP	7/22/2015	K1508273-005AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0300002	Baltimore City	2	Montebello Filter Plant #1	SW	WTP POE	EP	7/22/2015	K1508273-005AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0300002	Baltimore City	2	Montebello Filter Plant #1	SW	WTP POE	EP	7/22/2015	K1508273-005AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0300002	Baltimore City	2	Montebello Filter Plant #1	SW	WTP POE	EP	7/22/2015	K1508273-005AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0300002	Baltimore City	2	Montebello Filter Plant #1	SW	WTP POE	EP	7/22/2015	K1508273-005AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0300002	Baltimore City	2	Montebello Filter Plant #1	SW	WTP POE	EP	10/27/2015	K1512379-003	PFHpA	EPA 537	<		0.01	ppb	MD
MD0300002	Baltimore City	2	Montebello Filter Plant #1	SW	WTP POE	EP	10/27/2015	K1512379-003	PFBS	EPA 537	<		0.09	ppb	MD
MD0300002	Baltimore City	2	Montebello Filter Plant #1	SW	WTP POE	EP	10/27/2015	K1512379-003	PFHxS	EPA 537	<		0.03	ppb	MD
MD0300002	Baltimore City	2	Montebello Filter Plant #1	SW	WTP POE	EP	10/27/2015	K1512379-003	PFNA	EPA 537	<		0.02	ppb	MD
MD0300002	Baltimore City	2	Montebello Filter Plant #1	SW	WTP POE	EP	10/27/2015	K1512379-003	PFOS	EPA 537	<		0.04	ppb	MD
MD0300002	Baltimore City	2	Montebello Filter Plant #1	SW	WTP POE	EP	10/27/2015	K1512379-003	PFOA	EPA 537	<		0.02	ppb	MD
MD0300002	Baltimore City	3	Montebello Filter Plant #2	SW	WTP POE	EP	2/2/2015	K1501238-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0300002	Baltimore City	3	Montebello Filter Plant #2	SW	WTP POE	EP	2/2/2015	K1501238-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0300002	Baltimore City	3	Montebello Filter Plant #2	SW	WTP POE	EP	2/2/2015	K1501238-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0300002	Baltimore City	3	Montebello Filter Plant #2	SW	WTP POE	EP	2/2/2015	K1501238-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0300002	Baltimore City	3	Montebello Filter Plant #2	SW	WTP POE	EP	2/2/2015	K1501238-001	PFOA	EPA 537	<		0.02	ppb	MD
MD0300002	Baltimore City	3	Montebello Filter Plant #2	SW	WTP POE	EP	2/2/2015	K1501238-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0300002	Baltimore City	3	Montebello Filter Plant #2	SW	WTP POE	EP	4/23/2015	K1504552-005AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0300002	Baltimore City	3	Montebello Filter Plant #2	SW	WTP POE	EP	4/23/2015	K1504552-005AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0300002	Baltimore City	3	Montebello Filter Plant #2	SW	WTP POE	EP	4/23/2015	K1504552-005AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0300002	Baltimore City	3	Montebello Filter Plant #2	SW	WTP POE	EP	4/23/2015	K1504552-005AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0300002	Baltimore City	3	Montebello Filter Plant #2	SW	WTP POE	EP	4/23/2015	K1504552-005AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0300002	Baltimore City	3	Montebello Filter Plant #2	SW	WTP POE	EP	4/23/2015	K1504552-005AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0300002	Baltimore City	3	Montebello Filter Plant #2	SW	WTP POE	EP	7/22/2015	K1508273-001AM	PFBS	EPA 537	<		0.09	ppb	MD
MD0300002	Baltimore City	3	Montebello Filter Plant #2	SW	WTP POE	EP	7/22/2015	K1508273-001AM	PFOS	EPA 537	<		0.04	ppb	MD
MD0300002	Baltimore City	3	Montebello Filter Plant #2	SW	WTP POE	EP	7/22/2015	K1508273-001AM	PFOA	EPA 537	<		0.02	ppb	MD
MD0300002	Baltimore City	3	Montebello Filter Plant #2	SW	WTP POE	EP	7/22/2015	K1508273-001AM	PFNA	EPA 537	<		0.02	ppb	MD
MD0300002	Baltimore City	3	Montebello Filter Plant #2	SW	WTP POE	EP	7/22/2015	K1508273-001AM	PFHxS	EPA 537	<		0.03	ppb	MD
MD0300002	Baltimore City	3	Montebello Filter Plant #2	SW	WTP POE	EP	7/22/2015	K1508273-001AM	PFHpA	EPA 537	<		0.01	ppb	MD
MD0300002	Baltimore City	3	Montebello Filter Plant #2	SW	WTP POE	EP	10/27/2015	K1512381-001	PFNA	EPA 537	<		0.02	ppb	MD
MD0300002	Baltimore City	3	Montebello Filter Plant #2	SW	WTP POE	EP	10/27/2015	K1512381-001	PFBS	EPA 537	<		0.09	ppb	MD
MD0300002	Baltimore City	3	Montebello Filter Plant #2	SW	WTP POE	EP	10/27/2015	K1512381-001	PFHxS	EPA 537	<		0.03	ppb	MD
MD0300002	Baltimore City	3	Montebello Filter Plant #2	SW	WTP POE	EP	10/27/2015	K1512381-001	PFHpA	EPA 537	<		0.01	ppb	MD
MD0300002	Baltimore City	3	Montebello Filter Plant #2	SW	WTP POE	EP	10/27/2015	K1512381-001	PFOS	EPA 537	<		0.04	ppb	MD
MD0300002	Baltimore City	3	Montebello Filter Plant #2	SW	WTP POE	EP	10/27/2015	K1512381-001	PFOA	EPA 537	<		0.02	ppb	MD
MD1230063	Midway Chevrolet	1	Well #1 Pumphouse	GW	WTP POE	EP	1/6/2015	111017Q	PFBS	EPA 537	<		0.09	ppb	MD
MD1230063	Midway Chevrolet	1	Well #1 Pumphouse	GW	WTP POE	EP	1/6/2015	111017Q	PFHpA	EPA 537	<		0.01	ppb	MD
MD1230063	Midway Chevrolet	1	Well #1 Pumphouse	GW	WTP POE	EP	1/6/2015	111017Q	PFHxS	EPA 537	<		0.03	ppb	MD
MD1230063	Midway Chevrolet	1	Well #1 Pumphouse	GW	WTP POE	EP	1/6/2015	111017Q	PFNA	EPA 537	<		0.02	ppb	MD
MD1230063	Midway Chevrolet	1	Well #1 Pumphouse	GW	WTP POE	EP	1/6/2015	111017Q	PFOS	EPA 537	<		0.04	ppb	MD
MD1230063	Midway Chevrolet	1	Well #1 Pumphouse	GW	WTP POE	EP	1/6/2015	111017Q	PFOA	EPA 537	<		0.02	ppb	MD
MD1230063	Midway Chevrolet	1	Well #1 Pumphouse	GW	WTP POE	EP	7/6/2015	114591Q	PFBS	EPA 537	<		0.09	ppb	MD
MD1230063	Midway Chevrolet	1	Well #1 Pumphouse	GW	WTP POE	EP	7/6/2015	114591Q	PFHpA	EPA 537	<		0.01	ppb	MD
MD1230063	Midway Chevrolet	1	Well #1 Pumphouse	GW	WTP POE	EP	7/6/2015	114591Q	PFHxS	EPA 537	<		0.03	ppb	MD
MD1230063	Midway Chevrolet	1	Well #1 Pumphouse	GW	WTP POE	EP	7/6/2015	114591Q	PFNA	EPA 537	<		0.02	ppb	MD
MD1230063	Midway Chevrolet	1	Well #1 Pumphouse	GW	WTP POE	EP	7/6/2015	114591Q	PFOS	EPA 537	<		0.04	ppb	MD
MD1230063	Midway Chevrolet	1	Well #1 Pumphouse	GW	WTP POE	EP	7/6/2015	114591Q	PFOA	EPA 537	<		0.02	ppb	MD