

Annual Drinking Water Quality Report

MD0060013

TOWN OF UNION BRIDGE

Annual Water Quality Report for the period of January 1 to December 31, 2022

For more information regarding this report contact:

Dawn Metcalf 410.775.2711

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

Public participation is encouraged at the regularly scheduled Town Hall meetings occurring on the Fourth Monday of every month at the Town Hall

104 West Locust St.

TOWN OF UNION BRIDGE is Ground Water Under Direct Influence of Surface water

Este informe contiene información muy importante sobre el agua que usted. bebe. Tradúzcalo ó hable con alguien que lo entienda bien

A source water assessment has been performed by the Maryland Department of the Environment and is accessible on their website at:

https://mde.maryland.gov/programs/Water/water_Supply/Source_Water_Assessment_Program/Pages/by_county.aspx

-Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of Union Bridge is responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

"PFAS – short for per- and polyfluoroalkyl substances – refers to a large group of more than 4,000 human-made chemicals that have been used since the 1940s in a range of products, including stain- and water-resistant fabrics and carpeting, cleaning products, paints, cookware, food packaging and fire-fighting foams. These uses of PFAS have led to PFAS entering our environment, where they have been measured by several states in soil, surface water, groundwater and seafood. Some PFAS can last a long time in the environment and in the human body and can accumulate in the food chain.

Beginning in 2020, the Maryland Department of the Environment (MDE) initiated a PFAS monitoring program. PFOA and PFOS are two of the most prevalent PFAS compounds. PFOA and PFOS concentrations from samples taken from our water system in 2022 were 3.78 parts per trillion (ppt) and 16.7 ppt respectively, which resulted in the distribution of a tier two notice as required by MDE. In March 2023, EPA announced proposed maximum contaminate levels (MCLs) of 4 ppt for PFOA and 4 ppt for PFOS, and a Group Hazard Index for four additional PFAS compounds. Future regulations would require additional monitoring as well as certain actions for systems above the MCL or Hazard Index. EPA will publish the final MCLs and requirements by the end of 2023 or the beginning of 2024. Additional information about PFAS can be found on the MDE website: mde.maryland.gov/PublicHealth/PFAS-Landing-Page.aspx"

Source Water Information

SWA = Source Water Assessment

Source Water Name	Type of Water	Report Status	Location
UNION BRIDGE TOWN HALL NOPERMIT GU	GU	Y	
WHYTE ST WELL (FIRE DEPT) CL940608 GUCL940608	GU	Y	T OF UNION BRIDGE APPROX. 50 FT S OF LOCUST

2022 Regulated Contaminants Detected

Lead and Copper

Definitions:

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety. Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Lead and Copper	Likely Source of contamination
Copper	09/24/2021	1.3	1.3	0.42	0	ppm	Copper	Erosion of natural deposits Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	09/24/2021	0	15	<5	0	ppb	Lead	Corrosion of household plumbing systems; Erosion of natural deposits.

Disinfectants and

Disinfection By-Products	Collection Date	Highest Level	Range of Levels	MCLG	MCL	Units	Violation	Likely Source of contamination
		Detected	Detected					
Chlorine	2022	1.7	1.6 - 1.8	MRDLG = 4	MRDL = 4	ppm	N	Water additive used to control microbes.
Haloacetic Acids (HAA5)	2022	6.9	0 – 11.7	No goal for the total	60	ppb	N	By-product of drinking water disinfection
Total Trihalomethanes(TTHM)	2022	42.7	19.4 – 69.9	No goal for the total	80	ppb	N	By-product of drinking water disinfection.

Inorganic Contaminants

Barium	08/14/2021	0.033	0.033 - 0.033	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Nitrate [measured as Nitrogen]	2022	6	5.58 – 5.69	10	10	ppm	N	Runoff from fertilizer use, Leaching from Septic tanks, Erosion of natural deposits

- Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health care provider.

Turbidity

	Limit (Treatment Technique)	Level Detected	Violation	Likely Source of contamination
Highest single measurement	1 NTU	0.19 NTU	N	Soil runoff.

Information Statement: Turbidity is a measurement of the cloudiness of the water caused by suspended particles. We monitor it because it is a good indicator of water quality and the effectiveness of our filtration

95PT

Lowest monthly % meeting limit	0.3 NTU	100%	N	Soil runoff.
---------------------------------------	---------	------	---	--------------

Unregulated Contaminants

PFAS

	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of contamination
PFAS	10/22	41.01	41.	NA	NA	ppt	N	Anthropogenic activity
PFOS	10/22	16.7	16.	NA	NA	ppt	N	Anthropogenic activity
PFOA	10/22	3.78	3.78	NA	NA	ppt	N	Anthropogenic activity
PFHxS	10/22	9.85	9.85	NA	NA	ppt	N	Anthropogenic activity
HFPO-DA	10/22	<1	<1	NA	NA	ppt	N	Anthropogenic activity
PFBS	10/22	4.28	4.28	NA	NA	ppt	N	Anthropogenic activity

Water Quality Test Results

Definitions: The following tables contain scientific terms and measures, some of which may require explanation.

Avg: Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total Coliform bacteria have been found in our water system.

Maximum Contaminant Level Goal or MCLG:

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Level 2 Assessment:

A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum residual disinfectant level or MRDL:

The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG:

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

na: not applicable.

ppt: nanograms per liter or parts per trillion – or one ounce in 7,350,000,000 gallons of water

ppb: micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.

ppm: milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.

Treatment Technique or TT:

A required process intended to reduce the level of a contaminant in drinking water.